COUNTY OF ESSEX

LEROY SMITH PUBLIC SAFETY BUILDING

60 Nelson Place, Newark, NJ, 07102

LOCAL GOVERNMENT ENERGY AUDIT PROGRAM FOR NEW JERSEY BOARD OF PUBLIC UTILITIES

January 2015

Prepared by:



6 Campus Drive Parsippany, NJ 07054 (973) 538-2120

CHA PROJECT NO. 29142

TABLE OF CONTENTS

1.0 EXE	ECUTIVE SUMMARY	. 1
2.0 BUI	LDING INFORMATION AND EXISTING CONDITIONS	. 4
3.0 UTI	LITIES	. 8
4.0 BEN	NCHMARKING	11
5.0 ENE	ERGY CONSERVATION MEASURES	12
5.1	ECM-1 Central Control System Retro-Commissioning	13
5.2	ECM-2 Replace DHW Water Heater with Condensing DHW Water Heater	14
5.3.1	ECM-L1 Lighting Replacement / Upgrades	14
5.3.2	ECM-L2 Install Lighting Controls (Occupancy Sensors)	15
5.3.3	ECM-L3 Lighting Replacements with Controls (Occupancy Sensors)	15
5.4	Additional O&M Opportunities	16
6.0 PRC	OJECT INCENTIVES	17
6.1	Incentives Overview	17
6.1.1	New Jersey Smart Start Program	17
6.1.2	Direct Install Program	17
6.1.3	New Jersey Pay For Performance Program (P4P)	18
6.1.4	Energy Savings Improvement Plan	19
6.1.5	Renewable Energy Incentive Program	20
7.0 ALT	ERNATIVE ENERGY SCREENING EVALUATION	21
7.1	Solar	21
7.1.1	Photovoltaic Rooftop Solar Power Generation	21
7.1.2	Solar Thermal Hot Water Generation	22
7.2	Wind Powered Turbines	22
7.3	Combined Heat and Power Plant	23
7.4	Demand Response Curtailment	24
8.0 COI	NCLUSIONS & RECOMMENDATIONS	26

APPENDICES

- A Utility Usage Analysis and List of Third Party Energy Suppliers
- B Equipment Inventory
- C ECM Calculations and Cost Estimates
- D New Jersey BPU Incentive Programs
 - i. Smart Start
 - ii. Direct Install
 - iii. Pay For Performance Incentive Program (P4P)
 - iv. Energy Savings Improvement Plan (ESIP)
- E Photovoltaic (PV) Solar Power Generation Analysis
- F Photos
- G EPA Benchmarking Report

REPORT DISCLAIMER

This audit was conducted in accordance with the standards developed by the American Society of Heating, Refrigerating, and Air-Conditioning Engineers (ASHRAE) for a Level II audit. Cost and savings calculations for a given measure were estimated to within $\pm 20\%$, and are based on data obtained from the owner, data obtained during site observations, professional experience, historical data, and standard engineering practice. Cost data does not include soft costs such as engineering fees, legal fees, project management fees, financing, etc.

A thorough walkthrough of the building was performed, which included gathering nameplate information and operating parameters for all accessible equipment and lighting systems. Unless otherwise stated, model, efficiency, and capacity information included in this report were collected directly from equipment nameplates and /or from documentation provided by the owner during the site visit. Typical operation and scheduling information was obtained from interviewing staff and spot measurements taken in the field.

List of Common Energy Audit Abbreviations

- A/C Air Conditioning
- AHS Air Handling Unit
- BMS Building Management System
- Btu British thermal unit
- CDW Condenser Water
- CFM Cubic feet per minute
- CHW Chilled Water
- DCV Demand Control Ventilation
- DDC Direct Digital Control
- DHW Domestic Hot Water
- DX Direct Expansion
- EER Energy Efficiency Ratio
- EF Exhaust Fan
- EUI Energy Use Intensity
- Gal Gallon
- GPD Gallons per day
- GPF Gallons Per Flush
- GPH Gallons per hour
- GPM Gallons per minute
- GPS Gallons per second
- HHW Heating Hot Water
- HID High Intensity Discharge
- HP Horsepower
- HRU Heat Recovery Unit
- HVAC Heating, Ventilation, Air Conditioning
- HX Heat Exchanger
- kbtu/mbtu One thousand (1,000) Btu
- kW Kilowatt (1,000 watts)
- kWh Kilowatt-hours
- LED Light Emitting Diode
- mbh Thousand Btu per hour
- mmbtu One million (1,000,000) Btu
- OCC Occupancy Sensor
- PSI Pounds per square inch
- RTU Rooftop Unit
- SBC System Benefits Charge
- SF Square foot
- UH Unit Heater
- V Volts
- VAV Variable Air Volume
- VSD Variable Speed Drive
- W-Watt

1.0 EXECUTIVE SUMMARY

This report summarizes the energy audit performed by CHA for Essex County (EC) in connection with the New Jersey Board of Public Utilities (NJBPU) Local Government Energy Audit (LGEA) Program. The purpose of this report is to identify energy savings opportunities associated with major energy consumers and inefficient practices. Low-cost and no-cost are also identified during the study. This report details the results of the energy audit conducted for the building listed below:

Building Name Address		Square Feet	Construction Date
Leroy Smith Public Safety Building	60 Nelson Place, Newark, NJ, 07102	129,050	1963

The potential total annual energy and cost savings for the recommended energy conservation measures (ECM) identified in the survey are shown below:

Building Name	Electric Savings (kWh)	NG Savings (therms)	Total Savings (\$)	Payback (years)
Leroy Smith Public Safety Building	180,321	3,063	29,569	6.9

Each individual measure's annual savings are dependent on that measure alone, there are no interactive effects calculated. There are three options shown for Lighting ECM savings; only one option can be chosen. Incentives shown (if any) are based only on the SmartStart Incentive Program. Other NJBPU or local utility incentives may also be available/ applicable and are discussed in Section 6.0.

Each measure recommended by CHA typically has a stand-alone simple payback period of 15 years or less. However, if the owner choses to pursue an Energy Savings Improvement Plan (ESIP), high payback measures could be bundled with lower payback measures which ultimately can result in a payback which is favorable for an ESIP project to proceed. Occasionally, we will recommend an ECM that has a longer payback period, based on the need to replace that piece(s) of equipment due to its age, such as a boiler for example.

The following table provides a detailed summary of each ECM for the building surveyed, including costs, savings, SmartStart incentives and payback.

ECM #	Energy Conservation Measure	Est. Costs (\$)	Est. Savings (\$/year)	Payback w/o Incentive	Potential Incentive (\$)*	Payback w/ Incentive	Recommended
ECM-1	Central DDC System Retro-commissioning	56,279	8,235	6.8	0	6.8	Y
ECM-2	Replace DHW Water Heater with Condensing DHW Water Heater	11,780	611	19.3	120	19.1	Y
ECM- L1**	Lighting Replacements / Upgrades	114,708	18,729	6.1	16,970	5.2	N
ECM- L2**	Install Lighting Controls (Add Occupancy Sensors)	21,870	3,867	5.7	2,835	4.9	N
ECM- L3***	Lighting Replacements with Controls (Occupancy Sensors)	136,578	20,723	6.6	19,805	5.6	Y
	Total** Total(Recommended)	204,637 204,637	29,569 29,569	6.9 6.9	19,925 19,925	6.2 6.2	

Summary of Energy Conservation Measures

* Incentive shown is per the New Jersey SmartStart Program.

** These ECMs are not included in the Total, as they are alternate measures not recommended.


*** The lighting savings shown here does not include all the lighting in this building due to inaccessibility to many high security rooms.

The following alternative energy measures are also recommended for further study:

• Photovoltaic (PV) Rooftop Solar Power Generation – 30 kW System

If County of Essex implements the recommended ECMs, energy savings would be as follows:

	Existing Conditions	Post Recommended ECMs	Percent Savings
Costs (\$)	396,056	366,487	7%
Electricity (kWh)	2,309,237	2,128,916	8%
Natural Gas (therms)	51,931	48,868	6%
Site EUI (kbtu/SF/Yr)	101.3	94.2	



2.0 BUILDING INFORMATION AND EXISTING CONDITIONS

The following is a summary of building information related to HVAC, plumbing, building envelope, lighting, kitchen equipment and domestic hot water systems as observed during CHAs site visit. See appendix B for detailed information on mechanical equipment, including capacities, model numbers and age. See appendix F for some representative photos of some of the existing conditions observed while onsite.

Building Name: Leroy Smith Public Safety Building Address: 60 Nelson Place, Newark, NJ, 07102 Gross Floor Area: 129,050 Number of Floors: 13 floors and one basement Year Built: 1963 and renovated in 2010



Building Envelope

Description of Spaces: This is a public safety building which has department of homeland security, improvement authority, judges' chambers, Board of Education offices, and a law library.

Description of Occupancy: The facility serves police and TSA officers and other county staff.

Number of Computers: The amount of computers is not available due to the county security requirements.

Building Usage: The homeland security section is 24/7. The typical office operating hours are from 7:00AM to 5:00PM, Monday through Friday.

Construction Materials: Structural steel and concrete block.

Roof: The building has a flat roof which is covered with black rubber membrane. It is believed that the roof has insulation The roof is in good condition and therefore no ECMs associated with roof upgrades are considered .

Windows: The windows are double pane aluminum framed windows. The windows are in good condition and therefore no ECMs associated with window replacements are evaluated.

Exterior Doors: Exterior doors are steel doors and appear to be in good condition as are the seals. No ECMs associated with replacing the door seals are evaluated.

Heating Ventilation & Air Conditioning (HVAC) Systems

Heating: Three Aerco Benchmark 2.0 high efficiency condensing boilers are used to provide heating hot water for the heating coils in the AHUs and fin-tube radiation. The boilers have a rated 2,000 MBH input each with efficiency ranging from 87% to 96% depending on the return water temperature. The heating hot water is circulated throughout the building by two (2) hot water supply pumps which are driven by variable frequency drive (VFD) 15HP motors. In addition to the heating hot water system, there are twelve (12) Trane water source heat pumps WSHPs that provide additional heat for the building. Each WSHP has a ducted distribution system that serves many variable air volume (VAV) boxes which control the amount of conditioned air delivered to the rooms based on the room temperature. The supply fans of the WSHPs are driven by variable frequency drives (VFD). The details of these Trane WSHPs are listed in the cooling section below.

Cooling: The majority of this building is cooled by the same twelve (12) water source heat pumps which are located in 1st, 5th, 7th, 9th and 14th floor mechanical rooms. The condenser water loop is cooled by a Baltimore Aircoil (BAC) cooling tower located on the roof. The details of these units are listed below:

Name	Brand	Capacity	Location	Serving Area
AHU-1	Trane	25 ton cooling capacity 15HP Supply Fan Motor	1st Floor South Side Mechanical Room	South Side of 1-3 floor
AHU-2	Trane	25 ton cooling capacity 15HP Supply Fan Motor	1st Floor North Side Mechanical Room	North Side of 1-3 floor
AHU-3	Trane	25 ton cooling capacity 15HP Supply Fan Motor	5th Floor South Side Mechanical Room	South Side of 4th and 5th floor
AHU-4	Trane	25 ton cooling capacity 15HP Supply Fan Motor	5th Floor North Side Mechanical Room	North Side of 4th and 5th floor
AHU-5	Trane	20 ton cooling capacity 7.5HP Supply Fan Motor	7th Floor South Side Mechanical Room	South Side of 6th and 7th floor
AHU-6	Trane	20 ton cooling capacity 7.5HP Supply Fan Motor	7th Floor North Side Mechanical Room	North Side of 6th and 7th floor
AHU-7	Trane	20 ton cooling capacity 7.5HP Supply Fan Motor	9th Floor South Side Mechanical Room	South Side of 8th and 9th floor
AHU-8	Trane	20 ton cooling capacity 7.5HP Supply Fan Motor	9th Floor North Side Mechanical Room	North Side of 8th and 9th floor
AHU-9	Trane	20 ton cooling capacity 7.5HP Supply Fan Motor	9th Floor South Side Mechanical Room	South Side of 8th and 9th floor
AHU-10	Trane	20 ton cooling capacity 7.5HP Supply Fan Motor	9th Floor North Side Mechanical Room	North Side of 8th and 9th floor

HPV-1	Trane	AHU with water source heat pump	Conference Room in 14th floor	14 th floor Conference Room
HPV-2	Trane	AHU with water source heat pump	Conference Room in 14th floor	14 th floor Conference Room

There are also several smaller water source heat pumps located in the 2nd and 3rd floor office closets. These offices are high security areas and were not accessible during the site visit. In discussions with the facility staff, it is believed that each WSHP unit has about 1 ton cooling capacity. There are also three Mitsubishi ductless split units serving the server/computer rooms in the building. The server/computer rooms are also high security areas and were not accessible. The condensing units of the Mitsubishi split units are located on the roof and each unit has a rated cooling capacity of 3.5 ton.

Ventilation: The ventilation of the building is provided by three fresh air supply fans located on the roof and two heat recovery units located in the 14th floor mechanical room. These units are tagged HPV-1 and 2.The two heat recovery units use air-to-air heat exchanger to recover energy from the exhaust air and supply fresh air for all the WSHPs. Each of the heat recovery units has a 7.5 HP supply fan motor which is driven by VFD. The ventilation system is in good condition and therefore, there is no ECMs associated with improving the ventilation system are included.

Exhaust: This building is exhausted by the same two heat recovery units located in the 14th floor mechanical room.

Controls Systems

The building has an American Auto-Matrix central direct digital control (DDC) system controlling most of the HVAC devices in the building. Each VAV box has its own temperature sensors to control the room temperature and setback the temperature during unoccupied hours. Reviewing of the control screens, it was noted that the space temperature is typically set at 72 °F during cooling season and 70 °F during the heating season. The occupied hours of most of areas in the building are from 5:30AM to 9:00PM. The temperature is reset to 80 °F during cooling season unoccupied hours. The heating hot water boilers are turned on when the outdoor air temperature is below 70 °F. During our site visit we observed that the boilers were running during even though most of the rooms were not calling for heat. Additionally, It was noted that some of the temperature sensors were broken during reviewing the control screens. An ECM that evaluates the potential energy savings for retro-commissioning the DDC system has been included.

Domestic Hot Water Systems

Domestic hot water for the first floor is produced by s a gas fired A.O.Smith DHW heater which has a rated 120 MBH heating capacity and 80% efficiency. Additionally, the building has four electric DHW heaters located in 5th, 7th and 9th mechanical rooms that serve toilet rooms on these floors. Each electric heater has a rated 12kW heating capacity. As these water heaters are small and do not consume much electricity, there is little benefit to replacing them however, the basement DHW heater is more substantial and can be upgraded to a condensing DHW heater, therefore an ECM associated with replacing the basement DHW heater is evaluated.

Kitchen Equipment

There is no kitchen in this building.

Plug Load

This building has computer servers, computers, monitors, copiers and printers which contribute to the plug load in the building. The plug load devices appear to be Energy Star devices and therefore, there is no ECM associated with plug load devices.

Plumbing Systems

The building plumbing fixtures were renovated in 2010 and contain low flow toilets and urinals which are controlled by motion sensors. The sink faucets are single handle type and have low-flow type aerators. No water conservation related ECMs are evaluated.

Lighting Systems

The building has a combination of 32W T-8 fluorescent lighting and CFLs. The majority of lighting fixtures are T-8 fluorescent U-shape and linear fixtures. Most of the lights in this building are controlled by occupancy sensors or timers. There are many rooms in this building that are high security area and were not accessible during the site visit. The lighting audit for these spaces is based on both observation and lighting plans provided by Essex County. The total electric usage by the lighting is estimated based on the watt/sq. ft of the observed rooms. We have provided three alternatives for the observed lighting that include adding occupancy sensors to the existing lights, replacing the lights with LED lights and a third ECM that evaluates adding occupancy sensors to the proposed LED lights.

3.0 UTILITIES

This building shares one electricity meter with the Veterans Courthouse and the Hall of Records building. The electric meter is located in Veterans Courthouse. The utility usages of these buildings are calculated using the assumption that the usage is proportional to the square feet of each building. It is suggested that the County install sub-meters at each building to individually meter the energy consumption of each building. This building has its own gas meter. Utilities used by the building are delivered and supplied by the following utility companies:


	Electric	Natural Gas
Deliverer	PSE&G	PSE&G
Supplier	PSE&G	HESS

For the 12-month period ending in January 2014, the utilities usages and costs for the building were as follows:


E	lectric	
Annual Consumption	2,309,237	kWh
Annual Cost	348,483	\$
Blended Unit Rate	0.151	\$/kWh
Supply Rate	0.143	\$/kWh
Demand Rate	3.79	\$/kW
Peak Demand	566.3	kW
Nat	ural Gas	
Annual Consumption	51,931	Therms
Annual Cost	47,573	\$
Unit Rate	0.916	\$/therm

Blended Rate: Average rate charged determined by the annual cost / annual usage Supply Rate: Estimated

Demand Rate: Rate charged for actual electrical demand in kW (based on most recent electric bill)



The electric usage profile is somewhat typical for an office building Usage is higher in the summer season when air conditioning is used.



The natural gas usage is for heating and domestic hot water heating and therefore there is small usage in the summer months. The gas usage during the heating season is correlated to winter weather conditions.

See Appendix A for utility analysis.

Under New Jersey's energy deregulation law, the supply portion of the electric (or natural gas) bill is separated from the delivery portion. The supply portion is open to competition, and customers can shop around for the best price for their energy suppliers. The electric and natural gas distribution utilities will still deliver the gas/ electric supplies through their wires and pipes – and respond to emergencies, should they arise – regardless of where those supplies are purchased. Purchasing the energy supplies from a company other than your electric or gas utility is purely an economic decision; it has no impact on the reliability or safety of the service.

Com	Recommended to			
Utility	Units	Shop for Third		
		Party Supplier?		
Electricity	\$/kWh	\$0.151	\$0.13	Y
Natural Gas	\$/Therm	\$0.916	\$0.96	Ν


* Per U.S. Energy Information Administration (2013 data – Electricity and Natural Gas, 2012 data – Fuel Oil)

Additional information on selecting a third party energy supplier is available here:

http://www.state.nj.us/bpu/commercial/shopping.html.

See Appendix A for a list of third-party energy suppliers licensed by the Board of Public Utilities to sell within the building's service area.

The charts below represent estimated utility end-use utility profiles for the building. The values used within the charts were estimated from a review of the utility analysis and the energy savings calculations.



Site End-Use Utility Profile

4.0 BENCHMARKING

The EPA Portfolio Manager benchmarking tool provides a site and source Energy Use Intensity (EUI), as well as an Energy Star performance rating for qualifying building types. The EUIs are provided in kBtu/ft²/year, and the performance rating represents how energy efficient a building is on a scale of 1 to 100, with 100 being the most efficient. In order for a building to receive and Energy Star label, the energy benchmark rating must be at least 75. As energy use decreases from implementation of the proposed measures, the Energy Star rating will increase. However, the EPA does not have score for all types of buildings. The buildings that do not have energy rating now are compared with national median EUI.

The site EUI is the amount of heat and electricity consumed by a building as reflected in utility bills. Site energy may be delivered to a facility in the form of primary energy, which is raw fuel burned to create heat or electricity, such as natural gas or oil; or as secondary energy, which is the product created from a raw fuel such as electricity or district steam. To provide an equitable comparison for different buildings with varying proportions of primary and secondary energy consumption, Portfolio Manager uses the convention of source EUIs. The source energy also accounts for losses incurred in production, storage, transmission, and delivery of energy to the site, which provide an equivalent measure for various types of buildings with differing energy sources. The results of the benchmarking are contained in the table below.

Site EUI kBtu/ft²/yr	Source EUI (kBtu/ft²/yr)	Energy Star Rating (1-100)
101.3	234	N/A

The building has lower EUIs than the national median EUIs (national median site EUI is 53.3 kBtu/ft² and national median source EUI is 123.1 kBtu/ft²). It is believed that the higher EUIs is due to the 24/7 operation of the equipment in the building and lights. By implementing the energy conservation measures in the report, the EUI would be reduced and the Energy Start Rating would be improved.

5.0 ENERGY CONSERVATION MEASURES

The following types of energy savings opportunities are identified in this section of the report:

- Energy conservation measures (ECMs) are energy savings recommendations that typically require a financial investment. For these areas of opportunity, CHA prepared detailed calculations, as summarized in this section and in Appendix C. In general, additional savings may exist from reductions in maintenance activities associated with new equipment or better controls; however for conservatism, maintenance savings are not accounted for in this report; instead the only savings which are reported are those derived directly from reductions in energy which can be tracked by the utility bills.
- Operational and Maintenance measures (O&M) consist of low- or no-cost operational opportunities, which if implemented would have positive impacts on overall building operation, comfort levels, and/or energy usage. There are no estimated savings, costs or paybacks associated with the O&M measures included as part of this study.

Energy savings were quantified in the form of:

- electrical usage (kWh=Kilowatt-hour),
- electrical demand (kW=kilowatts),
- natural gas (therms=100,000 Btu),
- propane gas (gallons=91,650 Btu),
- fuel oil (gallons =138,700 Btu), and
- water (kgal=1,000 gallons).

These recommendations are influenced by the time period that it takes for a proposed project to "break even" referred to as "Simple Payback". Simple payback is calculated by dividing the estimated cost of implementing the ECM by the energy cost savings (in dollars) of that ECM.

Another financial indicator of the performance of a particular ECM is the Return on Investment or ROI, which represents the benefit (annual savings over the life of a project) of an investment divided by the cost of the investment. The result is expressed as a percentage or ratio.

Two other financial analyses included in this report are Internal Rate of Return (IRR) and Net Present Value (NPV). Internal Rate of Return is the discount rate at which the present value of a project costs equals the present value of the project savings. Net Present Value is the difference between present value of an investment's future net cash flows and the initial investment. If the NPV equals "0", the project would equate to investing the same amount of dollars at the desired rate. NPV is sometimes referred to as Net Present Worth. These values are provided in the Summary Tab in Appendix C.

5.1 ECM-1 Central Control System Retro-Commissioning

The building has an American Auto-Matrix central direct digital control (DDC) system controlling most of the HVAC equipment As observed during the site visit, the space temperatures were higher than set point temperatures for many VAV boxes and the boilers were providing heating when it appeared that heating was not needed. Retro-Commissioning of this system is recommend to identify non-functional devised and to recalibrate sensors.

Commissioning is the process of verifying that systems are designed, installed, functionally tested, and capable of being operated and maintained according to the owner's operational needs. Retro-commissioning is the same systematic process applied to existing buildings.

Both controls and components of the heating and cooling systems present saving opportunities during the retro-commissioning process. The DDC system and controls within a building play a crucial role in providing a comfortable building environment. Over time, temperature sensors or thermostats may drift out of synch. Poorly calibrated sensors can increase heating and cooling loads and lead to occupant discomfort. The following procedure is recommended:

- Calibrate the indoor and outdoor building sensors. Calibration of room thermostats, duct thermostats, humidistats, and pressure and temperature sensors should be in accordance with the original design specifications. Calibrating these controls may require specialized skills or equipment and may require outside expertise.
- Inspect damper and valve controls to verify proper functioning. Dampers should also be examined for proper opening and closing. Stiff dampers can cause improper modulation of the amount of outside air being used in the supply airstream. In some cases, dampers may be wired in a single position or disconnected, violating minimum outside air requirements.
- Review building operating schedules. HVAC controls must be adjusted to heat and cool the building properly during occupied hours. Occupancy schedules can change frequently over the life of a building, and control schedules should be adjusted accordingly. When the building is unoccupied, the temperature should be set back to save heating or cooling energy; however, minimal heating and cooling may be required when the building is unoccupied. In cold climates, for example, heating may be needed to keep water pipes from freezing.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

Budgetary Cost	Annual Utility Savings				Savings ROI Potential		Payback (without	Payback (with
COSI	EI	ectricity	Natural Gas	Total		Incentive	incentive)	incentive)
\$	kW	kWh	Therms	\$		\$	Years	Years
56,279	0	40,000	2,397	8,235	1.2	0	6.8	6.8

ECM-1 Central Control System Retro-commissioning

* Does not qualify for Incentive from the New Jersey SmartStart Program. See section 6.0 for other incentive opportunities

This measure is recommended.

5.2 ECM-2 Replace DHW Water Heater with Condensing DHW Water Heater

The basement mechanical room has a gas fired A.O.Smith DHW heater which has a rated 120 MBH heating capacity and 80% efficiency. Energy savings could be realized by replacing this heater with a high efficiency condensing gas fired heaters, which can operate at efficiencies up to 96%.

Savings were calculated based on the DHW supply temperature, estimated DHW usage, and standby heat loss from the storage tank. Standby heat loss from the storage tank was evaluated based on the tank size and Department of Energy's averaged heat loss rate for hot water tanks. The efficiency of the gas-fired condensing heater is 94% per manufacturer's data. Implementation of this measure will require installation of the gas fired condensing water heaters, gas pipes, gas regulators, and PVC pipes for flue gas exhausting.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

Budgetary Cost		Annua	I Utility Savings		ROI	Potential Incentive*	Payback (without	Payback (with
COSI	EI	ectricity	Natural Gas	Total		Incentive	incentive)	incentive)
\$	kW	kWh	Therms	\$		\$	Years	Years
11,780	0	0	667	611	(0.2)	120	19.3	19.1

* Incentive shown is per the New Jersey SmartStart Program. See section 6.0 for other incentive opportunities.

This measure is recommended.

5.3.1 ECM-L1 Lighting Replacement / Upgrades

The building has a combination of 32W T-8 fluorescent lighting and CFLs. The majority of lighting fixtures are T-8 fluorescent U-shape and linear fixtures. Recent technological improvements in light emitting diode (LED) technologies have driven down the initial costs making it a viable option for installation.

Overall energy consumption can be reduced by replacing inefficient bulbs and linear fluorescent bulbs with more efficient LED technology. To compute the annual savings for this ECM, the energy consumption of the current lighting fixtures was established and compared to the proposed fixture power requirement with the same annual hours of operation. The difference between the existing and proposed annual energy consumption was the energy savings. These calculations are based on 1 to 1 replacements of the fixtures, and do not take into account lumen output requirements for a given space. Many spaces in the building were not accessible during the site visit due to the high security requirements of this building. Therefore, the energy savings shown in this report represents part of the building lighting. If all the lights in the building were upgraded to LED, the energy saving would be higher than what is presented in the

report. A more comprehensive engineering study should be performed to determine correct lighting levels and more accurate energy savings.

Supporting calculations, including assumptions for lighting hours and annual energy usage for each fixture, are provided in Appendix C and summarized below:

Budgetary Cost		Annua	l Utility Savings		ROI	Potential Incentive*	Payback (without	Payback (with
COSI	E	ectricity	Natural Gas	Total		Incentive	incentive)	incentive)
\$	kW	kWh	Therms	\$		\$	Years	Years
114,708	14	126,375	0	18,730	1.6	16,970	6.1	5.2

ECM-L1 Lighting Replacement / Upgrades

* LED retrofits must go through the "custom" measures incentive option under New Jersey SmartStart Program. There are no "prescriptive" incentives for LED retrofits. Projects must achieve a minimum of 75,000 kWh annual savings to qualify for "custom" incentives. See section 6.0 for other incentive opportunities

This measure is not recommended in lieu of ECM L3.

5.3.2 ECM-L2 Install Lighting Controls (Occupancy Sensors)

Presently, most of the lights in this building are controlled by occupancy sensors or timers. Some areas could still benefit from replacing timers with occupancy sensors to turn off lights when they are unoccupied.

This measure recommends installing occupancy sensors for the current lighting system. Using a process similar to that utilized in Section ECM-L1, the energy savings for this measure was calculated by applying the known fixture wattages in the space to the estimated existing and proposed times of operation for each fixture.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

Budgetary Cost	Annual Utility Savings				ROI	Potential Incentive*	Payback (without	Payback (with
COSI	EI	ectricity	Natural Gas	Total		Incentive	incentive)	incentive)
\$	kW	kWh	Therms	\$		\$	Years	Years
21,870	0	27,044	0	3,867	1.8	2,835	5.7	4.9

ECM-L2 Install Lighting Controls (Occupancy Sensors)

* Incentive shown is per the New Jersey SmartStart Program. See section 6.0 for other incentive opportunities.

This measure is not recommended in lieu of ECM L3.

5.3.3 ECM-L3 Lighting Replacements with Controls (Occupancy Sensors)

This measure is a combination of ECM-L1 and ECM-L2; recommending replace/upgrade the current lighting fixtures to more efficient ones and installing occupancy sensors on the new lights. Interactive effects of the higher efficiency lights and occupancy sensors lead the energy and cost savings for this measure to not be cumulative or equivalent to the sum of replacing the lighting fixtures alone and installing occupancy sensors without

the lighting upgrade. The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

Budgetary Cost		Annua	I Utility Savings		ROI	Potential Incentive*	Payback (without	Payback (with
COSI	E	ectricity	Natural Gas	Total		Incentive	incentive)	incentive)
\$	kW	kWh	Therms	\$		\$	Years	Years
136,578	14	140,320	0	20,724	1.4	19,805	6.6	5.6

ECM-L3 Lighting Replacements with Controls (Occupancy Sensors)

* LED retrofits must go through the "custom" measures incentive option under New Jersey SmartStart Program. There are no "prescriptive" incentives for LED retrofits. Projects must achieve a minimum of 75,000 kWh annual savings to qualify for "custom" incentives. See section 6.0 for other incentive opportunities

This measure is recommended.

5.4 Additional O&M Opportunities

This list of operations and maintenance (O&M) - type measures represent low-cost or no-cost opportunities, which if implemented will have a positive impact on the overall building operations, comfort and/or energy consumption. The recommended O&M measures for this building are as follows:

- Replace cooling tower media
- Open triple duty valves to 100% and use VFDs to control the pumps
- Replace filters frequently in the WSHPs and HPV units
- Purchase Energy Star Rated appliances
- Turn computers off when not in use

6.0 PROJECT INCENTIVES

6.1 Incentives Overview

The following sections give detailed information on available incentive programs including New Jersey Smart Start, Direct Install, New Jersey Pay for Performance (P4P) and Energy Savings Improvement Plan (ESIP). If the county wishes to and is eligible to participate in the Energy Savings Improvement Plan (ESIP) program and/or the Pay for Performance Incentive Program (P4P), it cannot participate in either the Smart Start or Direct Install Programs. Refer to Appendix D for more information on the Smart Start program.

6.1.1 New Jersey Smart Start Program

For this energy audit, The New Jersey Smart Start Incentives are used in the energy savings calculations, where applicable. This program is intended for medium and large energy users and provides incentives for:

- Electric Chillers
- Gas Chillers
- Gas Heating
- Unitary HVAC
- Ground Source Heat Pumps
- Variable frequency Drives/ motors
- Refrigeration
- Prescriptive and performance lighting and lighting controls

The equipment is procured using a typical bid- build method, installed and paid for and then the incentives are reimbursed to the owner.

Refer to Appendix D for more information on the Smart Start program.

6.1.2 Direct Install Program

The Direct Install Program applies to smaller facilities that have a peak electrical demand of 200 kW or less in any of the previous 12 months. Buildings must be located in New Jersey and served by one of the state's public, regulated electric utility companies.

Direct Install is funded through New Jersey's Clean Energy Program and is designed to provide capital for building energy upgrade projects to fast track implementation. The program will pay up to 70% of the costs for lighting, HVAC, motors, refrigeration, and other equipment upgrades with higher efficiency alternatives. If a building is eligible for this funding, the Direct Install Program can reduce the implementation cost of energy conservation projects.

The Direct Install program has specific HVAC equipment and lighting requirements and is generally applicable only to smaller package HVAC units, small boilers and lighting retrofits.

The program pays a maximum amount of \$75,000 per building, and up to \$250,000 per customer per year. Installations must be completed by an approved Direct Install participating contractor, a list of which can be found on the New Jersey Clean Energy Website. Contractors will coordinate with the applicant to arrange installation of recommended measures identified in a previous energy assessment, such as this energy audit. The incentive is reimbursed to the Owner upon successful replacement and payment of the equipment.

The building does not qualify for this program because its electrical demand is more than the maximum peak electrical demand of 200 kW for the last 12 month period.

Refer to Appendix D for more information on this program.

6.1.3 New Jersey Pay For Performance Program (P4P)

This building may be eligible for incentives from the New Jersey Office of Clean Energy. The most significant incentives are available from the New Jersey Pay for Performance (P4P) Program. The P4P program is designed to offset the cost of energy conservation projects for facilities that pay the Societal Benefits Charge (SBC) and whose demand (kW) in any of the preceding 12 months exceeds 100 kW. This demand minimum has been waived for buildings owned by local governments or municipalities and non-profit organizations and *is not applicable to public schools*. Facilities that meet this criterion must also achieve a minimum performance target of 15% energy reduction by using the EPA Portfolio Manager benchmarking tool before and after implementation of the measure(s). Additionally, the overall return on investment (ROI) must exceed 10%. If the participant is a municipal electric company customer, and a customer of a regulated gas New Jersey Utility, only gas measures will be eligible under the Program. Available incentives are as follows:

Incentive #1: Energy Reduction Plan – This incentive is designed to offset the cost of services associated with the development of the Energy Reduction Plan (ERP). The ERP must include a detailed energy audit of the desired ECMs, energy savings calculations (using building modeling software) and inputting of all utility bills into the EPA Portfolio Manager website.

- Incentive Amount: \$0.10/SF
- Minimum incentive: \$5,000
- Maximum Incentive: \$50,000 or 50% of Facility annual energy cost

The standard incentive pays \$0.10 per square foot, up to a maximum of \$50,000, not to exceed 50% of facility annual energy cost, paid after approval of application. For building audits funded by the New Jersey Board of Public Utilities, which receive an initial 75% incentive toward performance of the energy audit, facilities are only eligible for an additional \$0.05 per square foot, up to a maximum of \$25,000, rather than the standard incentive noted above. The ERP must be completed by a Certified Energy Manager (CEM) and submitted along with the project application.

Incentive #2: Installation of Recommended Measures – This incentive is based on projected energy savings as determined in Incentive #1 (Minimum 15% savings must be achieved), and is paid upon successful installation of recommended measures.

<u>Electric</u>

- Base incentive based on 15% savings: \$0.09/ per projected kWh saved.
- For each % over 15% add: \$0.005 per projected kWh saved.
- Maximum incentive: \$0.11/ kWh per projected kWh saved.

<u>Gas</u>

- Base incentive based on 15% savings: \$0.90/ per projected Therm saved.
- For each % over 15% add: \$0.05 per projected Therm saved.
- Maximum incentive: \$1.25 per projected Therm saved.

Incentive cap: 25% of total project cost

Incentive #3: Post-Construction Benchmarking Report – This incentive is paid after acceptance of a report proving energy savings over one year utilizing the Environmental Protection Agency (EPA) Portfolio Manager benchmarking tool.

<u>Electric</u>

- Base incentive based on 15% savings: \$0.09/ per projected kWh saved.
- For each % over 15% add: \$0.005 per projected kWh saved.
- Maximum incentive: \$0.11/ kWh per projected kWh saved.

<u>Gas</u>

- Base incentive based on 15% savings: \$0.90/ per projected Therm saved.
- For each % over 15% add: \$0.05 per projected Therm saved.
- Maximum incentive: \$1.25 per projected Therm saved.

Combining Incentives #2 and #3 will provide a total of \$0.18/ kWh and \$1.8/therm not to exceed 50% of total project cost. Additional Incentives for #2 and #3 are increased by \$0.005/kWh and \$0.05/therm for each percentage increase above the 15% minimum target to 20%, calculated with the EPA Portfolio Manager benchmarking tool, not to exceed 50% of total project cost.

For the purpose of demonstrating the eligibility of the ECM's to meet the minimum savings requirement of 15% annual savings and 10% ROI for the Pay for Performance Program, all ECM's identified in this report have been included in the incentive calculations. The results for the building are shown in Appendix C, with more detailed program information in Appendix D.

6.1.4 Energy Savings Improvement Plan

The Energy Savings Improvement Program (ESIP) allows government agencies to make energy related improvements to their facilities and pay for the costs using the value of energy savings that result from the improvements. Under the recently enacted Chapter 4 of the Laws of 2009 (the law), the ESIP provides all government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources.

ESIP allows local units to use "energy savings obligations" (ESO) to pay for the capital costs of energy improvements to their facilities. ESIP loans have a maximum loan term of 15 year. ESOs are not considered "new general obligation debt" of a local unit and do not count against debt limits or require voter approval. They may be issued as refunding

bonds or leases. Savings generated from the installation of energy conservation measures pay the principal of and interest on the bonds; for that reason, the debt service created by the ESOs is not paid from the debt service fund, but is paid from the general fund.

For local governments interested in pursuing an ESIP, the first step is to perform an energy audit. Pursuing a Local Government Energy Audit through New Jersey's Clean Energy Program is a valuable first step to the ESIP approach. The "Local Finance Notice" outlines how local governments can develop and implement an ESIP for their facilities. The ESIP can be prepared internally if the entity has qualified staff. If not, the ESIP must be implemented by an independent contractor and not by the energy savings company producing the Energy Reduction Plan.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Local units should carefully consider all alternatives to develop an approach that best meets their needs. Refer to Appendix D for more information on this program.

6.1.5 Renewable Energy Incentive Program

The Renewable Energy Incentive Program (REIP) is part of New Jersey's efforts to reach its Energy Master Plan goals of striving to use 30 percent of electricity from renewable sources by 2020.

Incentives for sustainable bio-power projects and for energy storage projects are currently under development, with competitive solicitations for each of those technologies expected to begin in the first quarter of 2014. The wind program is currently on hold.

New solar projects are no longer eligible for REIP incentives, but can register for Solar Renewable Energy Certificates (SRECs) through the SREC Registration Program (SRP).

7.0 ALTERNATIVE ENERGY SCREENING EVALUATION

7.1 Solar

7.1.1 Photovoltaic Rooftop Solar Power Generation

The building was evaluated for the potential to install rooftop photovoltaic (PV) solar panels for power generation. Present technology incorporates the use of solar cell arrays that produce direct current (DC) electricity. This DC current is converted to alternating current (AC) with the use of an electrical device known as an inverter. The amount of available roof area determines how large of a solar array can be installed on any given roof. The table below summarizes the approximate roof area available on the building and the associated solar array size that can be installed.

Available Roof	Potential PV
Area	Array Size
(Ft ²)	(kW)
2,021	30

The PVWATTS solar power generation model was utilized to calculate PV power generation; this model is provided in Appendix E.

Installation of (PV) arrays in the state New Jersey will allow the owner to participate in the New Jersey Solar Renewable Energy Certificates Program (SREC). This is a program that has been set up to allow entities with large amounts of environmentally unfriendly emissions to purchase credits from zero emission (PV) solar-producers. An alternative compliance penalty (ACP) is paid for by the high emission producers and is set each year on a declining scale of 3% per year. One SREC credit is equivalent to 1000 kilowatt hours of PV electrical production; these credits can be traded for period of 15 years from the date of installation. Payments that will be received by the PV producer will change from year to year dependent upon supply and demand. There is no definitive way to calculate an exact price that will be received by the PV producer for SREC credits over the next 15 years. Renewable Energy Consultants estimates an average of \$170/SREC for 2014 and this number was utilized in the cash flow for this report.

The system costs for PV installations were derived from recent solar contractor budgetary pricing in the state of New Jersey and include the total cost of the system installation (PV panels, inverters, wiring, ballast, controls). The cost of installation is currently about \$4.00 per watt or \$4,000 per kW of installed system, for a typical system. There are other considerations that have not been included in this pricing, such as the condition of the roof and need for structural reinforcement. Photovoltaic systems can be ground mounted if the roof is not suitable, however, this installation requires a substantial amount of open property (not wooded) and underground wiring, which adds more cost. PV panels have an approximate 20 year life span; however, the inverter device that converts DC electricity to AC has a life span of 10 to 12 years and will most likely need to be replaced during the useful life of the PV system.

The implementation cost and savings related to this ECM are presented in Appendix E and summarized as follows:

Budgetary Cost	An	nual Utility	Savings	Total Savings	New Jersey Renewable SREC	Payback (without SREC)	Payback (with SREC)	Recommended
	Elec	tricity	Natural Gas					Ř
\$	kW	kWh	Therms	\$	\$	Years	Years	Y/N
\$120,000	30.0	38,247	0	\$5,772	\$6,502	20.8	9.8	FS

Photovoltaic (PV) Rooftop Solar Power Generation – 30 kW System

Note: CHA typically recommends a more detailed evaluation be conducted for the installation of PV Solar arrays when the screening evaluation shows a payback of less than 20 years. Therefore, this ECM is recommended for further study. Before implementation is pursued, the county should consult with a certified solar PV contractor.

7.1.2 Solar Thermal Hot Water Generation

Active solar thermal systems use solar collectors to gather the sun's energy to heat a fluid. An absorber in the collector (usually black colored piping) converts the sun's energy into heat. The heat is transferred to circulating water, antifreeze, or air for immediate use or is storage for later utilization. Applications for active solar thermal energy include supplementing domestic hot water, heating swimming pools, space heating or preheating air in residential and commercial buildings.


A standard solar hot water system is typically composed of solar collectors, heat storage vessel, piping, circulators, and controls. Systems are typically integrated to work alongside a conventional heating system that provides heat when solar resources are not sufficient. The solar collectors are usually placed on the roof of the building, oriented south, and tilted at the same angle as the site's latitude, to maximize the amount of solar radiation collected on a yearly basis.

Several options exist for using active solar thermal systems for space heating. The most common method is called a passive solar hot water system involves using glazed collectors to heat a liquid held in a storage tank (similar to an active solar hot water system described above which requires pumping). The most practical system would transfer the heat from the panels to thermal storage tanks and then use the pre-heated water for domestic hot water production. DHW is presently produced by natural gas fired water heaters and, therefore, this measure would offer natural gas utility savings. Unfortunately, the amount of domestic hot water system is not recommended due to the limited amount of domestic hot water presently consumed by the building.

This measure is not recommended due to the relatively low domestic hot water usage.

7.2 Wind Powered Turbines

Wind power is the conversion of kinetic energy from wind into mechanical power that is used to drive a generator which creates electricity by means of a wind turbine. A wind turbine consists of rotor and blades connected to a gearbox and generator that are mounted onto a tower. Newer wind turbines also use advanced technology to generate electricity at a variety of frequencies depending on the wind speed, convert it to DC and then back to AC before sending it to the grid. Wind turbines range from 50 – 750 kW for utility scale turbines down to below 50 kW for residential use. On a scale of 1 (the lowest) to 7 (the highest), Class 3 and above (wind speeds of 13 mph or greater) are generally considered "good wind resource" according to the Wind Energy Development Programmatic EIS Information Center hosted by the Bureau of Land Management. According to the map below, published by NREL, Newark, NJ is classified as Class 1 at 50m, meaning the city would not be a good candidate for wind power.



This measure is not recommended due to the location of the building.

7.3 Combined Heat and Power Plant

Combined heat and power (CHP), cogeneration, is self-production of electricity on-site with beneficial recovery of the heat byproduct from the electrical generator. Common CHP equipment includes reciprocating engine-driven, micro turbines, steam turbines, and fuel cells. Typical CHP customers include industrial, commercial, institutional, educational institutions, and multifamily residential facilities. CHP systems that are commercially viable at the present time are sized approximately 50 kW and above, with numerous options in blocks grouped around 300 kW, 800 kW, 1,200 kW and larger. Typically, CHP systems are used to produce a portion of the electricity needed by a facility some or all of the time, with the balance of electric needs satisfied by purchase from the grid.

Any proposed CHP project will need to consider many factors, such as existing system load, use of thermal energy produced, system size, natural gas fuel availability, and proposed plant location. The building has sufficient need for electrical generation and the ability to use most of the thermal byproduct during the winter and the summer. An absorption chiller could be installed to utilize the heat to produce chilled water. The most viable selection for a CHP plant at this location would be a reciprocating engine natural gas-fired unit. Purchasing this system and performing modifications to the existing HVAC and electrical systems would greatly outweigh the savings over the life of the equipment.

The CHP screening analysis was conducted utilizing the characteristics of the site before any of the ECMs described above are implemented. If any of the ECMs are implemented, the feasibility of installing a CHP system is reduced and the payback would likely be slightly extended.

Budgetary Cost	Annual Utility Usage		Total Savings	New Jersey Incentive	Payback (without Incentive)	Payback (with Incentive)	Recommended
	Existing Utility Cost	CHP Operating Cost					Rec
\$	\$	\$	\$	\$	Years	Years	Y/N
2,280,000	396,056	272,759	123,297	1,000,000	18.5	10.4	FS

Combined Heat and Power (CHP) – 500kW

This measure recommended for further study—see details Appendix E.

Although NJBPU LGEA program offers potential incentive for this measure as outlined above, the exact value must be determined by NJBPU. The savings outlined are evaluated at a screening level and should be refined during the design phase. It is recommended that Essex County pursue a more detailed CHP feasibility study to provide a more accurate depiction of the proposed CHP system to allow for application for incentives. The energy savings and implementation costs for this analysis have not been included in the project totals.

7.4 Demand Response Curtailment

Presently, electricity is delivered by PSE&G, which receives the electricity from regional power grid RFC. PSE&G is the regional transmission organization (RTO) that coordinates the movement of wholesale electricity in all or parts of 13 states and the District of Columbia including the State of New Jersey.

Utility Curtailment is an agreement with the utility provider's regional transmission organization and an approved Curtailment Service Provider (CSP) to shed electrical load by either turning major equipment off or energizing all or part of a facility utilizing an emergency generator; therefore, reducing the electrical demand on the utility grid. This program is to benefit the utility company during high demand periods and utility provider offers incentives to the CSP to participate in this program. Enrolling in the program will require program participants to drop electrical load or turn on emergency generators during high electrical demand conditions or during emergencies. Part of the program also will require that program participants reduce their required load or run emergency generators with notice to test the system.

A pre-approved CSP will require a minimum of 100 kW of load reduction to participate in any curtailment program. From February 2013 through January 2014 the following table summarizes the electricity load profile for the building.

Building Electric Load Profile

			Onsite	
Peak Demand	Min Demand	Avg Demand	Generation	Eligible?
kW	kW	kW	Y/N	Ϋ́/Ν
566.3	362.0	467.2	Ν	Y

*the demand is estimated from one month bill

This measure is not recommended due to the lack of onsite power generators.

8.0 CONCLUSIONS & RECOMMENDATIONS

The following section summarizes the LGEA energy audit conducted by CHA for the Leroy Smith Public Safety Building in Essex County.

The following projects should be considered for implementation:


- Central DDC System Retro-commissioning
- Replace DHW Water Heater with Condensing DHW Water Heater
- Lighting Replacements with Controls (Occupancy Sensors)

The potential annual energy and cost savings for the recommended ECMs are shown in the following table.

Electric Savings (kWh)	Natural Gas Savings (therms)	Total Savings (\$)	Payback (years)	
180,321	3,063	29,569	6.9	

If the county implements the recommended ECMs, energy savings would be as follows:

	Existing Conditions	Post Recommended ECMs	Percent Savings
Costs (\$)	396,056	366,487	7%
Electricity (kWh)	2,309,237	2,128,916	8%
Natural Gas (therms)	51,931	48,868	6%
Site EUI (kbtu/SF/Yr)	101.3	94.2	



Next Steps: This energy audit has identified several areas of potential energy savings. Essex County can use this information to pursue incentives offered by the NJBPU's NJ Clean Energy Program. Additional meetings will be scheduled with county staff members to review possible options.

APPENDIX A

Utility Usage Analysis and Alternate Utility Suppliers

Essex County Leroy Smith Public Safety Complex Electric Usage

Annual Utilities

12-month Summary

Electric						
Annual Usage	2,309,237	kWh/yr				
Annual Cost	348,483	\$				
Blended Rate	0.151	\$/kWh				
Consumption Rate	0.143	\$/kWh				
Demand Rate	3.79	\$/kW				
Peak Demand	566.3	kW				
Min. Demand	362.0	kW				
Avg. Demand	467.2	kW				
	Natural Gas					
Annual Usage	51,931	therms/yr				
Annual Cost	47,573	\$				
Rate	0.916	\$/therm				

Essex County Leroy Smith Public Safety Complex


Utility Bills: Account Numbers

Account Number	Building Name	Location	<u>Type</u> <u>Notes</u>
4206450706	Leroy Smith Public Safety Complex	60 Nelson Place, Newark, NJ, 07102	Electricity
6542561102	Leroy Smith Public Safety Complex	61 Nelson Place, Newark, NJ, 07102	Natural Gas

Essex County Leroy Smith Public Safety Complex Electric Usage

For Service at:			
Account No.:	4206450706	Delivery -	PSE&G
Meter No.:	778015129	Supplier -	N/A
Electric Service			

			Provider Charges		Usage (kWh) vs. Demand (kW) Charges	Unit Costs				
	Consumption	Demand	Delivery	Supplier	Total	Consumption	Demand	Blended Rate	Consumption	Demand
Month	(kWh)	(kW)	(\$)	(\$)	(\$)	(\$)	(\$)	(\$/kWh)	(\$/kWh)	(\$/kW)
February-13	169,436	364.05	6,362.59	17,790.76	24,153.35	22,863.02	1,290.33	0.14	0.13	3.54
March-13	174,079	367.40	6,308.63	18,278.32	24,586.95	23,284.73	1,302.22	0.14	0.13	3.54
April-13	181,090	430.89	6,732.24	19,014.49	25,746.73	24,219.47	1,527.26	0.14	0.13	3.54
May-13	172,097	415.36	6,422.47	18,070.16	24,492.63	23,020.42	1,472.21	0.14	0.13	3.54
June-13	202,550	481.88	11,766.94	21,267.72	33,034.66	31,326.67	1,707.99	0.16	0.15	3.54
July-13	243,617	558.69	14,157.24	25,579.83	39,737.07	37,756.83	1,980.24	0.16	0.15	3.54
August-13	226,686	566.30	13,734.70	23,802.01	37,536.71	35,529.52	2,007.19	0.17	0.16	3.54
September-13	221,855	536.60	13,232.41	23,294.75	36,527.16	34,625.26	1,901.91	0.16	0.16	3.54
October-13	188,077	442.91	7,358.59	19,748.07	27,106.66	25,536.81	1,569.85	0.14	0.14	3.54
November-13	157,573	419.00	6,194.64	16,545.20	22,739.84	21,278.95	1,460.89	0.14	0.14	3.49
December-13	186,110	361.95	6,820.38	19,541.58	26,361.96	25,099.98	1,261.98	0.14	0.13	3.49
January-14	186,067	369.94	6,922.41	<u>19,537.01</u>	26,459.42	25,160.51	1,298.91	0.14	0.14	3.51
Total (All)	2,309,237	566.30	\$106,013.25	\$242,469.90	\$348,483.15	\$329,702.18	\$18,780.97	\$0.151	\$0.143	\$3.53
Total (12 Months)	2,309,237	566.30	\$106,013.25	\$242,469.90	\$348,483.15	\$329,702.18	\$18,780.97	\$0.151	\$0.143	\$3.79
Not	es 1	2	3	4	5	6	7	8	9	10
	 Number of kWh of electr Number of kW of power Electric charges from De Electric charges from Su Fotal charges (Delivery 4 Charges based on the nu Total Charges (\$) / Cons Consumption Charges (\$) Densund Charges (\$) / Dens 	neasured livery provider pply provider Supplier) umber of kWh of electric umption (kWh)) / Consumption (kWh)	energy used	\$0.105 <i>/</i>	ĸWh	Estimated supply rate due to miss	ing data			



Leroy Smith Public Safety Complex Electric Usage

Leroy Smith Publich Service Complex Utility Data.xlsx Electric Graph

Essex County Leroy Smith Public Safety Complex Gas Usage

For Service at: Account No.:


Natural Gas Service

Meter No:

6542561102 3499595

> Delivery - PSE&G Supplier - HESS

			Charges			Unit Costs	
Month	Consumption (Therms)	Delivery (\$)	Supply (\$)	Total (\$)	Delivery (\$/Therm)	Supply (\$/Therm)	Total (\$/Therm)
February-13	10,387	\$ 3,301.00	\$5,619.43	\$ 8,920.43	\$ 0.318	\$ 0.541	\$ 0.859
March-13	8,802	\$ 3,659.72	\$4,761.94	\$ 8,421.66	\$ 0.416	\$ 0.541	\$ 0.957
April-13	6,833	\$ 1,313.05	\$3,696.87	\$ 5,009.92	\$ 0.192	\$ 0.541	\$ 0.733
May-13	2,911	\$ 730.27	\$1,574.65	\$ 2,304.92	\$ 0.251	\$ 0.541	\$ 0.792
June-13	500	\$ 228.37	\$270.37	\$ 498.74	\$ 0.457	\$ 0.541	\$ 0.998
July-13	109	\$ 129.07	\$59.24	\$ 188.31	\$ 1.179	\$ 0.541	\$ 1.720
August-13	39	\$ 111.43	\$21.26	\$ 132.69	\$ 2.836	\$ 0.541	\$ 3.377
September-13	43	\$ 111.38	\$23.10	\$ 134.48	\$ 2.608	\$ 0.541	\$ 3.149
October-13	911	\$ 258.28	\$492.99	\$ 751.27	\$ 0.283	\$ 0.541	\$ 0.824
November-13	4,487	\$ 2,316.19	\$2,427.26	\$ 4,743.45	\$ 0.516	\$ 0.541	\$ 1.057
December-13	7,059	\$ 2,982.96	\$3,819.10	\$ 6,802.06	\$ 0.423	\$ 0.541	\$ 0.964
January-14	9,849	\$ 4,336.51	\$5,328.49	\$ 9,665.00	\$ 0.440	\$ 0.541	\$ 0.981
Total (All)	51,931.06			47,572.93			\$ 0.916
Total (12 Months)	51,931.06			47,572.93			\$ 0.916



PSE&G GAS SERVICE TERRITORY Last Updated: 12/11/14

*<u>CUSTOMER CLASS</u> - R – RESIDENTIAL C – COMMERCIAL I - INDUSTRIAL

Supplier	Telephone & Web Site	*Customer Class
Ambit Northeast, LLC d/b/a Ambit Energy 103 Carnegie Center	877-282-6284	R/C
Suite 300 Princeton, NJ 08540	www.ambitenergy.com	ACTIVE
Amerigreen Energy, Inc. 333 Sylvan Avenue Suite 206	(888)559-4567	R/C/I
Englewood Cliffs, NJ 07632	www.amerigreen.com	ACTIVE
Astral Energy LLC 16 Tyson Place	888-850-1872	R/C/I
Bergenfield, NJ 07621	www.AstralEnergyLLC.com	ACTIVE
BBPC, LLC Great Eastern Energy	888-651-4121	С
116 Village Blvd. Suite 200 Princeton, NJ 08540	www.greateasternenergy.com	ACTIVE
Choice Energy, LLC 4257 US Highway 9, Suite 6C Freehold, NJ 07728	(888) 565-4490	R/C/I
	www.4choiceenergy.com	
Clearview Electric Inc. d/b/a Clearview Gas 1744 Lexington Ave.	800-746-4720	R/C
Pennsauken, NJ 08110	www.clearviewenergy.com	ACTIVE
Colonial Energy, Inc. 83 Harding Road	845-429-3229	С/І
Wyckoff, NJ 07481	www.colonialgroupinc.com	ACTIVE
Commerce Energy, Inc. 7 Cedar Terrace	888 817-8572	R
Ramsey, NJ 07746	www.commerceenergy.com	ACTIVE
Compass Energy Services, Inc. 33 Wood Avenue South, 610	866-867-8328	С/І
Iselin, NJ 08830	www.compassenergy.net	ACTIVE

Compass Energy Gas Services,	866-867-8328	С/І
LLC		
33 Wood Avenue South		
Suite 610	www.compassenergy.net	ACTIVE
Iselin, NJ 08830		
ConocoPhillips Company	800-646-4427	C/I
224 Strawbridge Drive, Suite		
107	www.conocophillips.com	ACTIVE
Moorestown, NJ 08057		
Consolidated Edison Energy,	888-686-1383 x2130	
Inc.		
d/b/a Con Edison Solutions		
535 State Highway 38, Suite	www.conedenergy.com	
140		
Cherry Hill, NJ 08002		
Consolidated Edison	888-665-0955	C/I
Solutions, Inc.		
Cherry Tree Corporate Center		ACTIVE
535 State Highway 38, Suite	www.conedsolutions.com	
140		
Cherry Hill, NJ 08002		
Constellation NewEnergy-Gas	800-785-4373	C/I
Division, LLC		
116 Village Boulevard, Suite		
200	www.constellation.com	ACTIVE
Princeton, NJ 08540		
Constellation Energy Gas	800-785-4373	R/C/I
Choice, Inc.		
116 Village Blvd., Suite 200	www.constellation.com	ACTIVE
Princeton, NJ 08540		
Direct Energy Business, LLC	888-925-9115	R
120 Wood Avenue, Suite 611		
Iselin, NJ 08830	http://www.business.directenergy.com/	ACTIVE
Direct Energy Business	(800) 437-7872	C/I
Marketing, LLC (fka Hess		
Energy Marketing)		
One Hess Plaza		
Woodbridge, NJ 07095	http://www.business.directenergy.com/	ACTIVE
Direct Energy Services, LLC	(888) 925-9115	R
120 Wood Avenue, Suite 611		
120 wood Avenue. Sume OFF		
Iselin, NJ 08830	www.directenergy.com	ACTIVE

Direct Energy Small Business, LLC (fka Hess Small Business Services, LLC) One Hess Plaza	(888) 464-4377	СЛ
Woodbridge, NJ 07095	http://www.business.directenergy.com/	ACTIVE
Gateway Energy Services	(866) 348-4193	R/C
Corp. 120 Wood Avenue Suite 611 Iselin, NJ 08830	www.gesc.com	ACTIVE
Glacial Energy of New Jersey,	888-452-2425	C/I
Inc. 21 Pine Street, Suite 237 Rockaway, NJ 07866	www.glacialenergy.com	ACTIVE
Global Energy Marketing,	800-542-0778	C/I
LLC 129 Wentz Avenue Springfield, NJ 07081	www.globalp.com	ACTIVE
Great Eastern Energy	888-651-4121	C/I
116 Village Blvd., Suite 200 Princeton, NJ 08540	www.greateastern.com	ACTIVE
Greenlight Energy	718-204-7467	С
330 Hudson Street, Suite 4 Hoboken, NJ 07030	www.greenlightenergy.us	ACTIVE
Harborside Energy LLC	877-940-3835	R/C
101 Hudson Street, Suite 2100 Jersey City, NJ 07302	www.harborsideenergynj.com	ACTIVE
Hess Energy, Inc.	800-437-7872	C/I
One Hess Plaza Woodbridge, NJ 07095	www.hess.com	ACTIVE
HIKO Energy, LLC	888 264-4908	R/C/I
655 Suffern Road Teaneck, NJ 07666	www.hikoenergy.com	ACTIVE
Hudson Energy Services, LLC	877- Hudson 9	С
7 Cedar Street Ramsey, NJ 07446	www.hudsonenergyservices.com	ACTIVE
IDT Energy, Inc.	877-887-6866	R/C
550 Broad Street Newark, NJ 07102	www.idtenergy.com	ACTIVE

Infinite Energy dba Intelligent	(800) 927-9794	R/C/I
Energy		
1200 Route 22 East Suite 2000		
Bridgewater, NJ 08807-2943	www.InfiniteEnergy.com	ACTIVE
Integrys Energy Services-	(800) 536-0151	C/I
Natural Gas, LLC 101 Eisenhower Parkway		
Suite 300	www.integrysenergy.com	ACTIVE
Roseland, NJ 07068		
Jsynergy LLC	(516) 331-2020	R/C/I
445 Cental Ave. Suite 204		
Cedarhurst, NY 11516	www.Jsnergyllc.com	ACTIVE
Major Energy Services, LLC	888-625-6760	R/C/I
1001 East Lawn Drive		
Teaneck NJ 07666	www.majorenergy.com	ACTIVE
Marathon Power LLC	888-779-7255	R/C/I
302 Main Street		
Paterson, NJ 07505	www.mecny.com	ACTIVE
Metromedia Energy, Inc.	1-877-750-7046	C/I
6 Industrial Way		
Eatontown, NJ 07724	www.metromediaenergy.com	ACTIVE
Metro Energy Group, LLC	888-53-Metro	R/C
14 Washington Place		
Hackensack, NJ 07601	www.metroenergy.com	ACTIVE
MPower Energy NJ LLC	877-286-7693	R/C/I
One University Plaza, Suite 507		
Hackensack, NJ 07601	www.mpowerenergy.com	ACTIVE
NATGASCO (Supreme	800-840-4427	R/C/I
Energy, Inc.)		
532 Freeman Street		
Orange, NJ 07050	www.supremeenergyinc.com	ACTIVE
New Energy Services LLC	800-660-3643	R/C/I
101 Neptune Avenue Deal, New Jersey 07723	www.newenergyservicesllc.com	ACTIVE
New Jersey Gas & Electric	866-568-0290	R/C
10 North Park Place Suite 420		
Morristown, NJ 07960	www.njgande.com	ACTIVE

Noble Americas Energy	877-273-6772	C/I
Solutions		
The Mac-Cali Building		
581 Main Street, 8th fl.	www.noblesolutions.com	ACTIVE
Woodbridge, NJ 07095		
North American Power &	888- 313-8086	R/C/I
Gas, LLC d/b/a North		
American Power		
197 Route 18 South Ste. 300	www.napower.com	ACTIVE
New Brunswick, NJ 08816		
North Eastern States, Inc.	(888) 535-6340	R/C/I
d/b/a Entrust Energy		
90 Washington Valley Road		
Bedminster, NJ 07921	www.entrustenergy.com	ACTIVE
Oasis Power, LLC d/b/a Oasis	(800)324-3046	R/C
Energy		
11152 Westheimer, Suite 901	www.oasisenergy.com	ACTIVE
Houston, TX 77042		
Palmco Energy NJ, LLC	877-726-5862	R/C/I
One Greentree Centre		
10,000 Lincoln Drive East, Suite		
201	www.PalmcoEnergy.com	ACTIVE
Marlton, NJ 08053		
Plymouth Rock Energy, LLC	855-32-POWER (76937)	R/C/I
338 Maitland Avenue		
Teaneck, NJ 07666	www.plymouthenergy.com	ACTIVE
PPL EnergyPlus, LLC	(732) 741-0505	C/I
Shrewsbury Executive Offices		
788 Shrewsbury Avenue		
Suite 2200		
Tinton Falls, NJ 07724	www.pplenergyplus.com	ACTIVE
PPL EnergyPlus Retail, LLC	(732) 741-0505 – 2000	С/І
Shrewsbury Executive Offices		
788 Shrewsbury Avenue, Suite		
220	www.pplenergyplus.com	ACTIVE
Tinton Falls, NJ 07724		
Public Power & Utility of New	(888) 354-4415	R/C/I
Jersey, LLC		
One International Blvd, Suite		
400	www.ppandu.com	ACTIVE
Mahwah, NJ 07495		

Residents Energy, LLC 550 Broad Street	(888) 828-7374	R/C
Newark, NJ 07102	www.residentsenergy.com	
Respond Power LLC 1001 East Lawn Drive	(877) 973-7763	R/C/I
Teaneck, NJ 07666	www.respondpower.com	ACTIVE
Save on Energy, LLC 1101 Red Ventures Drive	1 (877) 658-3183	R/C
Fort Mill, SC 29707	www.saveonenergy.com	ACTIVE
SFE Energy	1 (877) 316-6344	R/C/I
One Gateway Center Suite 2600 Newark, NJ 07012	www.sfeenergy.com	ACTIVE
S.J. Energy Partners, Inc. 208 White Horse Pike, Suite 4	(800) 695-0666	С
Barrington, NJ 08007	www.sjnaturalgas.com	ACTIVE
South Jersey Energy	800-266-6020	R/C/I
Company 1 South Jersey Plaza, Route 54 Folsom, NJ 08037	www.southjerseyenergy.com	ACTIVE
SouthStar Energy d/b/a New	(866) 477-8823	R/C
Jersey Energy 1085 Morris Avenue, Suite 155 Union, NJ 07083	www.newjerseyenergy.com	ACTIVE
Spark Energy Gas, LP/ Spark Energy 2105 City West Blvd. Suite 100	(713)600-2600	R/C/I
Houston, TX 77042 Sperian Energy Corp.	www.sparkenergy.com 888-682-8082	ACTIVE R/C/I
Bridgewater Center 1200 Route 22 East		ACTIVE
Bridgewater, NJ 08807 Sprague Energy Corp.	www.sperianenergy.com 855-466-2842	С/І
12 Ridge Road Chatham Township, NJ 07928	www.spragueenergy.com	ACTIVE
Stuyvesant Energy LLC	800-640-6457	C ACTIVE
10 West Ivy Lane, Suite 4 Englewood, NJ 07631	www.stuyfuel.com	ACTIVE

Stream Energy New Jersey,	(877) 369-8150	R/C
LLC		
309 Fellowship Road		
Suite 200		
Mt. Laurel, NJ 08054	www.streamenergy.net	ACTIVE
Summit Energy Services, Inc.	1 (800) 90-SUMMIT	C/I
10350 Ormsby Park Place		
Suite 400	www.summitenergy.com	ACTIVE
Louisville, KY 40223		
Systrum Energy	877-797-8786	R/C/I
1 Bergen Blvd.		
Fairview, NJ 07022	www.systrumenergy.com	ACTIVE
Tiger Natural Gas, Inc. dba	888-875-6122	R/C/I
Tiger, Inc.	000 075 0122	10,011
234 20th Avenue		
Brick, NJ 008724	www.tigernaturalgas.com	ACTIVE
UGI Energy Services, Inc.	800-427-8545	C/I
dba UGI Energy Link	800-427-8343	C/1
224 Strawbridge Drive, Suite	www.ugienergylink.com	ACTIVE
107	www.ugienergymik.com	ACTIVE
Moorestown, NJ 08057		
UGI Energy Services, Inc.	856-273-9995	C/I
d/b/a GASMARK	830-273-9993	C/1
224 Strawbridge Drive, Suite		
107	www.ugienergylink.com	ACTIVE
Moorestown, NJ 08057	www.ugienergymik.com	ACTIVE
	800-388-3862	R/C
Verde Energy USA, Inc. 2001 Route 46	800-388-3802	K/C
Waterview Plaza, Suite 301		
· ·	www.lowcostpower.com	ACTIVE
Parsippany, NJ 07054		
Viridian Energy PA LLC	866-663-2508	R/C
2001 Route 46, Waterview		
Plaza Suite 230		
Parsippany, NJ 07054	www.viridian.com	ACTIVE
Vista Energy Marketing, L.P.	888-508-4782	R/C/I
197 State Route 18 South, Suite		
3000		
South Wing		
East Brunswick, NJ 08816	www.vistaenergymarketing.com	ACTIVE
Woodruff Energy	800-557-1121	R/C/I
73 Water Street		
Bridgeton, NJ 08302	www.woodruffenergy.com	ACTIVE

Woodruff Energy US LLC 73 Water Street, P.O. Box 777 Bridgeton, NJ 08302	856-455-1111 800-557-1121 <u>www.woodruffenergy.com</u>	C/I ACTIVE
XOOM Energy New Jersey, LLC 744 Broad Street. 16th Floor Newark, NJ 07102	888-997-8979 www.xoomenergy.com	R/C/I ACTIVE
Your Energy Holdings, LLC One International Boulevard Suite 400 Mahwah, NJ 07495-0400	855-732-2493 www.thisisyourenergy.com	R/C/I ACTIVE

Back to main supplier information page

PSE&G ELECTRIC SERVICE TERRITORY Last Updated: 12/11/14

*<u>CUSTOMER CLASS</u> - R – RESIDENTIAL C – COMMERCIAL I –INDUSTRIAL

Supplier	Telephone	*Customer
	& Web Site	Class
Abest Power & Gas of NJ,	(888)987-6937	R/C/I
LLC		
202 Smith Street		
Perth Amboy, NJ 08861	www.AbestPower.com	ACTIVE
AEP Energy, Inc. f/k/a	(866) 258-3782	R/C/I
BlueStar Energy Services		
309 Fellowship Road, Fl. 2	www.aepenergy.com	ACTIVE
Mount Laurel, NJ 08054		
Alpha Gas and Electric,	(855) 553-6374	R/C
LLC		
641 5 th Street	www.alphagasandelectric.com	ACTIVE
Lakewood, NJ 08701		
Ambit Northeast, LLC d/b/a	877-282-6284	R/C
Ambit Energy		
103 Carnegie Center		
Suite 300	1.5	ACTIVE
Princeton, NJ 08540	www.ambitenergy.com	
American Powernet	(877) 977-2636	С/І
Management, LP		
437 North Grove St.	www.americanpowernet.com	ACTIVE
Berlin, NJ 08009	000.550.4567	
Amerigreen Energy, Inc.	888-559-4567	R/C
333Sylvan Avenue Englewood Cliffs, NJ 07632	www.amerigreen.com	ACTIVE
AP Gas & Electric, (NJ)	(855) 544-4895	R/C/I
LLC	(855) 544-4855	N/C/I
10 North Park Place, Suite 420	www.apgellc.com	ACTIVE
Morristown, NJ 07960		
Astral Energy LLC	(888)850-1872	R/C/I
16 Tyson Place		
Bergenfield, NJ 07621	www.AstralEnergyLLC.com	ACTIVE
Barclays Capital Services,	(800) 526-7000	С
Inc.		
70 Hudson Street		ACTIVE
Jersey City, NJ 07302-4585	www.barclays.com	
BBPC, LLC d/b/a Great	(888) 651-4121	С
Eastern Energy		

116 Village Blvd. Suite 200		
Princeton, NJ 08540		ACTIVE
	www.greateasternenergy.com	
Berkshire Energy Partners,	(610) 255-5070	C/I
LLC		
9 Berkshire Road		ACTIVE
Landenberg, PA 19350 Attn: Dana A. LeSage, P.E.	www.borkshiroonergypertners.com	
	www.berkshireenergypartners.com	D /C
Blue Pilot Energy, LLC 197 State Rte. 18 South	(800) 451-6356	R/C
Ste. 3000		
East Brunswick, NJ 08816	www.bluepilotenergy.com	ACTIVE
Brick Standard, LLC	(201)706-8101	C/I
235 Hudson Street Suite 1	(201)/00-0101	C/1
Hoboken, NJ 07030	www.standardalternative.com	ACTIVE
CCES LLC dba Clean	(877) 933-2453	R/C
Currents Energy Services		
566 Terhune Street		
Teaneck, NJ 07666	www.cleancurrents.com	ACTIVE
Champion Energy Services,	(888) 653-0093	R/C/I
LLC		
1200 Route 22		ACTIVE
Bridgewater, NJ 08807	www.championenergyservices.com	
Choice Energy, LLC	(888) 565-4490	R/C
4257 US Highway 9, Suite 6C		
Freehold, NJ 07728	www.4choiceenergy.com	ACTIVE
Clearview Electric, Inc.	(888) CLR-VIEW	R/C/I
1744 Lexington Avenue	(800) 746- 4702	
Pennsauken, NJ 08110	www.clearviewenergy.com	ACTIVE
Commerce Energy, Inc.	1-866-587-8674	R/C
7 Cedar Terrace		
Ramsey, NJ 07446	www.commerceenergy.com	ACTIVE
Community Energy Inc.	(866)946-3123	R/C/I
51 Sandbrook Headquarters	Ň, Ž	
Road		
Stockton, NJ 08559	www.communityenergyinc.com	ACTIVE
ConEdison Solutions	(888) 665-0955	C/I
Cherry Tree Corporate Center		
535 State Highway		
Suite 180		ACTIVE
Cherry Hill, NJ 08002	www.conedsolutions.com	

ConocoPhillips Company	(800) 646-4427	C/I
224 Strawbridge Drive		
Suite 107		ACTIVE
Moorestown, NJ 08057	www.conocophillips.com	
Constellation NewEnergy,	(888) 635-0827	R/C/I
Inc. 900A Lake Street, Suite 2 Ramsey, NJ 07446	www.constellation.com	ACTIVE
Constellation Energy	(877) 997-9995	R
900A Lake Street, Suite 2		
Ramsey, NJ 07446	www.constellation.com	ACTIVE
Credit Suisse, (USA) Inc.	(212) 538-3124	С
700 College Road East		
Princeton, NJ 08450	www.creditsuisse.com	ACTIVE
Direct Energy Business, LLC	(888) 925-9115	R
120 Wood Avenue, Suite 611		
Iselin, NJ 08830	http://www.business.directenergy.com/	ACTIVE
Direct Energy Business	(800) 437-7872	C/I
Marketing, LLC (fka Hess		
Energy Marketing)		
1 Hess Plaza		
Woodbridge, NJ 07095	http://www.business.directenergy.com/	ACTIVE
Direct Energy Services, LLC	(888) 925-9115	R
120 Wood Avenue, Suite 611		
Iselin, NJ 08830	www.directenergy.com	ACTIVE
Direct Energy Small	(888) 464-4377	C/I
Business, LLC (fka Hess		
Small Business Services,		
LLC)		
One Hess Plaza		
Woodbridge, NJ 07095	http://www.business.directenergy.com/	ACTIVE
Discount Energy Group,	(800) 282-3331	R/C
811 Church Road, Suite 149		
Cherry Hill, New Jersey 08002	www.discountonergygroup.com	ACTIVE
	www.discountenergygroup.com	
DTE Energy Supply, Inc.	(877) 332-2450	C/I
One Gateway Center, Suite 2600		ACTIVE
Newark, NJ 07102	www.dtesupply.com	AUIIVE
110 Walk, 113 0/102	www.utcsuppry.com	

Energy.me Midwest LLC	(855) 243-7270	R/C/I
90 Washington Blvd Bedminster, NJ 07921	www.energy.me	ACTIVE
, 		R/C
Energy Plus Holdings LLC 309 Fellowship Road	(877) 866-9193	R/C
East Gate Center, Suite 200		
Mt. Laurel, NJ 08054	www.energypluscompany.com	ACTIVE
Ethical Electric Benefit Co.	(888) 444-9452	R/C
d/b/a Ethical Electric		
100 Overlook Center, 2 nd Fl. Princeton, NJ 08540	www.ethicalelectric.com	ACTIVE
Energy Service Providers,	(866) 568-0290	R/C
Inc., d/b/a New Jersey Gas &	(800) 508-0290	N/C
Electric		
1 Bridge Plaza fl. 2		
Fort Lee, NJ 07024	www.njgande.com	ACTIVE
FirstEnergy Solutions 150 West State Street	(866) 625-7318	C/I
Trenton, NJ 08608	www.fes.com	ACTIVE
Gateway Energy Services	(866)348-4193	R/C
Corp.	(000)540 4175	NC
120 Wood Avenue Suite 611		
Iselin, NJ 08830	www.directenergybusiness.com	ACTIVE
GDF SUEZ Energy	(866) 999-8374	C/I
Resources NA, Inc.		
333 Thornall Street Sixth Floor		
Edison, NJ 08837	www.gdfsuezenergyresources.com	ACTIVE
GDF Suez Retail Energy	1-866-252-0078	R/C/I
Solutions LLC d/b/a THINK		
ENERGY		
333 Thornall St. Sixth Floor Edison, NJ 08819	www.mythinkenergy.com	ACTIVE
Glacial Energy of New	(888) 452-2425	С/І
Jersey, Inc.		
21 Pine Street, Suite 237		
Rockaway, NJ 07866	www.glacialenergy.com	ACTIVE
Global Energy Marketing	(800) 542-0778	R/C/I
LLC 129 Wentz Avenue		ACTIVE
Springfield, NJ 07081	www.globalp.com	ACTIVE
~p		

Green Mountain Energy	(866) 767-5818	C/I
Company 211 Carnegie Center Drive Princeton, NJ 08540	www.greenmountain.com/commercial- <u>home</u>	ACTIVE
Harborside Energy LLC 101 Hudson Street	(877) 940-3835	R/C
Suite 2100 Jersey City, NJ 07302	www.harborsideenergynj.com	ACTIVE
Hess Corporation	(800) 437-7872	C/I
1 Hess Plaza Woodbridge, NJ 07095	www.hess.com	ACTIVE
HIKO Energy, LLC	(888) 264-4908	R/C/I
655 Suffern Road Teaneck, NJ 07666	www.hikoenergy.com	ACTIVE
Hudson Energy Services, LLC	(877) Hudson 9	С
7 Cedar Street Ramsey, New Jersey 07446	www.hudsonenergyservices.com	ACTIVE
IDT Energy, Inc.	(877) 887-6866	R/C
550 Broad Street Newark, NJ 07102	www.idtenergy.com	ACTIVE
Independence Energy	(877) 235-6708	R/C
Group, LLC 211 Carnegie Center Princeton, NJ 08540	www.chooseindependence.com	ACTIVE
Inspire Energy Holdings	(866) 403-2620	R/C/I
LLC 923 Haddonfield Road 3rd Fl. Building B2 Cherry Hill, NJ 08002	www.inspireenergy.com	
Integrys Energy Services,	(800) 536-0151	C/I
Inc. 33 Wood Ave, South, Suite 610		ACTIVE
Iselin, NJ 08830	www.integrysenergy.com	
Jsynergy, LLC 445 Central Ave. Suite 204 Cedarhurst, NY 11516	(516) 331-2020 Jsynergyllc.com	R/C/I ACTIVE
Kuehne Chemical Company,	(973) 589-0700	Ι
Inc. 86 North Hackensack Avenue South Kearney, NJ 07032	kuehnechemical@comcast.net	

Liberty Power Delaware,	(866) 769-3799	C/I
LLC 1973 Highway 34, Suite 211 Wall, NJ 07719	www.libertypowercorp.com	ACTIVE
Liberty Power Holdings,	(866) 769-3799	R/C/I
LLC 1973 Highway 34, Suite 211 Wall, NJ 07719	www.libertypowercorp.com	ACTIVE
Linde Energy Services	(800) 247-2644	C/I
575 Mountain Avenue Murray Hill, NJ 07974	www.linde.com	ACTIVE
Marathon Power LLC	(888) 779-7255	R/C/I
302 Main Street Paterson, NJ 07505	www.mecny.com	ACTIVE
MP2 Energy NJ, LLC	(877) 238-5343	R/C/I
111 River Street, Suite 1204 Hoboken, NJ 07030	www.mp2energy.com	ACTIVE
Natures Current, LLC	(215) 464-6000	R/C/I
95 Fairmount Avenue Philadelphia, Pennsylvania		ACTIVE
19123	www.naturescurrent.com	
MPower Energy NJ LLC	(877) 286-7693	R/C/I
One University Plaza, Suite 507 Hackensack, NJ 07601	www.mpowerenergy.com	ACTIVE
NATGASCO, Inc. (Supreme	(800) 840-4427	R/C/I
Energy, Inc.) 532 Freeman St. Orange, NJ 07050	www.supremeenergyinc.com	ACTIVE
New Jersey Gas & Electric	(866) 568-0290	R/C/
10 North Park Place Suite 420 Morristown, NJ 07960	www.nicondo.com	ACTIVE
Norristown, NJ 07960 NextEra Energy Services	www.njgande.com (877) 528-2890 Commercial	R/C/I
New Jersey, LLC	(800) 882-1276 Residential	
651 Jernee Mill Road Sayreville, NJ 08872	www.nexteraenergyservices.com	ACTIVE
Noble Americas Energy	(877) 273-6772	C/I
Solutions The Mac-Cali Building 581 Main Street, 8th Floor Woodbridge, NJ 07095	www.noblesolutions.com	ACTIVE

Nordic Energy Services,	(877) 808-1027	R/C/I
LLC 50 Tice Boulevard, Suite 340 Woodcliff Lake, NJ 07677	www.nordiceenergy.us.com	ACTIVE
North American Power and Gas, LLC	(888) 313-9086	R/C/I
222 Ridgedale Avenue Cedar Knolls, NJ 07927	www.napower.com	ACTIVE
North Eastern States, Inc. d/b/a Entrust Energy 90 Washington Valley Road	(888) 535-6340	R/C/I
Bedminster, NJ 07921	www.entrustenergy.com	ACTIVE
Oasis Power, LLC d/b/a	(800)324-3046	R/C
Oasis Energy 11152 Westheimer, Suite 901 Houston, TX 77042	www.oasisenergy.com	ACTIVE
Palmco Power NJ, LLC One Greentree Centre 10,000 Lincoln Drive East, Suite 201	(877) 726-5862	R/C/I
Marlton, NJ 08053	www.PalmcoEnergy.com	ACTIVE
Park Power, LLC 1200 South Church St. Suite 23	(856) 778-0079	R/C/I
Mount Laurel, NJ 08054	www.parkpower.com	ACTIVE
Plymouth Rock Energy, LLC	(855) 32-POWER (76937)	R/C/I
338 Maitland Avenue Teaneck, NJ 07666	www.plymouthenergy.com	ACTIVE
Power Management Co., LLC b/b/a PMC Lightsavers Limited Liability Company 1600 Moseley Road	(585) 249-1360	С/І
Victor, NY 14564	www.powermanagementco.com	ACTIVE
PPL Energy Plus, LLC 811 Church Road	(800) 281-2000	C/I
Cherry Hill, NJ 08002	www.pplenergyplus.com	ACTIVE
PPL EnergyPlus Retail, LLC 788 Shrewsbury Avenue, Suite	(732) 741-0505 – 2000	С/І
220 Tinton Falls, NJ 07724	www.pplenergyplus.com	ACTIVE
Progressive Energy Consulting, LLC	(917) 837-7400	R/C/I

PO Box 4582	Progressivenrg@optionline.net	ACTIVE
Wayne, New Jersey 07474		
Prospect Resources, Inc. 208 W. State Street	(847) 673-1959	C
Trenton, NJ 08608-1002	www.prospectresources.com	ACTIVE
Public Power & Utility of	(888) 354-4415	R/C/I
New Jersey, LLC	(000) 554 4415	N/C/I
One International Blvd, Suite		
400	www.ppandu.com	ACTIVE
Mahwah, NJ 07495		
Reliant Energy	(877) 297-3795	R/C/I
211 Carnegie Center	(877) 297-3780	
Princeton, NJ 08540	www.reliant.com	ACTIVE
ResCom Energy LLC	(888) 238-4041	R/C/I
18C Wave Crest Ave.		
Winfield Park, NJ 07036	http://rescomenergy.com	ACTIVE
Residents Energy, LLC	(888) 828-7374	R/C
550 Broad Street		
Newark, NJ 07102	www.residentsenergy.com	
Respond Power LLC	(877) 973-7763	R/C/I
1001 East Lawn Drive	(011) 213 1103	N C/I
Teaneck, NJ 07666	www.majorenergy.com	ACTIVE
Save on Energy, LLC	1 (877)-658-3183	R/C
1101 Red Ventures Drive	1 (877)-038-5185	N/C
Fort Mill, SC 29707	www.saveonenergy.com	
SFE Energy One Gateway Center	1 (877) 316-6344	R/C/I
Suite 2600	www.sfeenergy.com	ACTIVE
Newark, NJ 07012	www.sreenergy.com	nemu
S.J. Energy Partners, Inc.	(800) 695-0666	C
208 White Horse Pike, Suite 4		
Barrington, NJ 08007	www.sjnaturalgas.com	ACTIVE
SmartEnergy Holdings, LLC	(800) 443-4440	R/C/I
100 Overlook Center		
2nd Floor		
Princeton, NJ NJ 08540		
United States of America	www.smartenergy.com	ACTIVE
South Jersey Energy	(800) 266-6020	R/C/I
Company		
1 South Jersey Plaza, Route 54	4.1	ACTIVE
Folsom, NJ 08037	www.southjerseyenergy.com	

Spark Energy Gas, LP/	(713)600-2600	R/C/I
Spark Energy		
2105 City West Blvd.		
Suite 100		
Houston, TX 77042	www.sparkenergy.com	ACTIVE
Sperian Energy Corp.	(888) 682-8082	R/C/I
1200 Route 22 East, Suite		
2000		ACTIVE
Bridgewater, NJ 08807	www.sperianenergy.com	
Starion Energy PA Inc.	(800) 600-3040	R/C/I
101 Warburton Avenue		
Hawthorne, NJ 07506	www.starionenergy.com	ACTIVE
Stream Energy New Jersey,	(877) 369-8150	R/C
LLC		
309 Fellowship Rd., Suite 200	www.streamenergy.net	ACTIVE
Mt. Laurel, NJ 08054		
Summit Energy Services,	1 (800) 90-SUMMIT	C/I
Inc.		
10350 Ormsby Park Place		
Suite 400		
Louisville, KY 40223	www.summitenergy.com	ACTIVE
Texas Retail Energy LLC	(866) 532-0761	C/I
Park 80 West Plaza II, Suite		
200 Se dille Directe NL 07662		
Saddle Brook, NJ 07663 Attn: Chris Hendrix	Toxogratailanaray com	ACTIVE
	Texasretailenergy.com	
TransCanada Power	(877) MEGAWAT	C/I
Marketing Ltd. 190 Middlesex Essex		
Turnpike, Suite 200		
Iselin, NJ 08830	www.transcanada.com/powermarketing	ACTIVE
TriEagle Energy, LP	(877) 933-2453	R/C/I
90 Washington Valley Rd	(017) 755 2755	
Bedminster, NJ 07921	www.trieagleenergy.com	ACTIVE
LICI Enorgy Sorrigon Inc	(800) 427 8545	С/І
UGI Energy Services, Inc. dba UGI Energy Link	(800) 427-8545	U/I
224 Strawbridge Drive		
Suite 107		
Moorestown, NJ 08057	www.ugienergylink.com	ACTIVE
Verde Energy USA, Inc.	(800) 388-3862	R/C
2001 Route 46		•
Waterview Plaza Suite 301		
Parsippany, NJ 07054	www.lowcostpower.com	ACTIVE

Viridian Energy	(866) 663-2508	R/C/I
2001 Route 46, Waterview		
Plaza		
Suite 310		
Parsippany, NJ 07054	www.viridian.com	ACTIVE
XOOM Energy New Jersey,	(888) 997-8979	R/C/I
LLC		
744 Broad Street. 16 th Floor		
Newark, NJ 07102	www.xoomenergy.com	ACTIVE
YEP Energy	(855) 363-7736	R/C/I
89 Headquarters Plaza North		
#1463		
Morristown, NJ 07960	www.yepenergyNJ.com	ACTIVE
Your Energy Holdings, LLC	(855) 732-2493	R/C/I
One International Boulevard		
Suite 400		
Mahwah, NJ 07495-0400	www.thisisyourenergy.com	ACTIVE

Back to the main supplier page

APPENDIX B


Equipment Inventory

CHA Project # 29142 Leroy Smith Public Safety Building Essex County

Description	QTY	Manufacturer Name	Model No.	Serial No.	Equipment Type / Utility	Capacity/Size /Efficiency	Efficiency	Location	Areas/Equipment Served	Date Installed	Remaining Useful Life (years)	Other Info. Current year	Years Old	ASHRAE life expectancy
Boiler	3	AERCO	Benchmark 2000	N/A	HHW Boiler	2000 MBH input, 1740- 1900 MBH output	87%-98% Eff.	Boiler Room	HHW Loop for HHW Coils and HHW Heaters	2010	21	2014	4	25
Pump Motor	2	Baldor	EM2513T	39K057W916	HHW Pump/Motor	15HP	93% efficiency	Boiler Room	HHW Loop for HHW Coils and HHW Heaters	2010	16	2014	4	20
Pump Motor	2	Baldor	EM2513T	39K057W916	Condenser Water Pump/Motor	50HP	95% efficiency	Boiler Room	To Cooling Tower	2010	16	2014	4	20
DHW-1	1	A.O.Smith	Cyclone BTH 120 000	0939M0023030	Natural Gas DHW Heater	120MBH	80%	Boiler Room	Most of the Building	2009	15	2014	5	20
Cooling Tower	1	BAC	PT2-1012-LA	69563803	Cooling Tower	N/A	N/A	Roof	The Whole Building	2010	16	2014	4	20
AHU-1	1	Trane	SCWFR2543MD	T09J20499	AHU	Water source heat pump with HHW coil to preheat the outdoor air 25 ton cooling capacity High Efficiency 15HP Fan Motor	N/A	1st Floor South Side Mechanical Room	South Side of 1-3 floor according to facility staff	2010	16	2014	4	20
AHU-2	1	Trane	SCWFR2543MD	T09J20499	AHU	Water source heat pump with HHW coil to preheat the outdoor air 25 ton cooling capacity High Efficiency 15HP Fan Motor	N/A	1st Floor North Side Mechanical Room	North Side of 1-3 floor according to facility staff	2010	16	2014	4	20
AHU-3	1	Trane	SCWFR2543MD	T09J20499	AHU	Water source heat pump with HHW coil to preheat the outdoor air 25 ton cooling capacity High Efficiency 15HP Fan Motor	N/A	5th Floor South Side Mechanical Room	South Side of 4th and 5th floor according to facility staff	2010	16	2014	4	20
AHU-4	1	Trane	SCWFR2543MD	T09J20499	AHU	Water source heat pump with HHW coil to preheat the outdoor air 25 ton cooling capacity High Efficiency 15HP Fan Motor	N/A	5th Floor North Side Mechanical Room	North Side of 4th and 5th floor according to facility staff	2010	16	2014	4	20
AHU-5	1	Trane	SCWFR2043MD	T09J20758	AHU	Water source heat pump with HHW coil to preheat the outdoor air 20 ton cooling capacity High Efficiency 7.5HP Fan Motor	N/A	7th Floor South Side Mechanical Room	South Side of 6th and 7th floor according to facility staff	2010	16	2014	4	20
AHU-6	1	Trane	SCWFR2043MD	T09J20758	AHU	Water source heat pump with HHW coil to preheat the outdoor air 20 ton cooling capacity High Efficiency 7.5HP Fan Motor	N/A	7th Floor North Side Mechanical Room	North Side of 6th and 7th floor according to facility staff	2010	16	2014	4	20
AHU-7	1	Trane	SCWFR2043MD	T09J20758	AHU	Water source heat pump with HHW coil to preheat the outdoor air 20 ton cooling capacity High Efficiency 7.5HP Fan Motor	N/A	9th Floor South Side Mechanical Room	South Side of 8th and 9th floor according to facility staff	2010	16	2014	4	20
AHU-8	1	Trane	SCWFR2043MD	T09J20758	AHU	Water source heat pump with HHW coil to preheat the outdoor air 20 ton cooling capacity High Efficiency 7.5HP Fan Motor	N/A	9th Floor North Side Mechanical Room	North Side of 8th and 9th floor according to facility staff	2010	16	2014	4	20
AHU-9	1	Trane	SCWFR2043MD	T09J20758	AHU	Water source heat pump with HHW coil to preheat the outdoor air 20 ton cooling capacity High Efficiency 7.5HP Fan Motor	N/A	9th Floor South Side Mechanical Room	South Side of 8th and 9th floor according to facility staff	2010	16	2014	4	20
AHU-10	1	Trane	SCWFR2043MD	T09J20758	AHU	Water source heat pump with HHW coil to preheat the outdoor air 20 ton cooling capacity High Efficiency 7.5HP Fan Motor	N/A	9th Floor North Side Mechanical Room	North Side of 8th and 9th floor according to facility staff	2010	16	2014	4	20
HRU-1	1	RenewAire	N/A	N/A	Heat Recovery Unit	Heat Recovery Units for the ventilation and has a 7.5HP supply fan	N/A	14th Floor South Side Mechanical Room	AHUs	2010	-4	2014	4	
HRU-2	1	RenewAire	N/A	N/A	Heat Recovery Unit	Heat Recovery Units for the ventilation and has a 7.5HP supply fan	N/A	14th Floor North Side Mechanical Room	AHUs	2010	-4	2014	4	
HPV-1	1	Trane	GEVE1204	W10C04801	AHU with water source heat pump	AHU with water source heat pump	N/A	Conference Room in 14th floor	AHUS	2010	-4	2014	4	
HPV-2	1	Trane	GEVE1204	W10C04802	AHU with water source heat pump	AHU with water source heat pump	N/A	Conference Room in 14th floor	AHUS	2010	-4	2014	4	
Fan Coil Units	many	Trane	N/A	N/A	Fan Coil Units	N/A	N/A	4rd floors	Public Safety Offices that are not accessible	2010	16	2014	4	20
Split Units Electric DHW Heaters	3	Mitsubishi A O Smith	PUY-A42NHA2 DES-100	N/A N/A	Split Unit Electric DHW heater	3.5 ton Cooling capacity 12kW heating capacity	EER of 12 100%	Roof Mechanical Rooms	Server Rooms Each floor	2010 2010	<u> </u>	2014 2014	4 4	20 20



CHA Projec	dit of Essex County - Leroy Smith Public Safety Complex of No.29142 ghting & Audit Input				Cost of Electricity:		<mark>!3</mark> \$/kWh <mark>′9</mark> \$/kW					
					EXISTING CON	DITIONS					Retrofit	
			No. of			Watts per					Control	
	Area Description	Usage	Fixtures	Standard Fixture Code	Fixture Code	Fixture	kW/Space	Exist Control	Annual Hours	Annual kWh		
Field	Unique description of the location - Room number/Room	Describe Usage Type	No. of	Lighting Fixture Code	Code from Table of Standard Fixtur		(Watts/Fixt) * (Fixt	Pre-inst. control	Estimated	(kW/space) *	Retrofit control	Notes
Code	name: Floor number (if applicable)	using Operating Hours	fixtures		Wattages	Table of	No.)	device	annual hours for	· · · · · · · · · · · · · · · · · · ·	device	
			before the			Standard			the usage group			
			retrofit			Fixture						
32LED	Basement Mechanical Room	Mechanical Room	15	1T 32 R F 2 (ELE)	F42LL	Wattages 60	0.90	SW	8736	7,862	NONE	
32LED	Sprinkler Room	Mechanical Room	4	1T 32 R F 2 (ELE)	F42LL	60	0.24	SW	8736	2,097	NONE	
32LED	Electric Room	Mechanical Room	6	1T 32 R F 2 (ELE)	F42LL	60	0.36	SW	8736	3,145	C-0CC	
20LED	Court Storage	Storage Areas	22	S 28 P F 1 (ELE)	F41ILL	31	0.68	000	8736	5,958	C-OCC	
20LED	Court Storage	Offices	16	S 28 P F 1 (ELE)	F41ILL	31	0.50	000	8736	4,333	C-0CC	
20LED	Court Storage	Offices	24	S 28 P F 1 (ELE)	F41ILL	31	0.74	000	8736	6,500	000-0	
20LED	Court Storage	Offices	10	S 28 P F 1 (ELE)	F41ILL	31	0.31	000	8736	2,708	C-0CC	
20LED	Server Room	Storage Areas	4	S 28 P F 1 (ELE)	F41ILL	31	0.12	000	8736	1,083	C-0CC	
20LED	Office	Offices	2	S 28 P F 1 (ELE)	F41ILL	31	0.06	000	8736	542	0000	
20LED 20LED	Hall Warehouse Storage	Hallways	16 32	S 28 P F 1 (ELE) S 28 P F 1 (ELE)	F41ILL	31	0.50	OCC SW	8736 8736	4,333 8,666	000-0 00-0	
32LED	Computer Control Room	Storage Areas Storage Areas	32	1T 32 R F 2 (ELE)	F41ILL F42LL	60	0.99	SW	8736	2,097	230-3	
32LED	Storage	Storage Areas	2	1T 32 R F 2 (ELE)	F42LL F42LL	60	0.24	SW	8736	1,048	020-22 020-2	
32LED	Electric Generator Room	Storage Areas	2	1T 32 R F 2 (ELE)	F42LL	60	0.12	SW	8736	1,048	000-0 C-0CC	
32LED	1st Floor Mechanical Room South	Mechanical Room	4	1T 32 R F 2 (ELE)	F42LL	60	0.12	SW	8736	2,097	000-0 C-0CC	
32LED	Mechanical Room North	Mechanical Room	4	1T 32 R F 2 (ELE)	F42LL	60	0.24	SW	8736	2,097	C-0CC	
20LED	2nd Floor Record Storage	Storage Areas	40	S 28 P F 1 (ELE)	F41ILL	31	1.24	SW	8736	10,833	NONE	
20LED	2nd Floor Record Storage	Storage Areas	42	S 28 P F 1 (ELE)	F41ILL	31	1.30	SW	8736	11,374	C-0CC	
25	Elevator Lobby	Hallways	17	R 13 C CF 2 (ELE)	CFQ13/2-L	28	0.48	SW	8736	4,158	C-0CC	
32LED	Break Room	Staff Lounge	12	1T 32 R F 2 (ELE)	F42LL	60	0.72	SW	8736	6,290	NONE	
32LED	Break Room	Staff Lounge	8	1T 32 R F 2 (ELE)	F42LL	60	0.48	SW	8736	4,193	NONE	
32LED	Small Break Room	Staff Lounge	2	1T 32 R F 2 (ELE)	F42LL	60	0.12	SW	8736	1,048	C-0CC	
25	Small Break Room	Staff Lounge	2	R 13 C CF 2 (ELE)	CFQ13/2-L	28	0.06	SW	8736	489	C-0CC	
32LED	Mechanical Room	Mechanical Room	4	1T 32 R F 2 (ELE)	F42LL	60	0.24	SW	8736	2,097	0000	
32LED	3rd Floor Rocord Storage	Staff Lounge	40	1T 32 R F 2 (ELE)	F42LL	60	2.40	SW	8736	20,966	0000	
32LED 20LED	3rd Floor Rocord Storage Elevator Lobby	Staff Lounge Hallways	40	1T 32 R F 2 (ELE) S 28 P F 1 (ELE)	F42LL F41ILL	60	2.40 0.19	SW SW	8736 8736	20,966 1,625	000-0 00-0	
20LED 20LED	Elevator Lobby	Hallways	10	S 28 P F 1 (ELE)	F41ILL	31	0.19	SW	8736	2,708	NONE	
196LED	Office	Offices	10	W 32 C F 4 (ELE)	F41LL	112	0.31	SW	8736	978	C-OCC	
196LED	Office	Offices	1	W 32 C F 4 (ELE)	F44ILL	112	0.11	SW	8736	978	NONE	
196LED	Office	Offices	1	W 32 C F 4 (ELE)	F44ILL	112	0.11	SW	8736	978	C-0CC	
196LED	Office	Offices	1	W 32 C F 4 (ELE)	F44ILL	112	0.11	SW	8736	978	C-0CC	
35LED	1st Floor Office 113A	Offices	2	T 32 R F 3 (ELE)	F43ILL/2	90	0.18	000	8736	1,572	C-0CC	
32LED	113B	Offices	3	1T 32 R F 2 (ELE)	F42LL	60	0.18	000	8736	1,572	C-OCC	
32LED	114	Mechanical Room	4	1T 32 R F 2 (ELE)	F42LL	60	0.24	000	8736	2,097	C-0CC	
32LED	116	Staff Lounge	2	1T 32 R F 2 (ELE)	F42LL	60	0.12	000	8736	1,048	C-0CC	
32LED	117	Offices	2	1T 32 R F 2 (ELE)	F42LL	60	0.12	000	8736	1,048	C-0CC	
32LED	119	Offices	4	1T 32 R F 2 (ELE)	F42LL	60	0.24	000	8736	2,097	C-0CC	
32LED	120	Offices	2	1T 32 R F 2 (ELE)	F42LL	60	0.12	000	8736	1,048	0000	
32LED	121	Offices	2	1T 32 R F 2 (ELE)	F42LL	60	0.12	220 220	8736	1,048	0000	
32LED 32LED	122 123	Hallways Offices	2	1T 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL F42LL	60	0.12	000	8736	1,048	000-0 00-0	
32LED 32LED	123	Staff Lounge	2	1T 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL F42LL	<u>60</u> 60	0.12	000	8736 8736	1,048 2,097	NONE	
32LED 32LED	124	Staff Lounge	4	1T 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL F42LL	60	0.12	000	8736	1,048	C-OCC	
32LED	125	Staff Lounge	3	1T 32 R F 2 (ELE)	F42LL	60	0.12	000	8736	1,572	000-0 00-0 00-0	
5LED	135	Staff Lounge	9	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.54	000	8736	4,717	C-0CC	
5LED	136	Hallways	8	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.48	000	8736	4,193	C-OCC	
32LED	106 Womens Room	Restroom	3	1T 32 R F 2 (ELE)	F42LL	60	0.18	000	8736	1,572	C-OCC	
32LED	107 Men's Room	Restroom	3	1T 32 R F 2 (ELE)	F42LL	60	0.18	000	8736	1,572	C-OCC	
32LED	102 Stair	Hallways	2	1T 32 R F 2 (ELE)	F42LL	60	0.12	000	8736	1,048	C-0CC	
32LED	110	Offices	2	1T 32 R F 2 (ELE)	F42LL	60	0.12	000	8736	1,048	000-0	
32LED	137	Storage Areas	1	1T 32 R F 2 (ELE)	F42LL	60	0.06	000	8736	524	000-0	
32LED	138	Staff Lounge	2	1T 32 R F 2 (ELE)	F42LL	60	0.12	000	8736	1,048	C-0CC	
32LED	139	Offices	2	1T 32 R F 2 (ELE)	F42LL	60	0.12	000	8736	1,048	C-0CC	
32LED	140	Offices	3	1T 32 R F 2 (ELE)	F42LL	60	0.18	000	8736	1,572	0000	
32LED	141	Offices	2	1T 32 R F 2 (ELE)	F42LL	60	0.12	220	8736	1,048	220-2	
25 32LED	142	Offices Offices	6	R 13 C CF 2 (ELE) 1T 32 R F 2 (ELE)	CFQ13/2-L F42LL	<u>28</u> 60	0.17	220 220	8736 8736	1,468 2,097	000-0 00-0	
32LED 32LED	<u>142</u> 143	Hallways	4	11 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL F42LL		0.24		8736	2,097		
32LED 32LED	143	Offices	2	1T 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL F42LL	60 60	0.12	000 000	8736	1,048	000-0 00-0	
32LED 32LED	144	Offices	2	1T 32 R F 2 (ELE)	F42LL F42LL	60	0.12	000	8736	1,048	000-0 00-0	
32LED	145	Offices	2	1T 32 R F 2 (ELE)	F42LL	60	0.12	000	8736	1,048	000-0 00-0 00-0	
32LED	147	Offices	4	1T 32 R F 2 (ELE)	F42LL	60	0.12	000	8736	2,097	000-000 00-000	
32LED	148	Offices	2	1T 32 R F 2 (ELE)	F42LL	60	0.12	000	8736	1,048	C-OCC	
32LED	149	Offices	2	1T 32 R F 2 (ELE)	F42LL	60	0.12	000	8736	1,048	C-0CC	
32LED	4th Floor Cubicles	Offices	45	1T 32 R F 2 (ELE)	F42LL	60	2.70	000	8736	23,587	C-0CC	
32LED	414	Offices	4	1T 32 R F 2 (ELE)	F42LL	60	0.24	000	8736	2,097	C-0CC	
32LED	415	Offices	3	1T 32 R F 2 (ELE)	F42LL	60	0.18	000	8736	1,572	C-0CC	
32LED	416	Offices	4	1T 32 R F 2 (ELE)	F42LL	60	0.24	000	8736	2,097	C-0CC	
32LED	417	Offices	2	1T 32 R F 2 (ELE)	F42LL	60	0.12	000	8736	1,048	000-0	
25	411 Women's Room	Restroom	2	R 13 C CF 2 (ELE)	CFQ13/2-L	28	0.06	000	8736	489	C-0CC	



Energy Audit of Essex County - Leroy Smith Public Safety Complex

Γ			No. of		EXISTING	ONDITIONS Watts per					- Retrofit Control	
	Area Description	Usage	Fixtures	Standard Fixture Code	Fixture Code	Fixture	kW/Space	Exist Control	Annual Hours	Annual kWh	Control	
Field	Unique description of the location - Room number/Room	Describe Usage Type	No. of	Lighting Fixture Code	Code from Table of Standard F	xture Value from	(Watts/Fixt) * (Fixt	Pre-inst. control	Estimated	(kW/space) *	Retrofit control	Notes
Code	name: Floor number (if applicable)	using Operating Hours	fixtures		Wattages	Table of	No.)	device	annual hours for	(Annual Hours)	device	
			before the			Standard			the usage group			
			retrofit			Fixture						
						Wattages						
2LED	409	Hallways	10	1T 32 R F 2 (ELE)	F42LL	60	0.60	000	8736	5,242		
2LED	407	Offices	2	1T 32 R F 2 (ELE)	F42LL	60	0.12	000	8736	1,048		
2LED	408	Offices	1	1T 32 R F 2 (ELE)	F42LL	60	0.06	000	8736	524		
25	408	Hallways	3	R 13 C CF 2 (ELE)	CFQ13/2-L	28	0.08	000	8736	734		
250	406	Conference	4	T 54 W F 3 (ELE) (T-5)	F43GHL	177	0.71	000	6000	4,248		
25	404 Men's Room	Restroom	3	R 13 C CF 2 (ELE)	CFQ13/2-L	28	0.08	000	8736	734		
5LED	419	Offices	1	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.06	000	8736	524		
2LED	420	Offices	1	1T 32 R F 2 (ELE)	F42LL	60	0.06	000	8736	524		
2LED	423	Offices	2	1T 32 R F 2 (ELE)	F42LL	60	0.12	000	8736	1,048		
2LED	424	Offices	4	1T 32 R F 2 (ELE)	F42LL	60	0.24	000	8736	2,097		
2LED	425	Offices	2	1T 32 R F 2 (ELE)	F42LL	60	0.12	000	8736	1,048		
2LED	426	Offices	2	1T 32 R F 2 (ELE)	F42LL	60	0.12	000	8736	1,048		
2LED	427	Offices	2	1T 32 R F 2 (ELE)	F42LL	60	0.12	000	8736	1,048		
2LED	428	Offices	4	1T 32 R F 2 (ELE)	F42LL	60	0.24	000	8736	2,097		
2LED	429	Offices	6	1T 32 R F 2 (ELE)	F42LL	60	0.36	000	8736	3,145		
2LED	430	Offices	6	1T 32 R F 2 (ELE)	F42LL	60	0.36	000	8736	3,145		
2LED	433	Offices	3	1T 32 R F 2 (ELE)	F42LL	60	0.18	000	8736	1,572		
2LED	435	Offices	8	1T 32 R F 2 (ELE)	F42LL	60	0.48	000	8736	4,193		
25	Elevator Lobby	Hallways	14	R 13 C CF 2 (ELE)	CFQ13/2-L	28	0.39	OCC	8736	3,425	<u>C-OCC</u>	
							1					
	Total		629				30.48			264,301		

APPENDIX C

ECM Calculations

Essex County -Leroy Smith Public Safety Complex CHA Project Number: 29142

Essex County - Leroy Smith Public Safety Complex

			<u> </u>																				
Recommend?		Item			Sa	avings			Cost	Simple	Life	Equivalent CO ₂	JJ Smart Start	Direct Install	Payback w/		Simple	Projected Lifetim	e Savings		ROI	NPV	IRR
Y or N			kW	kWh	therms	No. 2 Oil gal	Water kgal	\$		Payback	Expectancy	(Metric tons)	Incentives	Eligible (Y/N)	Incentives	kW	kWh	therms	kgal/yr	\$			
Y	ECM-1	Central DDC System Retro-commissioning	0.0	40,000	2,397	0	0	8,235	56,279	6.8	15	29.6 \$	-	Ν	6.8	0.0	600,000	35,948	0 \$	123,529	1.2	\$42,033	11.9%
Y	ECM-2	Replace DHW Water Heater with Condensing DHW Water Heater	0.0	0	667	0	0	611	\$ 11,780	19.3	15	3.6 5	120	Ν	19.1	0.0	0	10,000	0 \$	9,160	(0.2)	(\$4,370)	-2.9%
N	ECM-L1	Lighting Replacements / Upgrades	14	126,375	0	0	0	18,729	§ 114,708	6.1	15	53.1 5	16,970	Ν	5.2	216.9	1,895,625	0	0 \$	296,104	1.6	\$125,851	17.4%
Ν	ECM-L2	Install Lighting Controls (Add Occupancy Sensors)	0	27,044	0	0	0	3,867	\$ 21,870	5.7	15	11.4 5	2,835	Ν	4.9	0.0	405,660	0	0 \$	61,255	1.8	\$27,132	18.8%
Y	ECM-L3	Lighting Replacements with Controls (Occupancy Sensors)	14	140,321	0	0	0	20,723	\$ 136,578	6.6	15	59.0 5	19,805	Ν	5.6	216.8	2,104,822	0	0 \$	327,686	1.4	\$130,619	15.8%
		Total (Does Not Include ECM-L1 & ECM-L2)	14.5	180,321	3,063	0	0	\$ 29,569	6 204,637	6.9	15.0	92 \$	19,925		6.2	217	2,704,822	45,948	- \$	460,374	1.2	168,281	13.7%
		Recommended Measures (highlighted green above)	14.5	180,321	3,063	0	0	\$ 29,569	5 204,637	6.9	15.0	92 \$	19,925	0	6.2	217	2,704,822	45,948	- \$	460,374	1.2	168,281	13.7%
		% of Existing	3%	8%	6%	0	0																

	Utility	y Costs	Yearly Usage	Metric Ton Carbon Dioxide Equivalent	Building Area	A	nnual Utility Co	st
	\$ 0.151	\$/kWh blended		0.000420205	129,050	Electric	Natural Gas	Fuel
	\$ 0.143	\$/kWh supply	2,309,237	0.000420205		\$ 348,483	\$ 47,573	
	\$ 3.79	\$/kW	566.3	0				
	\$ 0.92	\$/Therm	51,931	0.00533471				
Estimated	\$ 7.50	\$/kgals		0				
		\$/Gal						

		City:	Newar	k. NJ	1		
	Occupied H	lours/Week	168				
	· · · ·		Building	Auditorium	Gymnasium	Library	Classrooms
	Enthalpy		Operating	¥		Occupied	Occupied
Temp	h (Btu/lb)	Bin Hours	Hours	Hours	Hours	Hours	Hours
102.5							
97.5	35.4	6	6	0	0	0	0
92.5	37.4	31	31	0	0	0	0
87.5	35.0	131	131	0	0	0	0
82.5	33.0	500	500	0	0	0	0
77.5	31.5	620	620	0	0	0	0
72.5	29.9	664	664	0	0	0	0
67.5	27.2	854	854	0	0	0	0
62.5	24.0	927	927	0	0	0	0
57.5	20.3	600	600	0	0	0	0
52.5	18.2	730	730	0	0	0	0
47.5	16.0	491	491	0	0	0	0
42.5	14.5	656	656	0	0	0	0
37.5	12.5	1,023	1,023	0	0	0	0
32.5	10.5	734	734	0	0	0	0
27.5	8.7	334	334	0	0	0	0
22.5	7.0	252	252	0	0	0	0
17.5	5.4	125	125	0	0	0	0
12.5	3.7	47	47	0	0	0	0
7.5	2.1	34	34	0	0	0	0
2.5	1.3	1	1	0	0	0	0
-2.5							
-7.5							

Multipliers				
Material:	1.027			
Labor:	1.246			
Equipment:	1.124			
	Heating System Efficiency			
Cooling Eff (kV	1.3			


He	ating	
Hours	4,427	Hrs
Weighted Avg	40	F
Avg	28	F
Со	oling	
Hours	4,333	Hrs
Weighted Avg	68	F
Ανα	78	F




Rate of Discount (used for NPV)

uel Oil

	Utility En	d Use Analysis		
Electricity	y Use (kWh):	Notes/Comments:		
2,309,237 T	otal	Based on utility analysis		
950,000 L	.ighting	Estimated		
200,000 N	/lotors	Estimated		
800,000 C	800,000 Cooling Estimated			
50,000 F	Plug Load	Estimated		
250,000 C	Computers/Servers	Estimated		
9,237 C	Other	Remaining		
Natural Gas	Use (Therms):	Notes/Comments:		
51,931 T	otal	Based on utility analysis		
47,931 B	Boilers			
4,000 C				





ECM-1 Central DDC System Retro-commissioning

Description: This ECM evaluates the energy savings associated with retro-commissioning the existing DDC system and repairing malfuctional VAV boxes, dampers and so on. The energy savings percentage is based on past performance of similar buildings which have a fully functioning DDC control system.

Building Information:						
129,050	Sq Footage					
Y	Cooling					
Y	Heating					

\$0.15 \$/kWh Blended \$0.92 \$/Therm

FULL DDC - TEMPERATURE SETBACK SAVINGS CALCULATION

EXISTING CONDITIONS								
Heating								
Heating Season Facility Temp	72	F						
Weekly Occupied Hours	40	hrs						
Heating Season Setback Temp	72	F						
Heating Season % Savings per Degree Setback	1%							
Annual Boiler Capacity	2,360	Mbtu/yr						
Connected Heating Load Capacity	2,360,000	Btu/hr						
Equivalent Full Load Heating Hours	100	hrs						
Heating System Efficiency	80%							
Cooling								
Cooling Season Facility Temp	72	F						
Weekly Occupied Hours	40	hrs						
Cooling Season Setback Temp	72	F						
Cooling Season % Savings per Degree Setback	0%							
Connected Cooling Load Capacity	200	Tons						
Equivalent Full Load Cooling Hours	100	hrs						
Cooling Equipment EER	10.0							
SAVINGS		-						
Natural Gas Savings	0	Therms						
Cooling Electricity Savings	0	kWh						

Nighttime Setback		
EXISTING CONDITIONS		
Heating		
Heating Season Facility Temp	72	F
Weekly Occupied Hours	40	hrs
Heating Season Setback Temp	72	F
Heating Season % Savings per Degree Setback	1%	
Annual Boiler Capacity		Mbtu/yr
Connected Heating Load Capacity	2,360,000	Btu/hr
Equivalent Full Load Heating Hours	50	hrs
Heating Equipment Efficiency	80%	
Cooling		
Cooling Season Facility Temp	72	F
Weekly Occupied Hours	40	hrs
Cooling Season Setback Temp	80	F
Cooling Season % Savings per Degree Setback	0%	
Connected Cooling Load Capacity	200	Tons
Equivalent Full Load Cooling Hours	50	hrs
Cooling Equipment EER	10.0	
SAVINGS		

FULL DDC - ADDITIONAL CONTROLS SAVINGS CALCULATION

EXISTING CONDITIONS							
Existing Facility Total Electric usage	2,309,237	kWh					
Existing Facility Total Gas usage	51,931	Therms					
Existing Facility Cooling Electric usage	800,000.0	kWh ¹					
Existing Facility Heating Natural Gas usage	47,931	Therms ⁻					
PROPOSED CONDITIONS							
Proposed Facility Cooling Electric Savings	40,000	kWh					
Proposed Facility Natural Gas Savings	2,397	Therms					
SAVINGS							
Electric Savings	40,000	kWh					
Natural Gas Savings	2,397	Therms					

Assumptions

1

2 3

- 35% of facility total electricity dedicated to Cooling; based on utility information
- 92% of facility total natural gas dedicated to Heating; based on utility information
- 5% The building already has a DDC control system but have not been calibrated or comministed. Therefore, it is estimated there would be 5% savings after commissioning the system

COMBINED SAVINGS								
Natural Gas Savings	2,397	Therms						
Cooling Electricity Savings	40,000	kWh						
Total Cost Savings	\$ 8,235							
Estimated Total Project Cost	\$ 56,279							
Simple Payback	6.8	Yrs						

SAVINGS		
Natural Gas Savings	0	Therms ³
Cooling Electricity Savings	0	kWh

Savings calculation formulas for setback are taken from NJ Protocols document for Occupancy Controlled Thermostats Savings calculations for additional controls are estimated based on the level of control to be added and prior experience

Multipliers							
Material: 1.03							
Labor:	1.25						
Equipment:	1.00						

ECM-1 Central DDC System Retro-commissioning - Cost

Description	QTY	UNIT	UNIT COSTS		SUBTOTAL COSTS			TOTAL COST REMARKS		
Description	QII	UNIT	MAT.	MAT. LABOR EQUIP.			LABOR	EQUIP.	TOTAL COST	REMARKS
						\$-	\$-	\$-	\$-	
Retrocommisson DDC system	129050	SF		\$ 0.28		\$-	\$ 45,023	\$-	\$ 45,023	DOE estimate
						\$-	\$-	\$-	\$-	
						\$-	\$-	\$-	\$-	
						\$-	\$-	\$-	\$-	

**Cost Estimates are for Energy Savings calculations only, do not use for procurement

\$ 45,023	Subtotal
\$ 11,256	25% Contingency
\$ 56,279	Total

ECM-2 Replace DHW Water Heater with Condensing DHW Water Heater

Description: This ECM evaluates the energy savings associated with replacing the gas fired tank type water heater with an equivalent capacity water heater.

-			
<u>ltem</u>	Value	<u>Units</u>	Formula/Comments
Avg. Monthly Utility Demand by Water Heater	333	Therms/month	Calculated from utility bill
Total Annual Utility Demand by Water Heater	400,000	MBTU/yr	1therm = 100 MBTU
Existing DHW Heater Efficiency	80%		Per manufacturer nameplate
Total Annual Hot Water Demand (w/ standby losses)	320,000	MBTU/yr	
Existing Tank Size	100	Gallons	Per manufacturer nameplate
Hot Water Piping System Capacity	5	Gallons	Estimated Per existing system (includes HWR piping)
Hot Water Temperature	120	°F	Per building personnel
Room Temperature	72	°F	
Standby Losses (% by Volume)	2.5%		(2.5% of stored capacity per hour, per U.S. Department of Energy)
Standby Losses (Heat Loss)	1.1	MBH	
Annual Standby Hot Water Load	9,198	MBTU/yr	
New Tank Size	100	Gallons	Based on A O Smith, condensing DHW Heater
Hot Water Piping System Capacity	5	Gallons	Estimated Per existing system (includes HWR piping)
Hot Water Temperature	120	°F	
Room Temperature	72	°F	
Standby Losses (% by Volume)	2.5%		(2.5% of stored capacity per hour, per U.S. Department of Energy)
Standby Losses (Heat Loss)	1.1	MBH	
Annual Standby Hot Water Load	9,198	MBTU/yr	
Total Annual Hot Water Demand	320,000	MBTU/yr	
Proposed Avg. Hot water heater efficiency	96%		Based on A O Smith, condensing DHW Heater Standby Losses and inefficient DHW heater eliminated
Proposed Fuel Use	3,333	Therns	Standby Losses and inefficient DHW heater eliminated
	\$ 0.00	ф <i>(</i> т)	
Utility Cost	\$0.92	\$/Therm	
Existing Operating Cost of DHW	\$3,664	\$/yr	
Proposed Operating Cost of DHW	\$3,053	\$/yr	

Savings Summary:

Utility	Energy	Cost Savings
Therms/yr	667	\$611

Multipliers	
Material:	1.03
Labor:	1.25
Equipment:	1.12

ECM-2 Replace DHW Water Heater with Condensing DHW Water Heater - Cost

Description		UNIT	UNIT COSTS			SUBTOTAL COSTS			TOTAL	REMARKS
			MAT.	LABOR	EQUIP.	MAT.	LABOR	EQUIP.	COST	REWARRS
DHW Heater Removal	1	LS		\$ 50		\$-	\$ 62	\$-	\$ 62	RS Means 2012
High Efficiency Gas-Fired DHW Heater	1	EA	\$ 5,500	\$ 500		\$ 5,649	\$ 623	\$-	\$ 6,272	Estimated
Miscellaneous Electrical	1	LS	\$ 300	\$ 300		\$ 308	\$ 374	\$-	\$ 682	RS Means 2012
Venting Kit	1	EA	\$ 450	\$ 650		\$ 462	\$ 810	\$-	\$ 1,272	RS Means 2012
Miscellaneous Piping and Valves	1	LS	\$ 500	\$ 500		\$ 514	\$ 623	\$-	\$ 1,137	Estimated

**Cost Estimates are for Energy Savings calculations only, do not use for procurement

\$ 9,424	Subtotal
\$ 2,356	25% Contingency
\$ 11,780	Total

New Jersey Pay For Performance Incentive Program

Note: The following calculation is based on the New Jersey Pay For Performance Incentive Program per April, 2012. Building must have a minimum average electric demand of 100 kW. This minimum is waived for buildings owned by local governements or non-profit organizations.

At a minimum, all recommended measures were used for this calculation. To qualify for P4P incentives, the following P4P requirements must be met:

- At least 15% source energy savings

- No more than 50% savings from lighting measures
- Scope includes more than one measure

- Project has at least a 10% internal rate of return

- At least 50% of the source energy savings must come from investor-owned electricity and/or natural gas (note: exemption for fuel conversions)

Incentive #1							
Audit is funded by NJ BPU	\$0.05	\$/sqft					

Is this audit funded by NJ BPU (Y/N) Board of Public Utilites (BPU)

Total Building Area (Square Feet)

	Annual	Utilities			
	kWh Therms				
Existing Cost (from utility)	\$348,483	\$47,573			
Existing Usage (from utility)	2,309,237	51,931			
Proposed Savings	180,321	3,063			
Existing Total MMBtus	13,075				
Proposed Savings MMBtus	92	22			
% Energy Reduction	7.1%				
Proposed Annual Savings	\$29,569				

129,050

Yes

	Min (Savings = 15%)		Increase (Savings > 15%)		Max Incentive		Achieved Incentive	
	\$/kWh	\$/therm	\$/kWh	\$/therm	\$/kWh	\$/therm	\$/kWh	\$/therm
Incentive #2	\$0.09	\$0.90	\$0.005	\$0.05	\$0.11	\$1.25	\$0.00	\$0.00
Incentive #3	\$0.09	\$0.90	\$0.005	\$0.05	\$0.11	\$1.25	\$0.00	\$0.00

		Incentives \$				
	Elec Gas Total					
Incentive #1	\$0	\$0	\$0			
Incentive #2	\$0	\$0	\$0			
Incentive #3	\$0	\$0	\$0			
Total All Incentives	\$0	\$0	\$0			

Total Project Cost	\$204,637

		Allowable Incentive	
% Incentives #1 of Utility Cost*	0.0%	\$0	
% Incentives #2 of Project Cost**	0.0%	\$0	
% Incentives #3 of Project Cost**	0.0%	\$0	
Total Eligible Incentives***	\$0		
Project Cost w/ Incentives	\$204,637		

Project Payb	ack (years)
w/o Incentives	w/ Incentives
6.9	6.9

* Maximum allowable incentive is 50% of annual utility cost if not funded by NJ BPU, and %25 if it is.

** Maximum allowable amount of Incentive #2 is 25% of total project cost.

Maximum allowable amount of Incentive #3 is 25% of total project cost.

*** Maximum allowable amount of Incentive #1 is \$50,000 if not funded by NJ BPU, and \$25,000 if it is.

Maximum allowable amount of Incentive #2 & #3 is \$1 million per gas account and \$1 million per electric account; maximum 2 million per project

Energy Audit of Essex County - Leroy Smith Public Safety Complex CHA Project No.29142 ECM-L1 Lighting Replacements

										RETROFIT CONDITIONS		T				COST & SAVIN	ISS ANAL I SIS	Simple Paybac	
				Watts per						Watts per	kW/Space	Retrofit		Annual kV			NJ Smart Star	rt With Out	
le Unique des	Area Description escription of the location - Room number/Room	No. of Fixtures Standard Fixture Code No. of fixtures "Lighting Fixture Code" Example 2T	Fixture Code Code from Table of Standard	Fixture Value from	kW/Space Exist (Watts/Fixt) * (Fixt Pre-in	Control Annual Hours st. Estimated daily		Number of Fixtures Standard Fixture Code No. of fixtures after "Lighting Fixture Code"	Fixture Code Code from Table of			Control Retrofit contro	Annual Hours Ar	nual kWh Saved //space) * (Original Anr		Annual \$ Saved (kWh Saved) *	Retrofit Cost Lighting Incenti Cost for Prescriptive	ive Incentive Length of time	Simple Payba
	name: Floor number (if applicable)	before the retrofit 40 R F(U) = 2'x2' Troff 40 w Recess. Floor 2		Table of		ol device hours for the	(Annual Hours)	the retrofit 2T 40 R F(U) = 2'x2' Troff 40 w Recess. Floor 2 lamps U shape	Standard Fixture Wattages	Table of Standard	(Number of Fixtures)	device	annual hours (Ar	nual kWh) - (Retro urs) Annual kWh)	ofit kW) - (Retrofit	(\$/kWh)	renovations to Lighting lighting system Measures	for renovations	
		lamps U shape		Standard Fixture		usage group		Recess. 1 loor 2 lamps 0 shape	wallayes	Fixture	i ixtures)		group				ingriting system measures	recovered	De lecovered
	Basement Mechanical Room	15 1T 32 R F 2 (ELE)	F42LL	Wattages 60	0.9	SW 8736	7,86		200732x2	Wattages 30	0.5	SW	8,736	3,931	3,931 0.5	\$ 582.63	3 \$ 3,505.50 \$ 0	6.0	6.0
	Sprinkler Room Electric Room	4 1T 32 R F 2 (ELE) 6 1T 32 R F 2 (ELE)	F42LL F42LL	<u> </u>	0.2	SW 8736 SW 8736	2,09		200732x2 200732x2	30	0.1	SW	8,736 8,736	· · · · · · · · · · · · · · · · · · ·	1,048 0.1 1.572 0.2	\$ 155.37 \$ 233.05	¢ 001100 ¢0	6.0 6.0	6.0
	Court Storage	22 S 28 P F 1 (ÈLE)	F41ILL	31	0.7 (DCC 8736	5,95	8 22 4 ft LED Tube	200732x1	15	0.3	000	8,736	2,883	3,075 0.4	\$ 455.74	\$ 3,194.40 \$0	7.0	7.0
	Court Storage Court Storage	16 S 28 P F 1 (ELE) 24 S 28 P F 1 (ELE)	F41ILL F41ILL	31		DCC 8736 DCC 8736	4,33		200732x1 200732x1	15 15	0.2	000 000	8,736 8,736	,	2,236 0.3 3,355 0.4	\$ 331.45 \$ 497.18	¢ _;020:20 \$0	7.0	7.0
	Court Storage	10 S 28 P F 1 (ELE) 4 S 28 P F 1 (ELE)	F41ILL	31		DCC 8736	2,70	8 10 4 ft LED Tube	200732x1	15	0.2	000	8,736	1,310	1,398 0.2	\$ 207.16	5 \$ 1,452.00 \$0	7.0	7.0
	Server Room Office	2 S 28 P F 1 (ELE) 2 S 28 P F 1 (ELE)	F41ILL F41ILL	31 31	0.1 0	DCC 8736 DCC 8736	1,08	3 4 4 ft LED Tube 2 2 4 ft LED Tube	200732x1 200732x1	15	0.1	000 000	8,736 8,736	262	559 0.1 280 0.0	\$ 82.86 \$ 41.43		7.0	7.0
	Hall Warehouse Storage	16 S 28 P F 1 (ELE) 32 S 28 P F 1 (ELE)	F41ILL F41ILL	31 31	0.5 (DCC 8736 SW 8736	4,33		200732x1 200732x1	15	0.2	OCC SW/	8,736 8,736)	2,236 0.3 1.473 0.5	\$ 331.45 \$ 662.90	¢ _;0_00 ¢0	7.0	7.0
	Computer Control Room	4 1T 32 R F 2 (ELÉ)	F42LL	60	0.2	SW 8736	2,09	7 4 4 ft LED Tube	200732x2	30	0.0	SW	8,736	,	I,048 0.1	\$ 155.37	\$ 934.80 \$0	6.0	6.0
	Storage Electric Generator Room	2 1T 32 R F 2 (ELE) 2 1T 32 R F 2 (ELE)	F42LL F42LL	<u> </u>	0.1	SW 8736 SW 8736	1,04		200732x2 200732x2	30 30	0.1	SW SW	8,736 8,736	524 524	524 0.1 524 0.1	\$ 77.68 \$ 77.68	3 \$ 467.40 \$0 3 \$ 467.40 \$0	6.0 6.0	<u> </u>
	1st Floor Mechanical Room South	4 1T 32 R F 2 (ELE)	F42LL	60	0.2	SW 8736	2,09	7 4 4 ft LED Tube	200732x2	30	0.1	SW	8,736	1,818	1,048 0.1	\$ 155.37	7 \$ 934.80 \$0	6.0	6.0
	Mechanical Room North 2nd Floor Record Storage	4 1T 32 R F 2 (ELE) 40 S 28 P F 1 (ELE)	F42LL F41ILL	<u> </u>	0.2	SW 8736 SW 8736	2,09		200732x2 200732x1	30 15	0.1	SW SW	8,736 8,736	.,	I,048 0.1 5,591 0.6	\$ 155.37 \$ 828.63	¢ 001100 ¢0	<u>6.0</u> 7.0	<u> </u>
	2nd Floor Record Storage	42 S 28 P F 1 (ELE)	F41ILL	31	1.3	SW 8736	11,37	4 42 4 ft LED Tube	200732x1	15	0.6	SW	8,736	0,001	5,871 0.7	\$ 870.06	6,098.40 \$ 0	7.0	7.0
	Elevator Lobby Break Room	17 R 13 C CF 2 (ELE) 12 1T 32 R F 2 (ELE)	CFQ13/2-L F42LL	28 60	0.5	SW 8736 SW 8736	4,15		CFQ13/2-L 200732x2	28 30	0.5	SW	8,736 8,736	4,158 3,145	- 0.0 3,145 0.4	\$ 466.10	\$ - \$0) \$ 2,804.40 \$0	6.0	#DIV/0! 6.0
	Break Room Small Break Room	8 1T 32 R F 2 (ELE) 2 1T 32 R F 2 (ELE)	F42LL	60 60	0.5	SW 8736	4,19		200732x2 200732x2	30	0.2	SW SW	8,736 8,736	2,097 2	2,097 0.2	\$ 310.73	3 \$ 1,869.60 \$0	6.0	6.0
	Small Break Room	2 R 13 C CF 2 (ELÉ)	F42LL CFQ13/2-L	60 28	0.1	SW 8736	48	9 2 R 13 C CF 2 (ELE)	CFQ13/2-L	28	0.1	SW	8,736 8,736	489	524 0.1 - 0.0	\$ 77.68 \$ -	3 \$ 467.40 \$0 \$ - \$0	6.0	6.0 #DIV/0!
	Mechanical Room 3rd Floor Rocord Storage	4 1T 32 R F 2 (ELE) 40 1T 32 R F 2 (ELE)	F42LL F42LL	60	0.2	SW 8736 SW 8736	2,09	7 4 4 ft LED Tube	200732x2 200732x2	30	0.1	SW	8,736 8,736	1,048	1,048 0.1).483 1.2	\$ 155.37 \$ 1552.67	7 \$ 934.80 \$0 7 \$ 9.348.00 \$0	6.0 6.0	6.0
	3rd Floor Rocord Storage	40 1T 32 R F 2 (ELE)	F42LL F42LL	60	2.4	SW 8736	20,96	6 40 4 ft LED Tube	200732x2 200732x2	30	1.2	SW	8,736	-,),483 1.2	\$ 1,553.67 \$ 1,553.67	' \$ 9,348.00 \$0	6.0	6.0
	Elevator Lobby Elevator Lobby	6 S 28 P F 1 (ELE) 10 S 28 P F 1 (ELE)	F41ILL F41ILL	31	0.2	SW 8736 SW 8736	1,62	5 6 4 ft LED Tube 8 10 4 ft LED Tube	200732x1 200732x1	15 15	0.1	SW	8,736 8,736	100	839 0.1 1 398 0.2	\$ 124.29 \$ 207.16	\$ 871.20 \$0 \$ \$ 1.452.00 \$0	7.0	7.0
	Office	1 W 32 C F 4 (ELE)	F44ILL	112	0.1	SW 8736	97	8 1 T 74 R LED	RTLED50	50	0.1	SW	8,736	437	542 0.1	\$ 80.27	7 \$ 236.25 \$0	2.9	2.9
)	Office Office	1 W 32 C F 4 (ELE) 1 W 32 C F 4 (ELE)	F44ILL F44ILL	<u> </u>	0.1	SW 8736 SW 8736	97	B 1 T 74 R LED B 1 T 74 R LED	RTLED50 RTLED50	50 50	0.1	SW SW	8,736 8,736	437 437	542 0.1 542 0.1	\$ 80.27 \$ 80.27	7 \$ 236.25 \$0 7 \$ 236.25 \$0	2.9	2.9
)	Office	1 W 32 C F 4 (ELE)	F44ILL	112	0.1	SW 8736	97	8 1 T 74 R LED	RTLED50	50	0.1	SW	8,736	437	542 0.1	\$ 80.27	\$ 236.25 \$0	2.9	2.9
	1st Floor Office 113A 113B	2 T 32 R F 3 (ELE) 3 1T 32 R F 2 (ELE)	F43ILL/2 F42LL	90 60	0.2 0	DCC 8736 DCC 8736	1,57		RTLED38 200732x2	38 30	0.1	000 000	8,736 8,736	664 786	909 0.1 786 0.1	\$ 134.65 \$ 116.53		3.5	3.5
	114	4 1T 32 R F 2 (ELE)	F42LL	60	÷.=	DCC 8736	2,09	7 4 4 ft LED Tube	200732x2	30	0.1	OCC	8,736	1,048	1,048 0.1	\$ 155.37	φ ee 1:00 φe	6.0	6.0
	<u>116</u> 117	2 1T 32 R F 2 (ELE) 2 1T 32 R F 2 (ELE)	F42LL F42LL	<u> </u>		DCC 8736 DCC 8736	1,04		200732x2 200732x2	30 30	0.1	000 000	8,736 8,736	<u> </u>	524 0.1 524 0.1	\$ 77.68 \$ 77.68	3 \$ 467.40 \$0 3 \$ 467.40 \$0	6.0 6.0	6.0
	119	4 1T 32 R F 2 (ELE)	F42LL	60		DCC 8736	2,09	7 4 4 ft LED Tube	200732x2	30	0.1	000	8,736	1,048	1,048 0.1	\$ 155.37	Y 934.80 \$0 X 407.40 \$0	6.0	6.0
	120	2 1T 32 R F 2 (ELE) 2 1T 32 R F 2 (ELE)	F42LL F42LL	<u> </u>	0.1	DCC 8736 DCC 8736	1,04	8 2 4 ft LED Tube 8 2 4 ft LED Tube	200732x2 200732x2	30 30	0.1	0000 0000	8,736 8,736	524	524 0.1 524 0.1	\$ 77.68 \$ 77.68	3 \$ 467.40 \$0 3 \$ 467.40 \$0	<u> </u>	6.0
	122	2 1T 32 R F 2 (ELE) 2 1T 32 R F 2 (ELE)	F42LL	60	÷	DCC 8736	1,04		200732x2	30	0.1	000	8,736	524	524 0.1	\$ 77.68		6.0	6.0
	123	4 1T 32 R F 2 (ELE)	F42LL F42LL	60 60		DCC 8736 DCC 8736	1,04		200732x2 200732x2	30	0.1	0000 0000	8,736 8,736	1,048	1,048 0.1	\$ 155.37	3 \$ 467.40 \$0 7 \$ 934.80 \$0	6.0 6.0	6.0
	125	2 1T 32 R F 2 (ELE) 3 1T 32 R F 2 (ELE)	F42LL F42LL	60		DCC 8736	1,04		200732x2	30	0.1	000	8,736	524	524 0.1 786 0.1	\$ 77.68 \$ 116.53	3 \$ 467.40 \$0 3 \$ 701.10 \$0	6.0	6.0
	135	9 2T 32 R F 2 (ELE)	FU2LL	60 60	0	DCC 8736 DCC 8736	4,71		200732x2 2RTLED	25	0.1	0000	8,736 8,736	1,966	2,752 0.3	\$ 407.84		6.0 4.5	4.5
	136 106 Womens Room	8 2T 32 R F 2 (u) (ELE) 3 1T 32 R F 2 (ELE)	FU2LL F42LL	60 60		DCC 8736 DCC 8736	4,19		2RTLED 200732x2	25 30	0.2	000 000	8,736 8,736	1,747 2	2,446 0.3	\$ 362.52 \$ 116.53	· · · · · · · · · · · · · · · · · · ·	4.5	4.5
	107 Men's Room	3 1T 32 R F 2 (ELE)	F42LL	60		DCC 8736	1,57	2 3 4 ft LED Tube	200732x2 200732x2	30	0.1	000	8,736	786	786 0.1	\$ 116.53 \$ 116.53		6.0	6.0
	102 Stair 110	2 1T 32 R F 2 (ELE) 2 1T 32 R F 2 (ELE)	F42LL F42LL	<u> </u>	0.1 (DCC 8736 DCC 8736	1,04	8 2 4 ft LED Tube 8 2 4 ft LED Tube	200732x2 200732x2	30	0.1	000 000	8,736 8,736	<u>524</u> 524	524 0.1 524 0.1	\$ 77.68 \$ 77.68	3 \$ 467.40 \$0 3 \$ 467.40 \$0	<u> </u>	6.0
	137	1 1T 32 R F 2 (ELE)	F42LL	60	0.1 (DCC 8736	52	4 1 4 ft LED Tube	200732x2	30	0.0	000	8,736	262	262 0.0	\$ 38.84	\$ 233.70 \$0	6.0	6.0
	<u>138</u> 139	2 1T 32 R F 2 (ELE) 2 1T 32 R F 2 (ELE)	F42LL F42LL	<u> </u>		DCC 8736 DCC 8736	1,04		200732x2 200732x2	30 30	0.1	000 000	8,736 8,736	524 524	524 0.1 524 0.1	\$ 77.68 \$ 77.68	3 \$ 467.40 \$0 3 \$ 467.40 \$0	<u>6.0</u> 6.0	6.0
	140	3 1T 32 R F 2 (ELE)	F42LL	60	0.2 (DCC 8736	1,57	2 3 4 ft LED Tube	200732x2	30	0.1	000	8,736	786	786 0.1	\$ 116.53	3 \$ 701.10 \$0	6.0	6.0
	<u> </u>	2 1T 32 R F 2 (ELE) 6 R 13 C CF 2 (ELE)	F42LL CFQ13/2-L	<u> </u>		DCC 8736 DCC 8736	1,04		200732x2 CFQ13/2-L	30 28	0.1	000 000	8,736 8,736	<u> </u>	524 0.1 - 0.0	\$ 77.68 \$ -	3 \$ 467.40 \$0 \$ - \$0	6.0	6.0 #DIV/0!
	142	4 1T 32 R F 2 (ELE)	F42LL	60		DCC 8736	2,09	7 4 4 ft LED Tube	200732x2	30	0.1	000	8,736	1,048	1,048 0.1	\$ 155.37	φ 554.00 φ0	6.0	6.0
	143 144	2 1T 32 R F 2 (ELE) 2 1T 32 R F 2 (ELE)	F42LL F42LL	<u> </u>	0.1 0.1 0.1	DCC 8736 DCC 8736	1,04 1,04	8 2 4 ft LED Tube 8 2 4 ft LED Tube	200732x2 200732x2	30 30	0.1	000	8,736 8,736	524	524 0.1 524 0.1	\$ 77.68	3 \$ 467.40 \$0 3 \$ 467.40 \$0	6.0 6.0	6.0
	145	2 1T 32 R F 2 (ELE) 2 1T 32 R F 2 (ELE)	F42LL	60 60	••••	DCC 8736 DCC 8736	1,04		200732x2 200732x2	30	0.1	000	8,736 8,736	524	524 0.1 524 0.1	\$ 77.68 \$ 77.68	¢ 101110 ¢0	6.0	6.0
	146	4 1T 32 R F 2 (ELE)	F42LL F42LL	60		DCC 8736 DCC 8736	1,04	Z 4 If LED Tube 7 4 4 ft LED Tube	200732x2 200732x2	30	0.1	000 000	8,736	1,048	I,048 0.1	\$ 155.37	3 5 407.40 \$0 7 \$ 934.80 \$0	6.0 6.0	6.0
	148 149	2 1T 32 R F 2 (ELE) 2 1T 32 R F 2 (ELE)	F42LL F42LL	60 60		DCC 8736 DCC 8736	1,04		200732x2 200732x2	30	0.1	00C 000	8,736 8,736	524	524 0.1 524 0.1	\$ 77.68 \$ 77.68	3 \$ 467.40 \$0 3 \$ 467.40 \$0	6.0 6.0	6.0
	4th Floor Cubicles	45 1T 32 R F 2 (ELE)	F42LL	60	2.7 (DCC 8736	23,58	7 45 4 ft LED Tube	200732x2	30	1.4	OCC	8,736	,	1,794 1.4	\$ 1,747.88	\$ 10,516.50 \$0	6.0	6.0
	414 415	4 1T 32 R F 2 (ELE) 3 1T 32 R F 2 (ELE)	F42LL F42LL	60 60		DCC 8736 DCC 8736	2,09		200732x2 200732x2	30 30	0.1	000 000	8,736 8,736	1,048 · · · · · · · · · · · · · · · · · · ·	1,048 0.1 786 0.1	\$ 155.37 \$ 116.53	¥ 00.000 ¥0	6.0 6.0	6.0 6.0
	416	4 1T 32 R F 2 (ELE)	F42LL	60	0.2	DCC 8736	2,09	7 4 4 ft LED Tube	200732x2	30	0.1	000	8,736	1,048	1,048 0.1	\$ 155.37	\$ 934.80 \$0	6.0	6.0
	417 411 Women's Room	2 1T 32 R F 2 (ELE) 2 R 13 C CF 2 (ELE)	F42LL CFQ13/2-L	60 28		DCC 8736 DCC 8736	1,04		<u>200732x2</u> CFQ13/2-L	30 28	0.1	000 000	8,736 8,736	<u> </u>	524 0.1 - 0.0	\$ 77.68 \$ -	3 \$ 467.40 \$0 \$ - \$0	6.0	6.0 #DIV/0
	409 407	10 1T 32 R F 2 (ELE)	F42LL	60	0.6 0	DCC 8736	5,24	2 10 4 ft LED Tube	200732x2	30	0.3	000	8,736	2,621 2	2,621 0.3	\$ 388.42	2 \$ 2,337.00 \$0	6.0	6.0
	407 408	2 1T 32 R F 2 (ELE) 1 1T 32 R F 2 (ELE)	F42LL F42LL	60 60		DCC 8736 DCC 8736	1,04	4 1 4 ft LED Tube	200732x2 200732x2	30	0.1	000 000	8,736 8,736	<u> </u>	524 0.1 262 0.0	\$ 77.68 \$ 38.84	3 \$ 467.40 \$0 4 \$ 233.70 \$0	6.0 6.0	6.0 6.0
	408	3 R 13 C CF 2 (ELE)	CFQ13/2-L	28	0.1 (DCC 8736	73	4 3 R 13 C CF 2 (ELE)	CFQ13/2-L	28	0.1	000	8,736	734	- 0.0	\$ -	\$ - \$0 \$ \$0	-	#DIV/0
	406 404 Men's Room	4 T 54 W F 3 (ELE) (T-5) 3 R 13 C CF 2 (ELE)	F43GHL CFQ13/2-L	177 28		DCC 6000 DCC 8736	4,24	8 4 T 54 W F 3 (ELE) (T-5) 4 3 R 13 C CF 2 (ELE)	F43GHL CFQ13/2-L	28	0.7	000 000	6,000 8,736	4,248 734	- 0.0	\$- \$-	\$ - \$0 \$ - \$0		#DIV/0
	419	1 2T 32 R F 2 (u) (ELE)	FU2LL	60	0.1 (DCC 8736	52	4 1 2T XX R LED	2RTLED	25	0.0	OCC	8,736	218	306 0.0	\$ 45.32	φ _02.00 φ0	4.5	4.5
	420	1 1T 32 R F 2 (ELE) 2 1T 32 R F 2 (ELE)	F42LL F42LL	60 60		DCC 8736 DCC 8736	52- 1,04	4 1 4 ft LED Tube 8 2 4 ft LED Tube	200732x2 200732x2	30	0.0	000 000	8,736 8,736	<u> </u>	524 0.1	\$ 38.84 \$ 77.68		6.0 6.0	6.0
	424 425	4 1T 32 R F 2 (ELE)	F42LL	60 60		DCC 8736	2,09	7 4 4 ft LED Tube	200732x2	30	0.1	00CC 00C	8,736 8,736	1,048	1,048 0.1	\$ 155.37 \$ 77.68	7 \$ 934.80 \$0	6.0	6.0
	426	2 1T 32 R F 2 (ELE) 2 1T 32 R F 2 (ELE)	F42LL F42LL	60 60	0.1	DCC 8736 DCC 8736	1,04 1,04		200732x2 200732x2	30	0.1	000	8,736 8,736	524	524 0.1	ψ 77.68 \$ 77.68	3 \$ 467.40 \$0 3 \$ 467.40 \$0	6.0 6.0	6.0
	427 428	2 1T 32 R F 2 (ELE) 4 1T 32 R F 2 (ELE)	F42LL F42LL	60 60	-	DCC 8736 DCC 8736	1,04		200732x2 200732x2	30	0.1	00C 000	8,736 8,736	524	524 0.1 1.048 0.1	\$ 77.68 \$ 155.37	3 \$ 467.40 \$0 7 \$ 934.80 \$0	6.0 6.0	6.0
	428 429	6 1T 32 R F 2 (ELE)	F42LL F42LL	60 60	0.4 (DCC 8736	2,09	5 6 4 ft LED Tube	200732x2	30	0.1	000	8,736	7	1,048 0.1 1,572 0.2	\$ 155.37 \$ 233.05		6.0	6.0
	430 433	6 1T 32 R F 2 (ELE) 3 1T 32 R F 2 (ELE)	F42LL F42LL	60 60		DCC 8736 DCC 8736	3,14	5 6 4 ft LED Tube	200732x2 200732x2	30	0.2	00C 000	8,736 8,736	1,572	1,572 0.2 786 0 1	\$ 233.05 \$ 116.55	• • • • • • • •	6.0 6.0	6.0
	435	8 1T 32 R F 2 (ELE)	F42LL	60	0.2	DCC 8736 DCC 8736	4,19	3 8 4 ft LED Tube	200732x2	30	0.1	000	8,736	2,097	2,097 0.2	\$ 310.73	3 \$ 701.10 \$0 3 \$ 1,869.60 \$0	6.0	6.0
	Elevator Lobby	14 R 13 C CF 2 (ELÉ)	CFQ13/2-L	28	0.4 (DCC 8736	3,42	5 14 R 13 C CF 2 (ELE)	CFQ13/2-L	28	0.4	000	8,736	3,425	- 0.0	\$	\$ - \$0		#DIV/0!
Total		629			30.5		264,301	629		2,726	16.0			137,926 126,375	14.5	\$18,730	\$114,708 \$0		

Energy Audit of Essex County - Leroy Smith Public Safety Complex CHA Project No.29142 ECM-L2 Install Occupancy Sensors

		EXISTING CONDITIONS					_	RETROFIT C	ONDITIONS				COST & SAVING				
														S ANAL 1515	NJ Smart Start	Simple Payback	
					Watts per						Annual kWh				Lighting	With Out	
	Area Description	No. of Fixtures	Standard Fixture Code	Fixture Code	Fixture	kW/Space	kW/Space	Retrofit Control	Annual Hours	Annual kWh	Saved	Annual kW Saved	Annual \$ Saved	Retrofit Cost	Incentive	Incentive	Simple Payback
Field Code	Unique description of the location - Room number/Room		Lighting Fixture Code	Code from Table of Standard	Value from	(Watts/Fixt) * (Fixt	(Watts/Fixt) *	Retrofit control		(kW/space) *	(Original Annual	· •	(kW Saved) *	Cost for		Length of time	Length of time for
	name: Floor number (if applicable)	before the retrofit		Fixture Wattages	Table of	No.)	(Number of Fixtures)		annual hours for	r /	kWh) - (Retrofit Annual kWh)	kW) - (Retrofit	(\$/kWh)	renovations to		for renovations	renovations cost to
					Standard Fixture Wattages		Fixtures)		the usage group		Annual Kwn)	Annual kW)		lighting system		cost to be recovered	be recovered
					Wattageo												
32LED	Basement Mechanical Room	15	1T 32 R F 2 (ELE)	F42LL	60	0.9	0.9	NONE		7,862.4	0.0		\$0.00		\$0.00		#DIV/0!
32LED	Sprinkler Room Electric Room	4	1T 32 R F 2 (ELE)	F42LL	60	0.2	0.2	NONE		2,096.6	0.0		\$0.00		\$0.00		#DIV/0!
32LED 20LED	Court Storage	22	1T 32 R F 2 (ELE) S 28 P F 1 (ELE)	F42LL F41ILL	60	0.4	0.4	00-0 00-0		3,145.0 4,766.4	1,191.6		\$0.00 \$170.40		\$35.00 \$35.00	1.6	#DIV/0! 1.4
20LED	Court Storage	16	S 28 P F 1 (ELE)	F41ILL	31	0.5	0.7	C-0CC		3.466.4	866.6		\$123.93		\$35.00	2.2	1.4
20LED	Court Storage	24	S 28 P F 1 (ELE)	F41ILL	31	0.7	0.7	C-0CC	6988.8	5,199.7	1,299.9	0.0	\$185.89		\$35.00	1.5	1.3
20LED	Court Storage	10	S 28 P F 1 (ELE)	F41ILL	31	0.3	0.3	00-0		2,166.5	541.6		\$77.45		\$35.00	3.5	3.0
20LED	Server Room	4	S 28 P F 1 (ELE)	F41ILL	31	0.1	0.1	000-0		866.6	216.7		\$30.98		\$35.00	8.7	7.6
20LED	Office Hall	16	S 28 P F 1 (ELE) S 28 P F 1 (ELE)	F41ILL F41ILL	31	0.1	0.1	230-3 230-3		433.3 4,333.1	108.3		\$15.49 \$0.00	7	\$35.00 \$35.00	17.4	15.2 #DIV/0!
20LED 20LED	Warehouse Storage	32	S 28 P F 1 (ELE) S 28 P F 1 (ELE)	F41ILL F41ILL	31	0.5	0.5	000-0 00-0 00-0		6,932.9	1,733.2		\$0.00 \$247.85		\$35.00	1.1	#DIV/0! 0.9
32LED	Computer Control Room	4	1T 32 R F 2 (ELE)	F42LL	60	0.2	0.2	C-OCC		1,677.3	419.3		\$59.96		\$35.00	4.5	3.9
32LED	Storage	2	1T 32 R F 2 (ELE)	F42LL	60	0.1	0.1	C-0CC		838.7	209.7		\$29.98	\$270.00	\$35.00	9.0	7.8
32LED	Electric Generator Room	2	1T 32 R F 2 (ELE)	F42LL	60	0.1	0.1	000-0		838.7	209.7		\$29.98		\$35.00	9.0	7.8
32LED	1st Floor Mechanical Room South	4	1T 32 R F 2 (ELE)	F42LL	60	0.2	0.2	0.000		2,096.6	0.0		\$0.00		\$35.00		#DIV/0!
32LED 20LED	Mechanical Room North 2nd Floor Record Storage	4 40	1T 32 R F 2 (ELE) S 28 P F 1 (ELE)	F42LL F41ILL	60	0.2	0.2	C-OCC NONE		2,096.6 10.832.6	0.0		\$0.00 \$0.00		\$35.00 \$0.00		#DIV/0! #DIV/0!
20LED	2nd Floor Record Storage	40	S 28 P F 1 (ELE)	F41ILL	31	1.3	1.2	C-OCC		9,099.4	2,274.9	0.0	\$325.30	+ • • • •	\$35.00	0.8	0.7
25	Elevator Lobby	17	R 13 C CF 2 (ELE)	CFQ13/2-L	28	0.5	0.5	C-0CC		4,158.3	0.0	0.0	\$0.00		\$35.00		#DIV/0!
32LED	Break Room	12	1T 32 R F 2 (ELE)	F42LL	60	0.7	0.7	NONE	8736	6,289.9	0.0	0.0	\$0.00	\$0.00	\$0.00		#DIV/0!
32LED	Break Room	8	1T 32 R F 2 (ELE)	F42LL	60	0.5	0.5	NONE		4,193.3	0.0		\$0.00	1	\$0.00	<u> </u>	#DIV/0!
32LED	Small Break Room Small Break Room	2	1T 32 R F 2 (ELE) R 13 C CF 2 (ELE)	F42LL CFQ13/2-L	60	0.1	0.1	220-2	8736 8736	1,048.3 489.2	0.0		\$0.00		\$35.00 \$35.00	<u> </u>	#DIV/0! #DIV/0!
25 32LED	Mechanical Room	4	IT 32 R F 2 (ELE)	F42LL	28	0.1	0.1	C-OCC C-OCC		489.2	0.0		\$0.00 \$0.00		\$35.00 \$35.00		#DIV/0! #DIV/0!
32LED	3rd Floor Rocord Storage	40	1T 32 R F 2 (ELE)	F42LL	60	2.4	2.4	C-OCC		20,966.4	0.0		\$0.00		\$35.00		#DIV/0!
32LED	3rd Floor Rocord Storage	40	1T 32 R F 2 (ELE)	F42LL	60	2.4	2.4	C-0CC	8736	20,966.4	0.0	0.0	\$0.00	\$270.00	\$35.00		#DIV/0!
20LED	Elevator Lobby	6	S 28 P F 1 (ELE)	F41ILL	31	0.2	0.2	000-0		1,624.9	0.0		\$0.00		\$35.00		#DIV/0!
20LED	Elevator Lobby	10	S 28 P F 1 (ELE)	F41ILL	31	0.3	0.3	NONE		2,708.2	0.0		\$0.00		\$0.00	0.0	#DIV/0!
196LED 196LED	Office Office	1	W 32 C F 4 (ELE) W 32 C F 4 (ELE)	F44ILL F44ILL	<u> </u>	0.1	0.1	C-OCC NONE		782.7 978.4	195.7 0.0		\$27.98 \$0.00	1	\$35.00 \$0.00	9.6	8.4 #DIV/0!
196LED	Office	1	W 32 C F 4 (ELE)	F44ILL	112	0.1	0.1	C-OCC		782.7	195.7		\$27.98		\$35.00	9.6	8.4
196LED	Office	1	W 32 C F 4 (ELE)	F44ILL	112	0.1	0.1	C-0CC		782.7	195.7		\$27.98		\$35.00	9.6	8.4
35LED	1st Floor Office 113A	2	T 32 R F 3 (ELE)	F43ILL/2	90	0.2	0.2	C-0CC		1,258.0	314.5		\$44.97		\$35.00	6.0	5.2
32LED	113B	3	1T 32 R F 2 (ELE)	F42LL	60	0.2	0.2	C-0CC		1,258.0	314.5		\$44.97		\$35.00	6.0	5.2
32LED	<u> </u>	4	1T 32 R F 2 (ELE)	F42LL F42LL	60	0.2	0.2	00-0 00-0		2,096.6 1,048.3	0.0		\$0.00 \$0.00	1	\$35.00 \$35.00		#DIV/0! #DIV/0!
32LED 32LED	117	2	1T 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL F42LL	60	0.1	0.1	00-0 00-0		838.7	209.7		\$29.98		\$35.00	9.0	#DIV/0! 7.8
32LED 32LED	119	4	1T 32 R F 2 (ELE)	F42LL	60	0.2	0.1	C-OCC		1,677.3	419.3		\$59.96	\$270.00	\$35.00	4.5	3.9
32LED	120	2	1T 32 R F 2 (ELE)	F42LL	60	0.1	0.1	C-0CC	6988.8	838.7	209.7	0.0	\$29.98	\$270.00	\$35.00	9.0	7.8
32LED	121	2	1T 32 R F 2 (ELE)	F42LL	60	0.1	0.1	C-0CC		838.7	209.7		\$29.98		\$35.00	9.0	7.8
32LED	122	2	1T 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL	60	0.1	0.1	00-0 00-0		1,048.3 838.7	0.0 209.7		\$0.00		\$35.00	0.0	#DIV/0!
32LED 32LED	<u> </u>	<u> </u>	1T 32 R F 2 (ELE)	F42LL F42LL	60	0.1	0.1	NONE		2,096.6	0.0		\$29.98 \$0.00		\$35.00 \$0.00	9.0	7.8 #DIV/0!
32LED	125	2	1T 32 R F 2 (ELE)	F42LL	60	0.1	0.1	C-OCC		1,048.3	0.0		\$0.00		\$35.00		#DIV/0!
32LED	126	3	1T 32 R F 2 (ELE)	F42LL	60	0.2	0.2	C-0CC	8736	1,572.5	0.0	0.0	\$0.00	\$270.00	\$35.00		#DIV/0!
5LED	135	9	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.5	0.5	C-0CC		4,717.4	0.0		\$0.00		\$35.00		#DIV/0!
5LED	136 100 Wamana Daam	8	2T 32 R F 2 (u) (ELE)	FU2LL	60	0.5	0.5	0.000		4,193.3	0.0		\$0.00		\$35.00	0.0	#DIV/0!
32LED 32LED	106 Womens Room 107 Men's Room	3	1T 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL F42LL	<u>60</u>	0.2	0.2	C-OCC C-OCC		1,258.0 1,258.0	314.5 314.5		\$44.97 \$44.97		\$35.00 \$35.00	6.0 6.0	5.2 5.2
32LED	102 Stair	2	1T 32 R F 2 (ELE)	F42LL	60	0.1	0.2	C-OCC		1,048.3	0.0		\$0.00		\$35.00	0.0	#DIV/0!
32LED	110	2	1T 32 R F 2 (ELE)	F42LL	60	0.1	0.1	C-0CC	6988.8	838.7	209.7		\$29.98	\$270.00	\$35.00	9.0	7.8
32LED	137	1	1T 32 R F 2 (ELE)	F42LL	60	0.1	0.1	000-0		419.3	104.8		\$14.99		\$35.00	18.0	15.7
32LED	138	2	1T 32 R F 2 (ELE)	F42LL	60	0.1	0.1	0.000		1,048.3	0.0 209.7		\$0.00 \$29.98	1	\$35.00	0.0	#DIV/0!
32LED 32LED	<u>139</u> 140	2	1T 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL F42LL	<u> </u>	0.1	0.1	00-0 00-0		838.7 1,258.0	314.5		\$29.90 \$44.97		\$35.00 \$35.00	9.0 6.0	7.8 5.2
32LED	141	2	1T 32 R F 2 (ELE)	F42LL	60	0.1	0.1	C-OCC		838.7	209.7		\$29.98		\$35.00	9.0	7.8
25	142	6	R 13 C CF 2 (ELÉ)	CFQ13/2-L	28	0.2	0.2	C-0CC	6988.8	1,174.1	293.5	0.0	\$41.97	\$270.00	\$35.00	6.4	5.6
32LED	142	4	1T 32 R F 2 (ELE)	F42LL	60	0.2	0.2	C-0CC		1,677.3	419.3		\$59.96		\$35.00	4.5	3.9
32LED 32LED	143 144	2	1T 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL F42LL	60	0.1	0.1	00-0 00-0		1,048.3 838.7	0.0 209.7		\$0.00 \$29.98	1	\$35.00 \$35.00	9.0	#DIV/0! 7.8
32LED 32LED	144 145	2	11 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL F42LL	60	0.1	0.1	000-0 00-0		838.7	209.7		\$29.98 \$29.98		\$35.00 \$35.00	9.0	7.8
32LED	146	2	1T 32 R F 2 (ELE)	F42LL	60	0.1	0.1	C-0CC		838.7	209.7		\$29.98		\$35.00	9.0	7.8
32LED	147	4	1T 32 R F 2 (ELE)	F42LL	60	0.2	0.2	C-0CC	6988.8	1,677.3	419.3	0.0	\$59.96	\$270.00	\$35.00	4.5	3.9
32LED	148	2	1T 32 R F 2 (ELE)	F42LL	60	0.1	0.1	0.000		838.7	209.7		\$29.98	\$270.00	\$35.00	9.0	7.8
32LED	149 4th Floor Cubicles	45	1T 32 R F 2 (ELE)	F42LL	<u> </u>	0.1	0.1	230-3		838.7	209.7 4,717.4		\$29.98 \$674.59		\$35.00 \$35.00	9.0 0.4	7.8
32LED 32LED	4th Floor Cubicles 414	40	1T 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL F42LL	60	0.2	2.7	00-0 00-0		18,869.8 1,677.3	4,717.4		\$674.59 \$59.96		\$35.00 \$35.00	0.4 4.5	0.3 3.9
32LED	415	3	1T 32 R F 2 (ELE)	F42LL	60	0.2	0.2	C-000		1,258.0	314.5		\$44.97		\$35.00	6.0	5.2
32LED	416	4	1T 32 R F 2 (ELE)	F42LL	60	0.2	0.2	C-0CC	6988.8	1,677.3	419.3	0.0	\$59.96	\$270.00	\$35.00	4.5	3.9
32LED	417	2	1T 32 R F 2 (ELE)	F42LL	60	0.1	0.1	0.000		838.7	209.7		\$29.98		\$35.00	9.0	7.8
25 221 ED	411 Women's Room		R 13 C CF 2 (ELE)	CFQ13/2-L	28	0.1	0.1	<u> </u>		391.4	97.8		\$13.99		\$35.00	19.3	16.8 #DIV//01
32LED 32LED	<u>409</u> 407	10	1T 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL F42LL	60	0.6	0.6	C-OCC C-OCC		5,241.6 838.7	0.0 209.7	0.0	\$0.00 \$29.98	\$270.00 \$270.00	\$35.00 \$35.00	9.0	#DIV/0! 7.8
32LED 32LED	407	1	1T 32 R F 2 (ELE)	F42LL	60	0.1	0.1	0000		419.3	104.8		\$14.99		\$35.00	18.0	15.7
25	408	3	R 13 C CF 2 (ELE)	CFQ13/2-L	28	0.1	0.1	C-0CC	8736	733.8	0.0	0.0	\$0.00	\$270.00	\$35.00		#DIV/0!
250	406	4	T 54 W F 3 (ELE) (T-5)	F43GHL	177	0.7	0.7	C-0CC	4800	3,398.4	849.6	0.0	\$121.49	\$270.00	\$35.00	2.2	1.9
25	404 Men's Room	3	R 13 C CF 2 (ELE)	CFQ13/2-L	28	0.1	0.1	NONE		733.8	0.0	1	\$0.00		\$0.00		#DIV/0!
5LED 32LED	<u>419</u> 420	1	2T 32 R F 2 (u) (ELE) 1T 32 R F 2 (ELE)	FU2LL F42LL	60	0.1	0.1	00-0 00-0		419.3 419.3	104.8 104.8		\$14.99 \$14.99		\$35.00 \$35.00	18.0 18.0	15.7 15.7
32LED 32LED	420	2	1T 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL F42LL	60	0.1	0.1	000-0 00-0		419.3 838.7	209.7		\$14.99 \$29.98		\$35.00 \$35.00	9.0	7.8
32LED	424	4	1T 32 R F 2 (ELE)	F42LL	60	0.2	0.1	C-000		1,677.3	419.3		\$59.96		\$35.00	4.5	3.9
32LED	425	2	1T 32 R F 2 (ELE)	F42LL	60	0.1	0.1	C-0CC	6988.8	838.7	209.7	0.0	\$29.98	\$270.00	\$35.00	9.0	7.8
32LED	426	2	1T 32 R F 2 (ELE)	F42LL	60	0.1	0.1	000-0		838.7	209.7		\$29.98		\$35.00	9.0	7.8
32LED	427	2	1T 32 R F 2 (ELE)	F42LL F42LL	60	0.1	0.1	230-3		838.7	209.7		\$29.98 \$59.96		\$35.00 \$35.00	9.0	7.8
32LED	428	4	1T 32 R F 2 (ELE)	F42LL	60	0.2	0.2	C-0CC	6988.8	1,677.3	419.3	U.U	1409.90	\$270.00	\$35.00	4.5	3.9

Energy Audit of Essex County - Leroy Smith Public Safety Complex CHA Project No.29142 ECM-L2 Install Occupancy Sensors

			EXIS		RETROFIT C	ONDITIONS		COST & SAVINGS ANALYSIS									
	Area Description														NJ Smart Start	Simple Payback	
		No. of Fixtures	Standard Fixture Code	Fixture Code	Watts per Fixture	kW/Space	kW/Space	Retrofit Control	Annual Hours	Annual kWh	Annual kWh Saved	Annual kW Saved	Annual \$ Saved	Retrofit Cost	Lighting Incentive	With Out Incentive	Simple Payback
Field Code	Unique description of the location - Room number/Room name: Floor number (if applicable)	No. of fixtures before the retrofit	Lighting Fixture Code	Code from Table of Standard Fixture Wattages	Value from Table of Standard Fixture Wattages	(Watts/Fixt) * (Fixt No.)	(Watts/Fixt) * (Number of Fixtures)		Estimated annual hours for the usage group	r í	(Original Annual kWh) - (Retrofit Annual kWh)	(Original Annual		Cost for renovations to lighting system		Length of time for renovations cost to be recovered	Length of time for renovations cost to be recovered
32LED	429	6	1T 32 R F 2 (ELE)	F42LL	60	0.4	0.4	C-OCC	6988.8	2,516.0	629.0	0.0	\$89.95	\$270.00	\$35.00	3.0	2.6
32LED	430	6	1T 32 R F 2 (ELE)	F42LL	60	0.4	0.4	C-0CC	6988.8	2,516.0	629.0	0.0	\$89.95	\$270.00	\$35.00	3.0	2.6
32LED	433	3	1T 32 R F 2 (ELE)	F42LL	60	0.2	0.2	C-0CC	6988.8	1,258.0	314.5	0.0	\$44.97	\$270.00	\$35.00	6.0	5.2
32LED	435	8	1T 32 R F 2 (ELE)	F42LL	60	0.5	0.5	C-0CC	6988.8	3,354.6	838.7	0.0	\$119.93	\$270.00	\$35.00	2.3	2.0
25	Elevator Lobby	14	R 13 C CF 2 (ELE)	CFQ13/2-L	28	0.4	0.4	C-0CC	8736	3,424.5	0.0	0.0		\$270.00	\$35.00		#DIV/0!
ī	Total	629				30.5	30.5			237,257.63	27,043.62	0.0	3867.2	21870.0	2835.0		
-					-	-	-	-	-	Deman	nd Savings		0.0	\$0			

Energy Audit of Essex County - Leroy Smith Public Safety Complex CHA Project No.29142 ECM-L3 Lighting Replacements with Occupancy Sensors

				EXISTING CONI	DITIONS							RETROFIT	CONDITIONS						COST & SAVI	NGS ANALYSIS	t Start Simple Payb	ack
	Anna Description	No. of Fistures	Oten dend Fintens Ocide	Findance On de	Watts per				A	Number of Fisters	Oten dend Fintune Oe de	Finture Onde	Watts per		Retrofit			ial kWh		Ligh	ing With Out	: · · · ·
de U	Area Description Unique description of the location - Room number/Room	No. of Fixtures No. of fixtures	Standard Fixture Code Lighting Fixture Code	Fixture Code Code from Table of Standard	Fixture Value from	kW/Space (Watts/Fixt) * (Fixt	Exist Control Pre-inst.	I Annual Hours Estimated daily	Annual kWh (kW/space) *	Number of Fixtures No. of fixtures after	Standard Fixture Code Lighting Fixture Code	Fixture Code Code from Table of	Fixture Value from	kW/Space (Watts/Fixt) *	Control Retrofit cont	Annual Hours Ann rol Estimated (kW/s		I Annual (Original Annual	d Annual \$ Saved (kWh Saved) *	Retrofit Cost Ince Cost for Prescrip	ve Length of tim	ne Length of time
	name: Floor number (if applicable)	before the retrofit		Fixture Wattages	Table of Standard	No.)	control device	e hours for the usage group	(Annual Hours)	the retrofit		Standard Fixture Wattages	Table of Standard	(Number of Fixtures)	device	annual hours (Ann for the usage Hour		Retrofit KW) - (Retrofit kWh) Annual kW)	(\$/kWh)	renovations to Lighting lighting system Measure	for renovatio	ons renovations cos be recovered
					Fixture							managoo	Fixture	i ixtu ooj		group	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,				recovered	
	Basement Mechanical Room	15	1T 32 R F 2 (ELE)	F42LL	Wattages 6	0.9	SW	873	6 7,862		4 ft LED Tube	200732x2	Wattages 30	0.5	NONE	8,736	3,931	3,931 0.5	\$ 582.63	\$ 3,505.50 \$	- 6.0	6.0
	Sprinkler Room Electric Room	4 6	1T 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL F42LL	6	0 0.2	SW SW	873	6 2,097 6 3.145		4 ft LED Tube 4 ft LED Tube	200732x2 200732x2	<u> </u>	0.1	NONE C-OCC	8,736 8,736	1,048 1.572	1,048 0.1 1.572 0.2	\$ 155.37 \$ 233.05	÷ •••••	- 6.0 35 7.2	6.0
	Court Storage		S 28 P F 1 (ELE)	F41ILL	3	1 0.7	000	873	6 5,958	22	4 ft LED Tube	200732x1	15	0.3	C-0CC	6,989	2,306	3,652 0.4	\$ 538.19	\$ 3,464.40 \$	35 6.4	6.4
	Court Storage Court Storage	<u> </u>	S 28 P F 1 (ELE) S 28 P F 1 (ELE)	F41ILL F41ILL	3	1 0.5 1 0.7	000 000	873 873	6 4,333 6 6,500		4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	<u>15</u> 15	0.2	C-OCC C-OCC	<u> </u>	1,677 2,516	2,656 0.3 3,984 0.4	\$ 391.41 \$ 587.12		<u>35 6.6</u> 35 6.4	<u> </u>
)	Court Storage Server Room	10	S 28 P F 1 (ELE) S 28 P F 1 (ELE)	F41ILL F41ILL	3	1 0.3	000 000	873	6 2,708 6 1.083	10	4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	15 15	0.2	000-0 00-0	6,989	1,048	1,660 0.2 664 0 1	\$ 244.63 \$ 97.85		35 7.0 35 8.7	6.9
)	Office	2	S 28 P F 1 (ELE)	F41ILL	3	1 0.1	000	873	6 542	2	4 ft LED Tube	200732x1	15	0.0	000-0 00-0	6,989	210	332 0.0	\$ 48.93	\$ 560.40 \$	<u> </u>	10.7
	Hall Warehouse Storage	<u> </u>	S 28 P F 1 (ELE) S 28 P F 1 (ELE)	F41ILL F41ILL	3	1 0.5 1 1.0	OCC SW	873	0 1,000		4 ft LED Tube 4 ft LED Tube	200732x1 200732x1	<u> </u>	0.2	230-3 230-3	8,736 6,989	2,097 3.355	2,236 0.3 5.311 0.5	\$ 331.45 \$ 782.83		<u>35 7.8</u> 35 6.3	7.7
)	Computer Control Room	4	1T 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL	6	0.2	SW	873	6 2,097	4	4 ft LED Tube	200732x2	30	0.1	0000	6,989	839	1,258 0.1	\$ 185.35	\$ 1,204.80 \$	35 6.5	6.3
	Storage Electric Generator Room	2	1T 32 R F 2 (ELE)	F42LL F42LL	6	0 0.1 0 0.1	SW SW	873	6 1,048 6 1,048	2	4 ft LED Tube 4 ft LED Tube	200732x2 200732x2	<u> </u>	0.1	C-0CC C-0CC	6,989	419	629 0.1 629 0.1	\$ 92.67 \$ 92.67		35 8.0 35 8.0	7.6
))	1st Floor Mechanical Room South Mechanical Room North	4	1T 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL F42LL	6	0 0.2	SW SW	873	6 2,097 6 2,097		4 ft LED Tube 4 ft LED Tube	200732x2 200732x2	<u> </u>	0.1	000-0 00-0	8,736 8,736	1,048	1,048 0.1 1.048 0.1	\$ 155.37 \$ 155.37	· · · · ·	<u>35 7.8</u> 35 7.8	7.5
)	2nd Floor Record Storage	40	S 28 P F 1 (ÈLE)	F41ILL	3	1 1.2	SW	873	6 10,833	40	4 ft LED Tube	200732x1	15	0.6	NONE		5,242	5,591 0.6	\$ 828.63	\$ 5,808.00 \$	- 7.0	7.0
<u> </u>	2nd Floor Record Storage Elevator Lobby	42	S 28 P F 1 (ELE) R 13 C CF 2 (ELE)	F41ILL CFQ13/2-L	3	1 1.3 8 0.5	SW SW	873	6 11,374 6 4,158		4 ft LED Tube R 13 C CF 2 (ELE)	<u>200732x1</u> CFQ13/2-L	<u> </u>	0.6	C-OCC C-OCC	6,989 8,736	4,403 4,158	<u> </u>	\$ 1,027.46 \$ -	\$ 6,368.40 \$ \$ 270.00 \$	35 6.2 35	6.2
	Break Room Break Room	12	1T 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL	6	0 0.7	SW	873	6 6,290		4 ft LED Tube	200732x2	30	0.4	NONE NONE		3,145	3,145 0.4	\$ 466.10 \$ 210.72		- 6.0	6.0
	Small Break Room	<u> </u>	1T 32 R F 2 (ELE)	F42LL F42LL	6	0 0.5 0 0.1	SW SW	873	6 4,193 6 1,048		4 ft LED Tube 4 ft LED Tube	200732x2 200732x2	30 30	0.2	C-OCC	8,736 8,736	2,097 524	2,097 0.2 524 0.1	\$ 310.73 \$ 77.68		- 6.0 35 9.5	6.0 9.0
	Small Break Room Mechanical Room	2	R 13 C CF 2 (ELE) 1T 32 R F 2 (ELE)	CFQ13/2-L F42LL	2	8 0.1 0 0.2	SW SW	873	6 489 6 2 097	2	R 13 C CF 2 (ELE) 4 ft LED Tube	CFQ13/2-L 200732x2	28	0.1	000-0 00-0	8,736 8,736	489 1.048	- 0.0 1.048 0.1	\$- \$155.37	\$ 270.00 \$ \$ 1,204.80 \$	35 35 7.8	75
	3rd Floor Rocord Storage	40	1T 32 R F 2 (ELE)	F42LL	6	0 2.4	SW	873	6 20,966	40	4 ft LED Tube	200732x2	30	1.2	C-OCC	8,736	10,483	10,483 1.2	\$ 1,553.67	\$ 9,618.00 \$	35 6.2	6.2
D	3rd Floor Rocord Storage Elevator Lobby	<u>40</u> 6	1T 32 R F 2 (ELE) S 28 P F 1 (ELE)	F42LL F41ILL	6 3	0 2.4 1 0.2	SW SW	873 873	6 20,966 6 1,625	6	4 ft LED Tube 4 ft LED Tube	200732x2 200732x1	<u>30</u> 15	1.2 0.1	000-0 00-0	8,736 8,736	10,483 786	10,483 1.2 839 0.1	\$ 1,553.67 \$ 124.29		35 6.2 35 9.2	6.2
D	Elevator Lobby Office	10	S 28 P F 1 (ELE) W 32 C F 4 (ELE)	F41ILL F44ILL	3	1 0.3	SW SW	873	6 2,708		4 ft LED Tube T 74 R LED	200732x1 RTLED50	15 50	0.2	NONE C-OCC		1,310	1,398 0.2 629 0.1	\$ 207.16 \$ 92.77	\$ 1,452.00 \$	- 7.0 35 5.5	7.0
)	Office	1	W 32 C F 4 (ELE)	F44ILL	11	2 0.1	SW	873	6 978	1	T 74 R LED	RTLED50	50	0.1	NONE	0,000	437	542 0.1	\$ 80.27	\$ 236.25 \$	- 2.9	2.9
)	Office Office	1	W 32 C F 4 (ELE) W 32 C F 4 (ELE)	F44ILL F44ILL	11	2 0.1	SW SW	873	6 978 6 978	1	T 74 R LED T 74 R LED	RTLED50 RTLED50	<u>50</u> 50	0.1	230-3 230-3	<u>6,989</u> 6,989	349 349	629 0.1 629 0.1	\$ 92.77 \$ 92.77		<u>35 5.5</u> 35 5.5	5.1
	1st Floor Office 113A	2	T 32 R F 3 (ÈLE)	F43ILL/2	g	0 0.2	000	873	6 1,572	2	T 59 R LED	RTLED38	38	0.1	C-0CC	6,989	531	1,041 0.1	\$ 153.64	\$ 742.50 \$	35 4.8	4.6
_	<u> </u>	3 4	1T 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL F42LL	6	0 0.2 0 0.2	0000	873 873	6 1,572 6 2,097		4 ft LED Tube 4 ft LED Tube	200732x2 200732x2	<u> </u>	0.1	C-OCC C-OCC	6,989 8,736	629 1,048	943 0.1 1,048 0.1	\$ 139.01 \$ 155.37		35 7.0 35 7.8	6.7
	116 117	2	1T 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL	6	0 0.1	000	873	6 1,048 6 1,048	2	4 ft LED Tube 4 ft LED Tube	200732x2 200732x2	30 30	0.1	0000	8,736	524	524 0.1 629 0.1	\$ 77.68 \$ 92.67	\$ 737.40 \$	35 9.5	9.0
	117	4	1T 32 R F 2 (ELE)	F42LL F42LL	6	0 0.2	000 000	873	6 1,048 6 2,097	4	4 ft LED Tube	200732x2 200732x2	30	0.1	000-0 00-0	6,989	839	1,258 0.1	\$ 92.67 \$ 185.35	T T	35 8.0 35 6.5	6.3
	120 121	2	1T 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL F42L1	6	0.1	000 000	873	6 1,048 6 1.048		4 ft LED Tube 4 ft LED Tube	200732x2 200732x2	<u> </u>	0.1	00-0 0-0		419 419	629 0.1 629 0.1	\$ 92.67 \$ 92.67	· ·	<u>35 8.0</u> 35 8.0	7.6
	122	2	1T 32 R F 2 (ELE)	F42LL	6	0 0.1	000	873	6 1,048	2	4 ft LED Tube	200732x2	30	0.1	C-0CC	8,736	524	524 0.1	\$ 77.68	\$ 737.40 \$	35 9.5	9.0
)	<u> </u>	2 4	1T 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL F42LL	6	0 0.1 0 0.2	000 000	873 873	6 1,048 6 2,097		4 ft LED Tube 4 ft LED Tube	200732x2 200732x2	<u> </u>	0.1	C-OCC NONE		419 1,048	629 0.1 1,048 0.1	\$ 92.67 \$ 155.37		<u> </u>	7.6
))	125 126	2	1T 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL F42LL	6	0 0.1	000 000	873	6 1,048 6 1,572	2	4 ft LED Tube 4 ft LED Tube	200732x2 200732x2	30 30	0.1	000-0 00-0	8,736 8,736	524	524 0.1 786 0.1	\$ 77.68 \$ 116.53		35 9.5 35 8.3	9.0
)	135	9	2T 32 R F 2 (u) (ELE)	FU2LL	6	0 0.5	000	873	6 4,717		2T XX R LED	200732X2 2RTLED	25	0.1	000-0 00-0	8,736	1,966	2,752 0.3	\$ 407.84	\$ 2,092.50 \$	<u> </u>	5.0
D	136 106 Womens Room	8	2T 32 R F 2 (u) (ELE) 1T 32 R F 2 (ELE)	FU2LL F42LL	6	0 0.5	000 000	873	6 4,193 6 1,572	8	2T XX R LED 4 ft LED Tube	2RTLED 200732x2	<u> </u>	0.2	000-0 00-0	8,736	1,747 629	2,446 0.3 943 0.1	\$ 362.52 \$ 139.01		<u>35 5.2</u> 35 7.0	5.1
D D	107 Men's Room	3	1T 32 R F 2 (ELE)	F42LL	6	0 0.2	OCC	873	6 1,572	3	4 ft LED Tube	200732x2	30	0.1	C-0CC	6,989	629	943 0.1	\$ 139.01	\$ 971.10 \$	35 7.0	6.7
))	102 Stair 110	2	1T 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL F42LL	6	0 0.1 0 0.1	000 000	873 873	1,010		4 ft LED Tube 4 ft LED Tube	200732x2 200732x2	<u> </u>	0.1	C-OCC C-OCC	8,736 6,989	524 419	524 0.1 629 0.1	\$ 77.68 \$ 92.67	\$ 737.40 \$	<u>35 9.5</u> 35 8.0	9.0
)	137	1	1T 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL F42LL	6	0 0.1	000 000	873	6 524 6 1.048		4 ft LED Tube 4 ft LED Tube	200732x2 200732x2	<u>30</u> 30	0.0	000-0 00-0	6,989 8,736	210 524	314 0.0 524 0.1	\$ 46.34 \$ 77.68		35 10.9 35 9.5	10.1
)	139	2	1T 32 R F 2 (ELE)	F42LL	6	0.1	000	873	6 1,048	2	4 ft LED Tube	200732x2	30	0.1	000-0 00-0	6,989	419	629 0.1	\$ 92.67	\$ 737.40 \$	35 8.0	7.6
)	<u> </u>	3	1T 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL F42LL	6	0 0.2 0 0.1	000 000	873			4 ft LED Tube 4 ft LED Tube	200732x2 200732x2	30 30	0.1	230-3 230-3		629 419	943 0.1 629 0.1	\$ 139.01 \$ 92.67		<u>35 7.0</u> 35 8.0	6.7
,	142	6	R 13 C CF 2 (ELE)	CFQ13/2-L	2	8 0.2	000	873	6 1,468	6	R 13 C CF 2 (ELE)	CFQ13/2-L	28	0.2	0.000	6,989	1,174	294 0.0	\$ 41.97	\$ 270.00 \$	35 6.4	5.6
	142	2	1T 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL F42LL	6	0.2	000	873	6 2,097 6 1,048	2	4 ft LED Tube 4 ft LED Tube	200732x2 200732x2	<u> </u>	0.1	000-0 00-0	8,736	<u>839</u> 524	1,258 0.1 524 0.1	\$ 185.35 \$ 77.68	· · · · ·	<u>35 6.5</u> 35 9.5	<u> </u>
	144	2	1T 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL F42LL	6	0 0.1	000 000	873	6 1,048	2	4 ft LED Tube 4 ft LED Tube	200732x2 200732x2	30	0.1	000-0	6,989	419 410	629 0.1 629 0.1	\$ 92.67 \$ 92.67	\$ 737.40 \$	35 8.0 35 8.0	7.6
	146	2	1T 32 R F 2 (ELE)	F42LL F42LL	6	0.1	000	873	6 1,048	2	4 ft LED Tube	200732x2 200732x2	30	0.1	0.00-0	6,989	419	629 0.1	\$ 92.67	\$ 737.40 \$	35 8.0 35 8.0	7.6
	<u> </u>	4 2	1T 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL F42LL	6	0 0.2 0 0.1	000 000	873 873	6 2,097 6 1,048		4 ft LED Tube 4 ft LED Tube	200732x2 200732x2	<u> </u>	0.1	C-OCC 220-2		839 419	1,258 0.1 629 0.1	\$ 185.35 \$ 92.67	· · · · ·	35 6.5 35 8.0	6.3
	149 Ath Floor Outbieles	2	1T 32 R F 2 (ELE)	F42LL	6	0.1	000	873	6 1,048	2	4 ft LED Tube	200732x2	30	0.1	C-0CC	6,989	419	629 0.1	\$ 92.67	\$ 737.40 \$	35 8.0	7.6
	4th Floor Cubicles 414	45	1T 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL F42LL	6	0 0.2	000	873 873	6 23,587 6 2,097	4	4 ft LED Tube 4 ft LED Tube	200732x2 200732x2	30 30	1.4 0.1	C-OCC C-OCC	6,989 6,989	9,435 839	14,152 1.4 1,258 0.1	\$ 2,085.18 \$ 185.35	\$ 1,204.80 \$	35 5.2 35 6.5	5.2 6.3
	415 416	3	1T 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL F42LL	6	0 0.2	000 000	873	6 1,572 6 2,097	3	4 ft LED Tube 4 ft LED Tube	200732x2 200732x2	30 30	0.1	000-0 00-0	6,989	629 839	943 0.1 1.258 0.1	\$ 139.01 \$ 185.35		35 7.0 35 6.5	6.7 6.3
	417	2	1T 32 R F 2 (ELE)	F42LL	6	0 0.1	000	873	6 1,048	2	4 ft LED Tube	200732x2	30	0.1	C-0CC	6,989	419	629 0.1	\$ 92.67	\$ 737.40 \$	35 8.0	7.6
	411 Women's Room 409	2 10	R 13 C CF 2 (ELE) 1T 32 R F 2 (ELE)	CFQ13/2-L F42LL	2	8 0.1 D 0.6	000 000	873 873	6 489 6 5,242	10	R 13 C CF 2 (ELE) 4 ft LED Tube	CFQ13/2-L 200732x2	28 30	0.1	C-OCC 220-2	6,989 8,736	391 2,621	98 0.0 2,621 0.3	\$ 13.99 \$ 388.42		35 19.3 35 6.7	<u> </u>
1	407	2	1T 32 R F 2 (ELE)	F42LL	6	0 0.1	000	873	6 <u>1,048</u>	2	4 ft LED Tube	200732x2	30	0.1	0.000	6,989	419	629 0.1	\$ 92.67	\$ 737.40 \$	35 8.0 25 10.0	7.6
	408 408	3	1T 32 R F 2 (ELE) R 13 C CF 2 (ELE)	F42LL CFQ13/2-L	2	B 0.1	0000	873 873	6 524 6 734		4 ft LED Tube R 13 C CF 2 (ELE)	200732x2 CFQ13/2-L	<u>30</u> 28	0.0	C-OCC C-OCC	6,989 8,736	734	314 0.0 - 0.0	\$ 46.34 \$ -	\$ 270.00 \$	35 10.9 35	10.1
	406 404 Men's Room	4	T 54 W F 3 (ELE) (T-5) R 13 C CF 2 (ELE)	F43GHL CFQ13/2-L	17 2	7 0.7 3 0.1	000 000	600 873	0 4,248 6 734		T 54 W F 3 (ELE) (T-5) R 13 C CF 2 (ELE)	F43GHL CFQ13/2-L	177 28	0.7	C-OCC NONE	4,800 8,736	3,398 734	850 0.0 - 0.0	\$ 121.49 \$ -	\$ 270.00 \$ \$ - \$	35 2.2	1.9
	419	1	2T 32 R F 2 (u) (ELE)	FU2LL	6	0 0.1	000	873	6 524	1	2T XX R LED	2RTLED	25	0.0	000-0	6,989	175	349 0.0	\$ 51.56	\$ 472.50 \$	35 9.2	8.5
+	<u> 420</u> 423	1 2	1T 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL F42LL	6	0 0.1 0 0.1	00C 000	873 873	021		4 ft LED Tube 4 ft LED Tube	200732x2 200732x2	<u>30</u> 30	0.0	C-OCC C-OCC		210 419	314 0.0 629 0.1	\$ 46.34 \$ 92.67		35 10.9 35 8.0	10.1 7.6
1	424	4	1T 32 R F 2 (ELE)	F42LL	6	0 0.2	000	873	6 2,097 6 1,015	4	4 ft LED Tube	200732x2	30	0.1	C-0CC	6,989	839	1,258 0.1	\$ 185.35	\$ 1,204.80 \$	35 6.5	6.3
	425 426	2	1T 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL F42LL	6	0 0.1 0 0.1	000 000	873	6 1,048 6 1,048	2	4 ft LED Tube 4 ft LED Tube	200732x2 200732x2	30 30	0.1	C-OCC C-OCC	6,989 6,989	419 419	629 0.1 629 0.1	\$ 92.67 \$ 92.67		35 8.0 35 8.0	7.6
\square	427 428	2 4	1T 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL F42LL	6	0.1	000 000	873	6 1,048 6 2,097	2	4 ft LED Tube 4 ft LED Tube	200732x2 200732x2	30 30	0.1	C-OCC 220-2	,	419 839	629 0.1 1.258 0.1	\$ 92.67 \$ 185.35	\$ 737.40 \$	35 8.0 35 6.5	7.6
	429	6	1T 32 R F 2 (ELE)	F42LL F42LL	6	0 0.4	000	873	6 2,097 6 3,145	6	4 ft LED Tube	200732x2 200732x2	30	0.1	0.000	6,989	1,258	1,258 0.1	\$ 278.02	\$ 1,672.20 \$	35 6.5 35 6.0	5.9
)	430 433	6 3	1T 32 R F 2 (ELE) 1T 32 R F 2 (ELE)	F42LL F42LL	6	0 0.4 0 0.2	000 000	873 873	6 3,145 6 1,572		4 ft LED Tube 4 ft LED Tube	200732x2 200732x2	<u>30</u> 30	0.2	000-0 000-0	6,989 6,989	1,258 629	1,887 0.2 943 0.1	\$ 278.02 \$ 139.01		35 6.0 35 7.0	<u>5.9</u> 6.7
D	435	8	1T 32 R F 2 (ELE)	F42LL	6	0 0.5	OCC	873	6 4,193	8	4 ft LED Tube	200732x2	30	0.2	C-OCC	6,989	1,677	2,516 0.2	\$ 370.70	\$ 2,139.60 \$	35 5.8	5.7
	Elevator Lobby	14	R 13 C CF 2 (ELE)	CFQ13/2-L	2	8 0.4	000	873	6 3,425	14	R 13 C CF 2 (ELE)	CFQ13/2-L	28	0.4	C-OCC	8,736	3,425	- 0.0	\$-	\$ 270.00 \$	<u>კე</u>	
Tel	otal	629				30.5		T	264,301	629				16.0			3,981	14.5	20,724	136,578 \$2,	25	

APPENDIX D

New Jersey Board of Public Utilities Incentives

- i. Smart Start
- ii. Direct Install
- iii. Pay for Performance (P4P)
- iv. Energy Savings Improvement Plan (ESIP)

I. SMART START

HOME RESIDENTIAL COMMERCIAL, INDUSTRIAL MULCOGAL GOVERNMENT Home * Commercial & Industrial * Programs NJ SMARTSTART BUILDINGS NJ SMARTSTART BUILDINGS	Ciean Energy	About Us Press Room Library Wer to Save siness, and for the Future
BPU Image: Second state of the second st	HOME	RESIDENTIAL COMMERCIAL, INDUSTRIAL AND LOGAL GOVERNMENT
HURRICANE SANDY PROGRAMS	BPU (NJ SmartStart Buildings
PROGRAMS BUILDING S		New Jorsoy
BULLDINGS	HURRICANE SANDY	- SmartStart
		BUILDINGS®
With New Jersey SmartStart Buildings	EQUIPMENT INCENTIVES	With New Jersey SmartStart Buildings
	FOOD SERVICE EQUIPMENT	A smart start now means better performance later! Whether you're starting a commer industrial project from the ground up, renovating existing space, or upgrading equipmen unique opportunities to upgrade the energy efficiency of the project.
APPLICATION FORMS	APPLICATION FORMS	
		Enhanced incentives are available for NJ SmartStart Building upgrades in buildings im Hurricane Sandy. Eligible projects receive an additional 50% and new incentives have
Visit the Sandy web page for details and important links.		Visit the Sandy web page for details and important links.
COMBINED HEAT & POWER AND	COMBINED HEAT & POWER AND	
substantial energy savings, both now and for the future. Learn more about:		New Jersey SmartStart Buildings can provide a range of support — at no cost to you — substantial energy savings, both now and for the future. Learn more about:
LOCAL GOVERNMENT ENERGY AUDIT Project Categories		Project Catagorian
Custom Measures	AUDIT	
LARGE ENERGY USERS PROGRAM Incentives for Qualifying Equipment and Projects Program Terms and Conditions Program Terms and Conditions	LARGE ENERGY USERS PROGRAM	M Incentives for Qualifying Equipment and Projects
ENERGY SAVINGS IMPROVEMENT Find a Trade Ally PROGRAM		· · · · · ·
DIRECT INSTALL you must submit an application form (and applicable worksheets) and receive an appro- from the program before any equipment is installed (click here for complete Terms and	DIRECT INSTALL	Please note: pre-approval is required for almost all energy efficiency incentives. T you must submit an application form (and applicable worksheets) and receive an approv from the program before any equipment is installed (click here for complete Terms and (Upon receipt of an approval letter, you may proceed to install the equipment listed on yc
ENERGY BENCHMARKING approved application. Equipment installed prior to the date of the approval letter is not e an incentive. Any customer and/or agent who purchases equipment prior to the re-	ENERGY BENCHMARKING	approved application. Equipment installed prior to the date of the approval letter is not e an incentive. Any customer and/or agent who purchases equipment prior to the rec
OIL, PROPANE & MUNICIPAL incentive approval letter does so at his/her own risk.		incentive approval letter does so at his/ner own risk.
ELECTRIC CUSTOMERS Getting Started	ELECTRIC CUSTOMERS	Getting Started
EDA PROGRAMS Submit your project application form as soon as you know you will be doing a constructi or replacing/adding equipment.	EDA PROGRAMS	Submit your project application form as soon as you know you will be doing a constructiv
SBC CREDIT PROGRAM	SBC CREDIT PROGRAM	

http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/nj-... 5/30/2014

CONTACT US

PAST PROGRAMSApply for pre-approval by submitting an application for the type of equipment you have c
install. The application should be accompanied by a related worksheet, where applicable
manufacturer's specification sheet (refer to the specific program requirements on the ba
application for specs needed for your project) for the equipment you are planning to inst
(Program representatives will review your application package and approve it, reject it, a
advise you of upgrades in equipment that will save energy costs and/or increase your in

Support for Custom Energy-Efficiency Measures

Custom measures allows program participants the opportunity to receive an incentive fo energy-efficiency measures that are not on the prescriptive equipment Incentive list, but project/facility specific.

Incentives for Qualifying Equipment and Projects

Financial incentives are available for large and small projects. These incentives offset so maybe even all! — of the added cost to purchase qualifying energy-efficient equipment, provides significant long-term energy savings. Ranges of incentives are available for quequipment (depending on type, size, and efficiency) in several categories.

Find out more about equipment incentives

For specific details on equipment requirements and financial incentives, including ince equipment not listed here, contact a program representative. Fiscal year financial incent be limited to a maximum of \$500,000 per customer utility account and are available as fipermits.

Home | Residential | Commercial & Industrial | Renewable Energy About Us | Press Room | Library | FAQs | Calendar | Newsletters | Contact Us | Site

CIGan Energy	About Us Press Room Library /er to Save ess. and for the Future
HOME	RESIDENTIAL GOMMERGIAL, INDUSTRIAL AND LOGAL GOVERNMENT
COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT	Home » Commercial & Industrial » Programs » NJ SmartStart Buildings Equipment Incentives Special Notice Enhanced incentives are available for NJ SmartStart Building upgrades in buildings impli- Hurricane Sandy. Eligible projects receive an additional 50% and new incentives have added for high efficiency food service equipment. Visit the Sandy web page for details and important links.
PROGRAMS	More reasons for a smart start on your next project!
NJ SMARTSTART BUILDINGS	New Jersey SmartStart Buildings provides financial incentives for qualifying equipment. These incentives were developed to help our customers offset some of the added cost to purchase qualifying energy-efficient
FOOD SERVICE EQUIPMENT	equipment, which provides significant long-term energy savings. A wide range of incentives are available for qualifying equipment (depending on type, size and
APPLICATION FORMS	efficiency).
TOOLS AND RESOURCES PAY FOR PERFORMANCE	Listed below are the types of qualifying equipment and ranges of incentives. For details on equipment requirements and full listings of incentives, refer to the online application forms .
COMBINED HEAT & POWER AND FUEL CELLS	Please note that almost all equipment incentives require pre-approval before equipment is installed. (click for exceptions)To start the pre-approval process, submit an Equipment Application, and appropriate Equipment Worksheets, for the type of
LOCAL GOVERNMENT ENERGY AUDIT	types of equipment you are planning to install along with equipment specification sheets (refer to the specific program requirements on the back of the application for specificatic needed for your project) and a current utility bill(s).
LARGE ENERGY USERS PROGRAM	In order to be eligible to receive financial incentives under this Program, Applicants mus receive electric and/or gas service from one of the regulated electric and/or gas utilities
ENERGY SAVINGS IMPROVEMENT PROGRAM	the State of New Jersey. They are: Atlantic City Electric, Jersey Central Power & Light, Rockland Electric Company, New Jersey Natural Gas, Elizabethtown Gas, PSE&G, and South Jersey Gas.
DIRECT INSTALL	
ENERGY BENCHMARKING	Electric Chillers
OIL, PROPANE & MUNICIPAL ELECTRIC CUSTOMERS	Water-cooled chillers (\$12 - \$170 per ton) Air-cooled chillers (\$8 - \$52 per ton)
EDA PROGRAMS	Gas Cooling
SBC CREDIT PROGRAM	Gas absorption chillers (\$185-\$450 per ton) Gas Engine-Driven Chillers (Calculated through Custom Measure F

PAST PROGRAMS	
	Desiccant Systems (\$1.00 per cfm - gas or electric)
TOOLS AND RESOURCES	Electric Unitary HVAC
PROGRAM UPDATES	Unitary AC and split systems (\$73 - \$92 per ton)
0017407.00	Air-to-air heat pumps (\$73 - \$92 per ton)
CONTACT US	Water-source heat pumps (\$81 per ton)
	Packaged terminal AC & HP (\$65 per ton)
	Central DX AC Systems (\$40 - \$72 per ton)

Ground Source Heat Pumps

Closed Loop (\$450-750 per ton)

Dual Enthalpy Economizer Controls (\$250) Occupancy Controlled Thermostats (\$75 each) A/C Economizing Controls (\$85 - \$170 each)

Gas Heating

Gas-fired boilers < 300 MBH (\$300 per unit) Gas-fired boilers ≥ 300 MBH - 1500 MBH (\$1.75 per MBH) Gas-fired boilers ≥ 1500 MBH - ≤ 4000 MBH (\$1.00 per MBH) Gas-fired boilers > 4000 MBH (Calculated through Custom Measure Gas furnaces (\$300-\$400 per unit) Gas infrared heaters - indoor only (\$300 - \$500 per unit) Boiler economizing controls (\$1,200 - \$2,700 per unit)

Variable Frequency Drives

Variable air volume (\$65 - \$155 per hp) Chilled-water pumps (\$60 per hp) Compressors (\$5,250 to \$12,500 per drive)

Natural Gas Water Heating

Gas water heaters ≤ 50 gallons (\$50 per unit) Gas-fired water heaters > 50 gallons (\$1.00 - \$2.00 per MBH) Tankless water heaters replacing a free standing water heater > 82 energy factor (\$300 per heater) Gas-fired booster water heaters (\$17 - \$35 per MBH)

Premium Motors

Three-phase motors (\$45 - \$700 per motor) (Incentive was discor effective March 1, 2013 except for buildings impacted by Hurric Sandy. Approved applications will have the standard timefram year from the program commitment date to complete the instal

Refrigerator/Freezer Case Premium Efficiency Motors (ECM)

Fractional (< 1 HP) Electronic Commutated Motors (ECM) (\$40 per for replacement of existing shaded-pole motor in refrigerated/freeze

Prescriptive Lighting

New Linear Fluorescent

T-12. HID and Incandescent to T-5 and T-8 (\$25 - \$200 pe fixture) (Note: T12 replacements are only available for buildings impacted by Hurricane Sandy)

New Induction (\$70 per replaced HID fixture)

New LED

Screw-in/Plug-in (\$10 - \$20 per lamp) Refrigerator/Freezer Case (\$30 - \$65 per fixture) Outdoor pole/arm/wall-mounted luminaires (\$100 - \$175 p fixture) Display case (\$30 per case) Shelf-mounted display and task (\$15 per linear foot) Wall-wash, desk, recessed (\$20 - \$35 per fixture) Parking garage luminaires (\$100 per fixture) Track or Mono-Point directional (\$50 per fixture) Stairwell and Passageway luminaires (\$40 per fixture) High-Bay, Low-Bay (\$150 per fixture) Bollard (\$50 per fixture) luminaires for Ambient Lighting of Interior Commercial Spa Linear panels (\$50 per fixture) Fuel pump canopy (\$100 per fixture) LED retrofit kits (custom measures) New Pulse-Start Metal Hallide (\$25 per fixture) Linear Fluorescent Retrofit (\$10 - \$20 per fixture) Induction Retrofit (\$50 per retrofitted HID fixture)

New Construction/Complete Renovation (performance-based)

Note: Incentives for T-12 to T-5 and T-8 lamps with electronic ballast in facilities (\$10 per fixture, 1-4 lamps) and T-5/T-8 high bay fixtures (\$16 - per fixture) were discontinued effective March 1, 2013 for T-12 retrofits replacements except for buildings impacted by Hurricane Sandy. Approapplications will have the standard timeframe of one year from the proc commitment date to complete the installation

Lighting Controls

Occupancy Sensors

Wall mounted (\$20 per control)

Remote mounted (\$35 per control)

Daylight dimmers (\$25 per fixture controlled, \$50 per fixtur office applications only)

Occupancy controlled hi-low fluorescent controls (\$25 per controlled)

HID or Fluorescent Hi-Bay Controls

Occupancy hi-low (\$35 per fixture controlled)

Daylight dimming (\$45 per fixture controlled)

Refrigeration

Covers and Doors

Energy-Efficient doors for open refrigerated doors/covers per door)

Aluminum Night Curtains for open refrigerated cases (\$3.5 linear foot)

Controls

Door Heater Control (\$50 per control) Electric Defrost Control (\$50 per control) Evaporator Fan Control (\$75 per control) Novelty Cooler Shutoff (\$50 per control)

Food Service Equipment

Cooking

Combination Electric Oven/Steamer (\$1,000 per oven) Combination Gas Oven/Steamer (\$750 per oven) Electric Convection Oven (\$350 per oven) Gas Convection Oven (\$500 per oven) Gas Rack Oven (\$1,000 single, \$2,000 double) Gas Conveyor Oven (\$500 small deck, \$750 large deck) Electric Fryer (\$200 per vat) Gas Fryer (\$749 per vat) Electric Large Vat Fryer (\$200 per vat) Gas Large Vat Fryer (\$200 per vat) Electric Griddle (\$300 per griddle) Gas Griddle (\$125 per griddle) Electric Steam Cooker (\$1,250 per steamer) Gas Steam Cooker (\$2,000 per steamer)

Holding

Full Size Insulated Cabinets (\$300 per cabinet) Three Quarter Size Insulated Cabinets (\$250 per cabinet) Half Size Insulated Cabinets (\$200 per cabinet)

Cooling

Glass Door Refrigerators (\$75 - \$150 per unit) Solid Door Refrigerators (\$50 - \$200 per unit) Glass Door Freezers (\$200 - \$1,000 per unit) Solid Door Freezers (\$100 - \$600 per unit) Ice Machines (\$50 - \$500 per unit)

Cleaning


Dishwashers (\$400 - \$1,500 per unit)


Other Equipment Incentives*

Performance Lighting (\$1.00 per watt per square foot below prograi incentive threshold, currently 5% more energy efficient than ASHR/ 2007 for New Construction only.) Custom electric and gas equipment incentives (not prescriptive)

*Equipment incentives are calculated based on type, efficiency, size, and appliand are evaluated on a case-by-case basis. Contact us for details.

Home | Residential | Commercial & Industrial | Renewable Energy About Us | Press Room | Library | FAQs | Calendar | Newsletters | Contact Us | Site II. DIRECT INSTALL





http://www.njcleanenergy.com/commercial-industrial/programs/direct-install

III. PAY FOR PERFORMANCE (P4P)

About Us | Press Room | Library

COMMERCIAL, INDUS AND LOGAL GOVERNI



Your Power to Save

At Home, for Business, and for the Future

HOME



COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT

HURRICANE SANDY

PROGRAMS

NJ SMARTSTART BUILDINGS

PAY FOR PERFORMANCE

EXISTING BUILDINGS

PARTICIPATION STEPS

APPLICATIONS AND FORMS

APPROVED PARTNERS

NEW CONSTRUCTION

FAQS

BECOME A PARTNER

COMBINED HEAT & POWER AND FUEL CELLS

LOCAL GOVERNMENT ENERGY AUDIT

LARGE ENERGY USERS PROGRAM

ENERGY SAVINGS IMPROVEMENT PROGRAM

DIRECT INSTALL

ENERGY BENCHMARKING

Home » Commercial & Industrial » Programs » Pay for Performance


RESIDENTIAL

Pay for Performance - Existing Buildings

Download program applications and incentive forms.

The Greater the Savings, the Greater Your Incentives

Take a comprehensive, whole-building approach to saving energy in your existing facilit earn incentives that are directly linked to your savings. Pay for Performance relies on a



program partners who provide technical services under direct you. Acting as your energy expert, your partner will develop a reduction plan for each project with a whole-building technica component of a traditional energy audit, a financial plan for fu energy efficient measures and a construction schedule for ins

Eligibility

Existing commercial, industrial and institutional buildings with demand over 100 kW for any of the preceding twelve months to participate including hotels and casinos, large office buildir family buildings, supermarkets, manufacturing facilities, scho shopping malls and restaurants. Buildings that fall into the fol customer classes are not required to meet the 100 kW demai

to participate in the program: hospitals, public colleges and universities, 501(c)(3) non-p affordable multifamily housing, and local governmental entities. Your energy reduction p define a comprehensive package of measures capable of reducing the existing energy consumption of your building by 15% or more.

Exceptions to the 15% threshold requirement may be made for certain industrial, manufiwater treatment and datacenter building types whose annual energy consumption is heaweighted on process loads. Details are available in the high energy intensity section of t page.

ENERGY STAR Portfolio Manager

Pay for Performance takes advantage of the ENERGY STAR Program with Portfolio Manager, EPA's interactive tool that allows facility managers to track and evaluate energy and water consumption across all of their buildings. The tool provides the opportunity to load in the characteristics and energy usage of your buildings and determine an energy performance benchmark score. You can then assess energy management goals over time, identify strategic



opportunities for savings, and receive EPA recognition for superior energy performance.

This rating system assesses building performance by tracking and scoring energy use ir facilities and comparing it to similar buildings. That can be a big help in locating opportucost-justified energy efficiency upgrades. And, based on our findings, you may be invited participate in the Building Performance with ENERGY STAR initiative and receive specirecognition as an industry leader in energy efficiency.

Incentives


OIL, PROPANE & MUNICIPAL ELECTRIC CUSTOMERS	Pay for Performance incentives are awarded upon the satisfactory completion of three p milestones:
EDA PROGRAMS	Incentive #1 - Submittal of complete energy reduction plan prepared by an app program partner - Contingent on moving forward, incentives will be between \$5
SBC CREDIT PROGRAM	\$50,000 based on approximately \$.10 per square foot, not to exceed 50% of the annual energy expense.
PAST PROGRAMS	Incentive #2 - Installation of recommended measures - Incentives are based on the projected level of electricity and natural gas savings resulting from the installation of comprehensive energy-efficiency measures.
PROGRAM UPDATES	Incentive #3 - Completion of Post-Construction Benchmarking Report - A completed report verifying energy reductions based on one year of post-
CONTACT US	implementation results. Incentives for electricity and natural gas savings will be based on actual savings, provided that the minimum performance threshold of savings has been achieved.

A detailed Incentive Structure document is available on the applications and form

Steps to Participation

Click here for a step-by-step description of the program.

Home | Residential | Commercial & Industrial | Renewable Energy About Us | Press Room | Library | FAQs | Calendar | Newsletters | Contact Us | Site



Funding

□ Check the box if an Energy Savings Improvement Program (ESIP) will be a source of funding. ESIP allows government agencies to pay for energy related improvements using the value of the resulting energy savings.
 Do you expect to receive funding under any other efficiency programs? □ No □ Yes If Yes, please specify below:

The for the former of the second seco	
Utility Program #1 – Utility:	Program Name:
Utility Program #2 – Utility:	Program Name:
Federal Program #1 – Organization:	Program Name:
Federal Program #2 – Organization:	Program Name:
Other Program – Organization:	Program Name:

Additional Project information

Additional Utility Account(s)

Account type	Account number
Account type	Account number

Additional Comments:

Complete this application form and send it directly to the Commercial/Industrial Market Manager by e-mail, mail or fax.

New Jersey's Clean Energy Program c/o TRC Energy Services-P4P 900 Route 9 North, Suite 404 • Woodbridge, NJ 07095

Phone: 866-657-6278 • Fax: 732-855-0422 E-mail: P4P@NJCleanEnergy.com

Visit our website: NJCleanEnergy.com/P4P

New Jersey SmartStart Buildings[®] is a registered trademark. Use of the mark without the permission of the New Jersey Board of Public Utilities, Office of Clean Energy is prohibited. *Incentives/Requirements subject to change. 001-FY15-07/14

Pay For Performance-Existing Buildings

Participation Agreement

Definitions:

ADMINISTRATOR - New Jersey Board of Public Utilities (NJBPU)

APPLICATION PROCESS - The Program pays incentives in phases upon satisfactory completion of each of three Program milestones - approval of a complete Energy Reduction Plan, installation of all recommended measures per the Energy Reduction Plan, completion of Post-Construction Benchmarking Report (for incentive amounts, please refer to Incentive Amounts). In order to be eligible for Program Incentives, a Participating Customer or an agent authorized by a Customer, must submit to the Market Manager a properly completed application package application form, Participating Customer's company W-9, twelve consecutive months of the project's utility bills and executed Participation Agreement. All components of the application package must be filled out completely, truthfully and accurately. This application package must be received on or before June 30, 2015 in order to be eligible for the Fiscal Year 2015 Incentives. The Market Manager will review the application package to determine if the project is eligible for a Program Incentive. When approved, the Participating Customer will receive an approval letter from their Case Manager with the estimated authorized first incentive amount and the date by which the Energy Reduction Plan must be submitted. Upon receipt of the approval letter, the Participating Customer and Partner may proceed with work on the Energy Reduction Plan. The Market Manager or agent thereof reserves the right to conduct a pre-inspection of the facility prior to the installation of equipment. This will be done prior to the issuance of the Energy Reduction Plan approval letter. Approval of this Application is not an approval of the project's scope of work. Scope of work is only approved upon approval of the Energy Reduction Plan. See application and program guidelines for more information

CHANGES TO THE PROGRAM – The Program and Participation Agreements may be changed by the Market Manager at any time without notice. Approved applications, however, will be processed to completion under the agreements in effect at the time of the Market Manager's approval.

ELIGIBILITY - Program Incentives are available to existing commercial, industrial and certain multifamily buildings with peak kilowatt demand usage of more than 100 kW in any of the most recent preceding twelve months of utility bills and a customer of the New Jersey Utilities. Market Manager has the discretion to approve applications that fall below the 100 kW minimum by no more than 10%. If the Participant is a municipal electric company customer, and a customer of an investor-owned gas New Jersey Utility, only gas measures will be eligible for incentives under the Program. Similarly, if the Participant is an oil/propane customer and a customer of an investorowned electric New Jersey Utility, only electricity measures will be eligible for incentives under the Program.

Equipment procured by participating Customer through another program affered by the New Jersey Utilities, as applicable, is not eligible for incentives through this Program. Customers who, from July 1, 2013 – June 30, 2014, have not contributed to the Societal benefits Change of the applicable New Jersey Utility may not be eligible for incentives offered through this program.

ENDORSEMENT – The Market Manager and Administrator do not endorse, support or recommend any particular manufacturer, product or system design in promoting this Program.

ENERGY-EFFICIENT MEASURES – Any device eligible to receive a Program Incentive payment through the New Jersey's Clean Energy Commercial and Industrial Program. The total package of measures as presented in the Energy Reduction Plan must have at least a 10% internal rate of return (IRR).

ENERGY REDUCTION PLAN – A document created by the Participating Customer's selected Partner that defines several key aspects of the project including (but not limited to) existing conditions as a result of a whole-building technical analysis, benchmarking summaries, recommended measures, financing plan and implementation schedule.

ENERGY REDUCTION PLAN APPROVAL - After application approval, the Participating Customer and Partner must work together to finalize and submit an Energy Reduction Plan which incorporates a work scope that will achieve the minimum 15% reduction in source energy performance target in accordance with the Program rules and policies along with the Benchmarking Tool, modeling software file, a copy of the executed Partner and Participating Customer contract, an original copy of the executed Installation Agreement and a Request for Incentive #1 Payment form. All components of the submittal package must be filled out completely, truthfully and accurately. The Market Manager, agents thereof and/or the selected Partner must be provided reasonable access to the Participating Customer's facility, staff, tenants and/or others necessary to develop an Energy Reduction Plan that will achieve the minimum 15% performance target as well as the necessary utility billing data as dictated by the Program. The Energy Reduction Plan submittal package will be reviewed and must be approved by the Market Manager prior to payment of Incentive #1. Upon approval of the submittal package, the Customer will receive an Incentive #1 approval letter indicating the date by which all measures in the Energy Reduction Plan must be installed (no later than twelve months following the Energy Reduction Plan submittal approval date).

and the second gap of the second s

INCENTIVE AMOUNTS - Incentive #1 - \$0.10 per square foot of the project with a maximum amount of \$50,000 and minimum of \$5,000, not to exceed 50% of the project's annual energy cost and contingent on installation of measures in the Energy Reduction Plan and receipt of a signed Installation Agreement. If installation does not commence within the required timeframe, Incentive #1 may be required to be returned to the program. In the event the project is cancelled and Incentive #1 is not returned, the project may reapply to the program in the future but another Incentive #1 will not be paid. Incentive #2 - 50% of the total performance-based incentive (combination of Incentives #2 and #3) calculated per Program's incentive structure; Incentive #3 remaining amount based on the realized energy savings of the project. For customers that have successfully participated in the Local Government Energy Audit Program, Incentive #1 will be reduced by 50% to \$0.05 per square foot up to \$25,000. Actual Incentive #1 paid shall not be higher than 5% over the committed amount. Actual Incentive #2 paid shall not be higher than the committed amount, unless the Energy Reduction Plan has been resubmitted due to changes in the work scope. Actual Incentive #3 paid shall be higher or lower than the committed amount based on actual energy savings but shall not be greater than program Incentive Caps

The Market Manager will provide incentives according to those described in this section or as modified upon notice to Participating Customer. All incentive payments are paid directly to the Participating Customer or the Participating Customer's designed as indicated on the application form. The Program is not bound to pay any incentive unless the submittal package associated with the incentive payment is approved by the Market Manager who reserves the sole discretion of approving or disapproving the submittal packages.

INCENTIVE CAP – Program Incentives #2 and #3 will be capped not to exceed 50% of the total actual project cost. Incentive #1 will be capped not to exceed 50% of the project's annual energy cost. The Market Manager reserves the right to limit the amount of the Program Incentives (Incentive #1, #2 and #3) to \$1M per gas and electric account (limited to \$2M per project) in a program year. Campus style facilities, which are mastered-inetered, are subject to the annual incentive cap of \$1 million per gas and electric account. The Participating Costomer will also be subject to an annual Entity Cap of \$4M (Definition of an Entity can be found in the Board Order Docket No. EO07030203).

INSTALLATION AGREEMENT – The Participating Customer must submit an executed Installation Agreement as part of the Request for Incentive #1 Form. By executing the Installation Agreement, the Customer agrees to install all of the measures in the Energy Reduction Plan, which are estimated to result in meeting or exceeding the minimum 15% performance target. The Customer agrees to the performance-based incentives (Incentives #2 & #3) as indicated in the document which are based on the results of the Eaergy Reduction Plan. Implementation of the measures must commence in the time period twelve months following the approval date of the Energy Reduction Plan. Failure to complete the installation of the measures in the Energy Reduction Plan may result in the repayment of Incentive #1. In the event the project is cancelled and Incentive #1 is not returned, the project may reapply to the program in the future but another Incentive #1 will not be paid.

LIMITATION OF LIABILITY – By virtue of participating in this Program, Participating Customers agree to waive any and all claims or damages against TRC Energy Services, the Market Manager, and the Administrator, except the receipt of the Program Incentive. Participating Customers agree that the Market Manager's and Administrator's liability, in connection with this Program, is limited to paying the Program Incentive specified. Under no circumstances shall the Market Manager, its representatives, or subcontractors, or the Administrator be liable for any lost profits, special, punitive, consequential or incidental damages or for any other damages or claims connected with or resulting from participation in this Program. Further, any liability attributed to the Market Manager under this Program shall be individual, and not joint and/or several.

The Market Manager's review and approval of the Energy Reduction Plan cannot be construed to be a determination as to performance, applicability, dollar savings, energy savings, or any other aspect of the proposed project. The Market Manager and Administrator offer no guarantee or warranty of performance of the project's equipment or system. The participant assumes full responsibility and liability for the installation of all equipment, including but not limited to design, specification, all permits, installation, maintenance, performance and financing. By participating in the program and accepting incentive dollars, you agree to hold harmless the Market Manager and Administrator and their respective staffs with respect to the Project

MARKET MANAGER - TRC Energy Services is responsible for managing the New Jersey Clean Energy Commercial & Industrial Programs.

MEASUREMENT & VERIFICATION APPROVAL – Twelve months subsequent to the Incentive #2 Payment Submittal package submission date, measurement and verification of the projected energy reduction will be conducted by the Participating Customer's Partner using the project's post-installation utility data (supplied by the Customer). The Participating Customer must work with their Partner to submit the Incentive #3 Payment Submittal, consisting of the Post-Construction Benchmarking Pay For Performance-Existing Buildings Report, Benchmarking Tool, and Request for Incentive #3 form. All components of the submittal package must be filled out

and the first state of the second

completely, truthfully and accurately. Upon review of the submittal package (by the Market Manager or agent thereof), the remaining 50% of the total performancebased incentive (Incentives #2 & #3) will be released to the Participating Customer. If the Post-Construction Benchmarking Report indicates that the project did not meet the minimum performance target, the post-iustallation completion period may be extended to up to twenty-four months subsequent to the Incentive Payment #2 package submission date. Upon approval of the submittal package, the Customer will receive an Incentive #3 Submittal approval letter indicating successful completion of the program.

NEW JERSEY UTILITIES – The investor-owned electric and/or gas utilities in the State of New Jersey. They are: Atlantic Ciry Electric, Jersey Central Power & Light, Rockland Electric Company, New Jersey Natural Gas, Elizabethtown Gas, PSE&G, and South Jersey Gas.

PARTICIPATING CUSTOMERS - Those non-residential electric and/or gas service customers of the New Jersey Utilities who participate in this Program.

PARTICIPATING CUSTOMER'S CERTIFICATION – Participating Customer agrees that all information is true and that he/she has conformed to all of the Program and equipment requirements per the Program Guidelines. Participating Customer certifies that he/she purchased and installed the equipment listed in the Energy Reduction Plan at their defined New Jersey project location.

PARTNER- An approved professional who provides technical building performance services to Participating Customers, acting as their "energy efficiency expert". Participating Customers are required to hire an approved Pay for Performance Partner to develop the Energy Reduction Plan and facilitate installation of the recommended package of Energy-Efficient Measures. Participants are required to enter into a contractual agreement with a selected Partner which outlines the set of minimum services the Partner will provide to the Participating Customer throughout the life of the project. It is strongly recommended that Participating Customers perform due diligence in selecting a Pay for Performance Partner. Fees charged by the Partner are not regulated by the Program and could vary between Partners.

PERFORMANCE-BASED INCENTIVES – The combination of Incentives #2 and #3, which are based on the projected and actual energy reduction performance of the project.

PERFORMANCE TARGET – A minimum of a 15% annual source energy savings performance target must be achieved in order to participate. The performance target is based on reducing the total energy consumption for the facility. No more than 50% of the total source energy savings may be derived from lighting measures. The total energy savings may not come from a single measure. A 4% performance target may be offered to customers whose annual energy consumption is heavily weighted to manufacturing and process loads. This approach will be reviewed on a case-by-case basis and must be pre-approved by the Market Manager. In order to be considered, the project must involve: A manufacturing facility, including such industries as plastics and packaging, chemicals, petrochemicals, metals, paper and pulp, transportation, biotechnology, pharmaceutical, food and beverage, mining and mineral processing, general manufacturing, equipment manufacturers and data centers; and manufacturing and/or process-related loads, including data center consumption, consume 50% or more of total facility energy consumption. No more than 50% of the total source energy savings may be derived from non-investor owned withlices or fuels.

POST-INSTALLATION APPROVAL – After the complete installation of all measures in the Energy Reduction Plan, the Customer and their Partner must finalize and submit the Incentive #2 Payment Submittal, consisting of the Installation Report, invoices, and Request for Incentive #2 Payment form. All components of the submittal package must be filled out completely, truthfully and accurately. Upon review of the submittal package and verification of the complete installation of all measures in the Energy Reduction Plan (via inspection by the Market Manager or agent thereof), 50% of the total performancebased incentive (Incentives #2 & #3) will be released to the Participating Customer. Upon approval of the submittal package, the Customer will receive an Incentive #2 approval letter indicating the date by which the post-installation Measurement & Verification phase began and will eud (twelve months in length).

The Market Manager reserves the right to verify sales transactions and to have reasonable access to Participating Customer's facility to inspect both pre-existing products or equipment (if applicable) and the Energy-Efficient Measures installed under this Program, either prior to issuing incentives or at a later time. Energy-Efficient Measures must be installed in buildings located within the service territory of one of the New Jersey Utilities (as defined by the Program) as designated on the Participating Customer's Pay for Performance application. Program Incentives are available for qualified Energy-Efficient Measures as listed and described in the Program Guidelines. The Participating Customer must ultimately own the equipment, either through an up-front purchase or at the end of a short-term lease.

PRE-INSTALLED MEASURES - An Energy Reduction Plan must be approved by the program and an approval letter sent to the customer in order for incentives to be committed. Upon receipt of an Energy Reduction Plan, all project facilities must be preinspected. Measures installed prior to pre-inspection of the facility shall not be included as part of the ERP scope of work and will not be eligible for incentives. Measure installation undertaken prior to ERP approval, but after pre-inspection, is done at the customer's own risk. In the event that an Energy Reduction Plan is rejected by the program, the customer will not receive any incentives. PRODUCT INSTALLATION OR EQUIPMENT INSTALLATION - Installation of the Energy-Efficient Measures.

Projects with a contract threshold of \$15,444 are required to pay no less than prevailing wage rate to workers employed in the performance of any construction undertaken in connection with Board of Public Utilities financial assistance, or undertaken to fulfill any condition of receiving Board of Public Utilities financial assistance, including the performance of any contract to construct, renovate or otherwise prepare a facility, the operations of which are necessary for the receipt of Board of Public Utilities financial assistance. By submitting an application, or accepting program incentives, applicant agrees to adhere to New Jersey Prevailing Wage requirements, as applicable.

PROGRAM – New Jersey's Clean Energy Pay for Performance Program offered herein by the New Jersey Board of Public Utilities pursuant to state regulatory approval under the New Jersey Electric Discount and Energy Competition Act, NJSA 48:3-49, et seq.

PROGRAM GUIDELINES - See Pay for Performance Program Guidelines available from your Partner.

PROGRAM INCENTIVES – Refers to the amount or level of incentive that the Program provides to participating customers pursuant to the Program offered herein (see the description under "Incentive Amount" beading).

PROGRAM OFFER – The Program covers products purchased and/or services rendered on or after July 1, 2014. Program Incentives are available to non-residential retail electric and/or gas service customers of the New Jersey Utilities.

PROJECT – A commercial, industrial or multifamily existing building with peak demand in excess of 100 kW in any of the most recent preceding twelve months of electric usage. Multifamily building(s) must be four (4) stories or greater or three (3) stories and under having central heating, cooling, or metering serving more than one building. The 100 kW requirement is waived for the following customer classes: hospitals, non-profits (as defined by section 501(c)(3) of the luternal Revenue Code), public colleges and universities, local government entities, including K-12 schools, and affordable multifamily customers (defined as low income, subsidized, HUD, etc.)

TAX CLEARANCE CERTIFICATION – Businesses must apply for and receive a Tax Clearance Certificate from the New Jersey Division of Taxation before they can receive any incentive, grant or other financial assistance from the Program.

TAX LIABILITY – The Market Manager will not be responsible for any tax liability that may be imposed on any Participating Customer as a result of the payment of Program Incentives. All Participating Customers must supply their federal tax identification number or social security number on the application form in addition to providing a copy of their W-9 form as part of the application package in order to receive a Program Incentive.

TERMINATION – New Jersey's Clean Energy Program reserves the right to extend, modify (this includes modification of Program Incentive levels) or terminate this Program without prior or further notice.

WARRANTIES – THE MARKET MANAGER AND ADMINISTRATOR DO NOT WARRANT THE PERFORMANCE OF INSTALLED EQUIPMENT, AND/OR SERVICES RENDERED AS PART OF THIS PROGRAM, EITHER EXPRESSLY OR IMPLICITY. NO WARRANTIES OR REPRESENTATIONS OF ANY KIND, WHETHER STATUTORY, EXPRESSED, OR IMPLIED, INCLUDING, WITHOUT LIMITATIONS, WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE REGARDING EQUIPMENT OR SERVICES PROVIDED BY A MANUFACTURER OR VENDOR. CONTACT YOUR VENDOR/ SERVICES PROVIDER FOR DETAILS REGARDING PERFORMANCE AND WARRANTIES.

ACKNOWLEDGEMENT – I have read, understood and am in compliance with all rules and regulations concerning this incentive program. I certify that all information provided is correct to the best of my knowledge, and I give the Market Manager permission to share my records with the New Jersey Board of Public Utilities, and contractors it selects to manage, coordinate or evaluate the Pay For Performance Program, including the release of electric and natural gas utility billing information, as well as make available to the public non-sensitive information. I allow reasonable access to my property to inspect the installation and performance of the technologies and installations that are eligible for incentives under the guidelines of New Jersey's Clean Energy Program. This arrangement supersedes all other communications and representations.

CUSTOMER'S SIGNATURE

PARTNER SIGNATURE

By signing, I certify that I have read, understand and agree to the Participation Agreement listed above. IV. ENERGY SAVINGS IMPROVEMENT PLAN (ESIP)

Cigan Engrav	About Us Press Room Librar /er to Save ess, and for the Future
HOME	RESIDENTIAL COMMERCIAL, INDUSTRIA AND LOCAL GOVERNMEN
BPU (Home » Commercial & Industrial » Programs Energy Savings Improvement Program A new State law allows government agencies to make energy related improvements to facilities and pay for the costs using the value of energy savings that result from the im
COMMERCIAL, INDUSTRIAL AND LOCAL GOVERNMENT	Under Chapter 4 of the Laws of 2009 (the law), the "Energy Savings Improvement Program" (ESIP), provides all government agencies in New Jersey with a flexible tool to and reduce energy usage with minimal expenditure of new financial resources.
HURRICANE SANDY PROGRAMS	This Local Finance Notice outlines how local governments can develop and implement their facilities. Below are two sample RFPs:
NJ SMARTSTART BUILDINGS	Local Government School Districts (K-12)
PAY FOR PERFORMANCE	All RFPs must be submitted to the Board for approval at ESIP@bpu.state.nj.us.
COMBINED HEAT & POWER AND FUEL CELLS	The Board also adopted protocols to measure energy savings:
LOCAL GOVERNMENT ENERGY AUDIT LARGE ENERGY USERS PROGRAM ENERGY SAVINGS IMPROVEMENT PROGRAM DIRECT INSTALL	Measuring Energy Savings Procedures for Implementation The ESIP approach may not be appropriate for all energy conservation and energy eff improvements. Local units should carefully consider all alternatives to develop an app best meets their needs. Local units considering an ESIP should carefully review the Lo Notice, the law, and consult with qualified professionals to determine how they should task. The NJ Board of Public Utilities sponsored Sustainable Jersey in the creation of an ESI Guidebook that explains how to implement the program. The guidebook also includes of successful projects and a list of helpful resources.
ENERGY BENCHMARKING OIL, PROPANE & MUNICIPAL ELECTRIC CUSTOMERS EDA PROGRAMS	FIRST STEP – ENERGY AUDIT For local governments interested in pursuing an ESIP, the first step is to perform an er as prescribed in P.L.2012 c.55.
SBC CREDIT PROGRAM	ENERGY REDUCTION PLANS
PAST PROGRAMS	If you have an ESIP plan that needs to be submitted to the Board of Public Utilities, plat to ESIP@bpu.state.nj.us. Please limit the file size to 3MB (or break it into smaller files)
TOOLS AND RESOURCES PROGRAM UPDATES	Frankford Township School District Northern Hunterdon-Voorhees Regional High School
CONTACT US	Manalapan Township (180 MB - Right Click, Save As)

http://www.njcleanenergy.com/commercial-industrial/programs/energy-savings-improvem... 5/30/2014

ESIP PROGRAM

BPU RULES

- 1. Public Entity must decide if they will use an ESCO or DIY method or Hybrid thereof prior to issuing the RFP and the RFP must state the intended method. A change in the project procurement model after the RFP closing date will be cause for immediate rejection and disqualification of potential Clean Energy program incentives.
- 2. RFP procedures shall be adhered to as per the legislation, including the use of BPU approved forms. Any alteration of the forms, without prior approval from the BPU shall be grounds for rejection.
- 3. RFP must include copy of an audit (ASHRAE Level II w/Level III for lighting) and audit must be prepared by a firm classified by DPMC in the 036 discipline.
- 4. All firms, including professional services, whether using ESCO or DIY model, must be DPMC classified.
- 5. If an Architect is engaged by the public entity, the architectural fees are the responsibility of the public entity and must be paid directly to the firm. These fees may be included in the energy cost savings analysis and payback.

ESCO's may contract directly with an architectural firm, in which case the architectural firm serves as a subcontractor to the ESCO and the project related service costs may be included within the project's economic model.

6. Public entity shall conduct pre-bid meetings and site visits per existing statutes.

In the interest of open public bidding transparency, it is a requirement of the BPU that all proposers must attend the pre-proposal bid meeting.

- 7. There shall be no negative cash flow in any year of the program. section 7 (1)(a)
 "the energy savings resulting from the program will be sufficient to cover the cost of the program's energy conservation measures."
- 8. SREC values are not permitted to be used in the energy cost savings calculations.
- 9. Capital cost avoidance values are not to be used in the energy savings calculations.
- 10. Operational and Maintenance (O&M) cost savings may be permitted in the cost savings calculations, but only with supporting documentation.
- 11. Blended utility rates shall not be permitted. Use the actual utility tariff or local contracted rates if there is a third party supplier.

For the RFP proposals, the public entity shall define the utility rates in the RFP

- 12. Contracted third party utility rates may only be used for the term of the contract (5 yr. maximum) Subsequent years are to be projected at the utility tariff rates plus the annual BPU escalation rates.
- 13. Public entity shall conduct M&V (measurement and verification) at the one (1) year operational date and shall provide a copy of the M&V report to the Board of Public Utilities.

For the RFP proposals, the ESCO shall provide the cost for the one (1) year M&V only. For comparative purposes, the one year M&V pricing shall be indicated on the proposal Form VI, under the "Annual Service Costs" column. Additional M&V costs are at the discretion of the local unit and are not to be included in the proposal.

- 14. The decisions made by BPU staff regarding compliance or other issues that arise in connection with the RFP procurement process shall be considered a final decision of the BPU. Any appeal will need to be through the New Jersey Superior Court, Appellate Division.
- 15. For the RFP proposals only, Demand Response (DR) revenues claimed by ESCO's can only be projected for a maximum period of three (3) years. DR revenue projections beyond three years will not be permitted. DR revenues must be included and presented under the "Energy Rebates/Incentives" column of FORM VI.
- 16. ESCO "fees" proposed during the RFP phase of the project cannot increase post-award. ESCO's are required to maintain the fee percentages through final contract negotiations and construction of the Board approved Energy Savings Plan
- 17. Public Bid openings shall be held on the due date of the proposal submissions. The public entity shall announce the name of the bidder and the total dollar amount. After award of a contract, all proposals received will be made available by the owner for public inspection
- 18. Rejection of bids by the public entity shall be conducted in accordance with the appropriate sections of the applicable legislation, as stated in Title 40A:11-13.2. Additionally all proposals must be returned to the respective ESCO's upon rejection.
- 19. Field changes that exceed 5% of the project cost require BPU approval.
- 20. Energy Savings Plans (ESP) that is dependent upon incentives from the Clean Energy Program must review the current program requirements, at the time of application, for each incentive to insure eligibility. If any program incentive is denied, resubmission of all ESIP related forms will be necessary to remain ESIP qualified.

APPENDIX E

Photovoltaic Analysis


Essex County Department of Parks Public Safety Complex


Cost of Electricity	\$0.151	/kWh
Electricity Usage	2,309,237	kWh/yr
System Unit Cost	\$4,000	/kW

Photovoltaic (PV) Solar Power Generation - Screening Assessment

Budgetary		Annual Utility	Savings		Estimated	Total	Federal Tax	New Jersey Renewable	Payback (without	Payback (with
Cost					Maintenance	Savings	Credit	** SREC	incentive)	incentive)
					Savings					
\$	kW	kWh	therms	\$	\$	\$	\$	\$	Years	Years
\$120,000	30.0	38,247	0	\$5,772	0	\$5,772	\$0	\$6,502	20.8	9.8

** Estimated Solar Renewable Energy Certificate Program (SREC) SREC for 15 Years= \$170 /1000kwh





30 kW Enter into PV Watts

PV Watts Inputs***		Enter into PV Watts (always 20 if flat, if
Array Tilt Angle	20	pitched - enter estimated roof angle)
Array Azimuth	180	Enter into PV Watts (default)
Zip Code	07052	Enter into PV Watts
DC/AC Derate Factor	0.83	Enter info PV Watts

PV Watts Output

38,247 annual kWh calculated in PV Watts program

% Offset Calc

Usage PV Generation % offset 2,309,237 (from utilities) 38,247 (generated using PV Watts) 2%

- * http://www.freemaptools.com/area-calculator.htm
- ** http://www.flettexchange.com
- *** http://gisatnrel.nrel.gov/PVWatts_Viewer/index.html

In all in the late

CONREL NATIONAL RENEWARLE ENERGY LABORATORY

Pédekg-dékresynatítév(váp isihány dqf)isinág Edequé fólsokalysi el ili 322 dam – kirolyit p dqil iliyinhyd drogo mhrydd dgat xqfhadhydhol dgat grif qué úháhfa ydaldwyd ela halgifi Yahfayra J bei grif vábahfa foldafhadwich [finad ödi kuninhydpä]el i 512 dam Janovil 11 vil 19 odd 518 p rogelovil 18 kel elabel shuinp dqfhâdhigrafgilhinhydhigit i khiji 512 dam Janovil 11 vil 19 odd 518 p rogelovil 18 kel elabel shuinp dqfhâdhigrafgilhinhydhigit i khiji 512 dam Janovil 11 vil 19 odd 518 p rogelovil 18 kel olibel shuinp dqfhâdhigrafgilhinhydhigit i khiji 512 dam Janovil 11 vil 19 odd 518 p rogelovil 18 kel 0000 dgal algdelê fin oddjele naryblig p ritei walchichigi 518 p rojhdig Haroleochfeldekliki (vép filoyjanal? ojudkél kaw-Sholp Lyhdig) #Kili (wily) (wi

 $\begin{array}{l} 0.1 Molthy InveReitBYZ daw: ProjnakeProjnak, Belleury Ugingi$ e | 8 white Qodwrydad Utopiuz dewit Highing | 6 Oderuchery | 8«QUENA, A = XXD-R M erschnaktige | 6 white Databigting inneVoordingdende Highing | A GOF# #Databigtink, Birnel white XXDBOndangh preder Stational | 6 MOZ HIL, skizging of | 8 eitherbrightine $drg | Baxaarvichijk koherchytes. \\ \end{array}$

Wkhiligdp InWGR HAQ UHCZDOCIDQ PH#kkdalkgrwitehiliochigilagii dq [ii Linulinhquthkirq;/ii dgyfnakhgj;/ii axxed2ki(ii rufi rektmir p dqghalik khkerinhuthkifikiggrundistrationurp rekitidq [iitquda [ii akchiliggrunwitrationhuthkihlifi rghalliGR HAQ UHOZDOCIDQ PH# vikdalkgrwitraryght#

dq|#xxssru#ffrqxxakgj,#arligkj#r#dvlwdgfh#r#dq|# nlgg#z kk#uhjdug# x#%kh#xu#r#%kh#Prgha#ru#dq|# xsgdhv/Mihjkhqv%r#ghz#/nu/rq%r#kh#Prgha

МИКИВ БОЛГ МИКИВ БОЛГ МИКИВ СОЛГ МИКИВ

Month	Solar Radiation	AC Energy	Energy Value
	(kWh / m ² / day)	(kWh)	(\$)
January	2.78	2,259	336
February	3.52	2,556	380
March	4.34	3,398	506
April	4.95	3,620	539
Мау	5.69	4,177	622
June	5.86	4,057	604
July	5.73	4,050	603
August	5.47	3,833	570
September	4.91	3,424	509
October	3.99	2,974	443
November	2.68	2,021	301
December	2.35	1,879	280
nnual	4.36	38,248	\$ 5,693

Location and Station Identification

Requested Location	60 Nelson Place, Newark, NJ, 07102
Weather Data Source	(TMY2) NEWARK, NJ 1.5 mi
Latitude	40.7° N
Longitude	74.17° W
PV System Specifications (Residential)	
DC System Size	30 kW
Module Type	Standard
Array Type	Fixed (open rack)
Array Tilt	20°
Array Azimuth	180°
System Losses	14%
Inverter Efficiency	96%
DC to AC Size Ratio	1.1
Initial Economic Comparison	
Average Cost of Electricity Purchased from Utility	0.15 \$/kWh
Initial Cost	3.30 \$/Wdc
Cost of Electricity Generated by System	0.21 \$/kWh

These values can be compared to get an idea of the cost-effectiveness of this system. However, system costs, system financing options (including 3rd party ownership) and complex utility rates can significantly change the relative value of the PV system.

CHP SCREENING LEVEL PRELIMINARY EVALUATION LeRoy Smith Public Safety Building CASE 1 - a 500kW Reciprocating Engines

BASE CASE	
Boiler Efficiency	80%
Natural Gas Cost	9.16 \$/MMBtu
Electricity Purchase Cost	0.15 \$/kWh
Total Electricity Purchase Cost	\$348,483
Total Gas Purchase Cost	\$47,573
Total Energy Purchase Cost	\$396,056
CHP CASE	
CHP Basis	Recip Cogen Eng.
Engine Generator	Ener-G
Configuration	Recip. Engines
Power Gross Output	500 kW
Plant Auxiliary Power	6%
Engine Availability	0.97
Plant Net Output	470 kW
Fuel Gas LHV	1736 Btu/scft
Fuel Gas HHV	1927 Btu/scft
Fuel Consumption (HHV)	2.3 MMBtu/hr
Heat Recovery Jacket Water Cooler	0.8 MMBtu/hr
Heat Recovery Engine Exhaust	0.4 MMBtu/hr
Engine Maintenance Cost	0.018 \$/kWh
Natural Gas Cost	9.16 \$/MMBtu
Electricity Purchase Cost	0.15 \$/kWh
Total Electricity Purchase Cost	\$0
Total Gas Purchase Cost	\$272,759
Engine Maintenance Cost	\$0
Total CHP Operating Cost	\$272,759
Potential Maximum NJBPU Grant	\$1,000,000
ECONOMIC EVALUATION	
Annual Energy Cost Savings	\$123,297
Project Cost Multiplier	3,800 \$/kW
Project Cost (Incentives Not Included)	\$1,900,000
Total Cost (+20% Soft Cost Markup)	\$2,280,000.0
Simple Payback	18.5 Years
	10.4

Notes:

1) Existing electrical loads are an based on electrical utility data provided by the facility.

2) Existing natural gas loads are based on natural gas utility data provided by the facility.

3) Reciprocating engine purchase and maintenance costs are budget costs are estimated based on previous projects

		Electricity			Natural Ga	s (HHV)		Heating Hot Wa	Heat to	Chiller	
Month	Days	Peak	Average	Total	Total	Average	Average	Total	Avg. Flow	Power	Load
		kW	kW	kWh	MMBtu	MMBtu/hr	MMBtu/hr	MMBtu	GPM	Ratio	Ton
Jan	31	369.94	250.1	186,067	984.9	1.3	0.91	680	46	0.72	0
Feb	28	364.05	252.1	169,436	1038.7	1.5	1.07	717	53	0.86	0
Mar	31	367.40	234.0	174,079	880.2	1.2	0.82	607	41	0.65	50
Apr	30	430.89	251.5	181,090	683.3	0.9	0.65	472	33	0.45	100
May	31	415.36	231.3	172,097	291.1	0.4	0.27	201	13	0.19	200
Jun	30	481.88	281.3	202,550	50.0	0.1	0.05	34	2	0.03	250
Jul	31	558.69	327.4	243,617	10.9	0.0	0.01	8	1	0.01	250
Aug	31	566.30	304.7	226,686	3.9	0.0	0.00	3	0	0.00	250
Sep	30	536.60	308.1	221,855	4.3	0.0	0.00	3	0	0.00	100
Oct	31	442.91	252.8	188,077	91.1	0.1	0.08	63	4	0.06	50
Nov	30	419.00	218.9	157,573	448.7	0.6	0.43	310	21	0.30	20
Dec	31	361.95	250.1	186,110	705.9	0.9	0.65	487	33	0.53	0
	Annual	443		2,309,237	5,193		0.41	3,583	21	0.27	106

CHP CASE																			
	Power	Generation	Power	Engine Gas	Usage (HHV)		Absorption Ch	iller	Total Heatin	g Required	Engine H	eat Recovery	Available	Heat Used b	by Facility	Existin	g Boilers	Total Fuel	СНР
Month	Average	Total	Import	Average	Total	Cooling	Power Red.	Heat	Total	Total	Coolers	Exhaust	Average	From Recip	o. Engine	Heat	Gas Use	Consumption	Efficiency
	kW	kWh	kWh	MMBtu/hr	MMBtu	Ton	kW	MMBtu/hr	MMBtu/hr	MMBtu	MMBtu/hr	MMBtu/hr	MMBtu/hr	MMBtu/hr	MMBtu	MMBtu	MMBtu	MMBtu	%
Jan	370	266,980	0	1.80	1,297	0	0.0	0.0	0.91	680	0.77	0.30	1.07	0.91	659	20	25	1,322	134%
Feb	364	237,300	0	1.77	1,152	0	0.0	0.0	1.07	717	0.77	0.29	1.06	1.06	694	23	29	1,181	146%
Mar	367	265,146	0	1.78	1,288	50	35.0	0.8	1.62	1,203	0.77	0.30	1.07	1.07	770	432	540	1,828	145%
Apr	431	300,937	0	2.09	1,462	100	70.0	1.6	2.25	1,624	0.77	0.35	1.12	1.12	781	842	1,053	2,515	137%
May	415	299,758	0	2.02	1,456	200	140.0	3.2	3.47	2,582	0.77	0.33	1.11	1.11	798	1,784	2,229	3,685	139%
Jun	470	328,248	0	2.28	1,594	250	175.0	4.0	4.05	2,914	0.77	0.38	1.15	1.15	803	2,111	2,639	4,233	133%
Jul	470	339,190	0	2.28	1,647	250	175.0	4.0	4.01	2,984	0.77	0.38	1.15	1.15	830	2,154	2,692	4,339	133%
Aug	470	339,190	0	2.28	1,647	250	175.0	4.0	4.00	2,979	0.77	0.38	1.15	1.15	830	2,149	2,686	4,333	133%
Sep	470	328,248	0	2.28	1,594	100	70.0	1.6	1.60	1,155	0.77	0.38	1.15	1.15	803	352	440	2,034	133%
Oct	443	319,639	0	2.15	1,552	50	35.0	0.8	0.88	658	0.77	0.36	1.13	0.88	638	20	25	1,577	122%
Nov	419	292,630	0	2.03	1,421	20	14.0	0.3	0.75	540	0.77	0.34	1.11	0.75	524	16	20	1,441	116%
Dec	362	261,214	0	1.76	1,269	0	0.0	0.0	0.65	487	0.77	0.29	1.06	0.65	472	15	18	1,287	117%
Annual	421	3,578,479	0	2.04	17,379	106	74	1.7	2.11	18,521	0.77	0.34	1.11	1.01	8,603	9,918	12,398	29,777	132%

22-Dec-14 1

Page 1 of 1

APPENDIX F

Photos

ECM-1 Replace the Split AC Units with High Efficiency Split Units



Existing Split Units

ECM-2 Central



DDC

system

Existing DDC Control Screen

ECM-3 Replace Domestic Hot Water Heaters with Condensing DHW Heater



Existing DHW Heater

ECM-L1 Lighting Replacement / Upgrades



Existing Lights

ECM-L2 Install Lighting Controls (Occupancy Sensors)

No Pictures Available

APPENDIX G

EPA Benchmarking Report



ENERGY STAR® Score¹ For Year Ending: January 31, 2014 Date Generated: December 18, 2014

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property & Contact Information		
Property Address Leroy Smith Public Safety Buildng 60 Nelson Place	Property Owner	Primary Contact
Newark, New Jersey 07102	()	()
Property ID: 4279893		

Energy Consumption and Energy Use Intensity (EUI)									
Site EUI	Annual Energy by Fu	lel	National Median Comparison						
101.3 kBtu/ft ²	Electric - Grid (kBtu)	7,879,113 (60%)	National Median Site EUI (kBtu/ft ²)	53.3					
101.3 KDIU/II	Natural Gas (kBtu)	5,193,106 (40%)	National Median Source EUI (kBtu/ft ²)	123.1					
			% Diff from National Median Source EUI	90%					
Source EUI			Annual Emissions						
234 kBtu/ft ²			Greenhouse Gas Emissions (Metric Tons	1,331					
			CO2e/year)						

Signature & Stamp of Verifying Professional

I _____

_____ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature:	Date:

Licensed Professional

, (____)___-

 	-	

Professional Engineer Stamp (if applicable)